

Washington State Department of
Labor & Industries
Electrical Program

Electricians and Electrical Installations

Chapter 19.28 RCW

July 2014 Edition

Electrical Program



www.ElectricalProgram.Lni.wa.gov

F500-039-111

FIELD SERVICES AND PUBLIC SAFETY

José Rodríguez, Assistant Director

ELECTRICAL PROGRAM

Chief Electrical Inspector
Po Box 44460
Olympia, WA 98504-4460
(360) 902-5249 FAX (360) 902-5595
E-mail: ElectricalProgram@lni.wa.gov

ELECTRICAL LICENSING AND CERTIFICATION

PO Box 44460
Olympia, WA 98504-4460
(360) 902-5269 FAX (360) 902-5296
E-mail: ElectricalProgram@lni.wa.gov

ELECTRICAL PLAN REVIEW

7273 Linderson Way SW
Tumwater, WA 98501-4460
PO Box 44460
Olympia, WA 98504-4460
(360) 902-5246 FAX (360) 902-5595

www.lni.wa.gov/TradesLicensing/Electrical

How to Request an Electrical Inspection:

<http://www.lni.wa.gov/TradesLicensing/Electrical/FeePermlnspl/Permitlnspect/default.asp#3>

REGION ONE

BELLINGHAM, WA 98225-4647 (BHAM)

1720 Ellis St, Suite 200
(360) 647-7300 FAX (360) 647-7310
24 Hr Inspection Line (360) 647-7272

MOUNT VERNON, WA 98273-5500 (MTVE)

525 E College Way, Suite H
(360) 416-3000 FAX (360) 416-3031
24 Hr Inspection Line (360) 416-3005

EVERETT, WA 98208-3727 (TB26)

729 100TH ST SE
(425) 290-1309 FAX (425) 290-1399
24 Hr Inspection Line (425) 290-1310

REGION TWO

BELLEVUE, WA 98005-3037 (NB75)

616 120th Avenue NE, Suite C201
(425) 990-1400 FAX (425) 990-1446
24 Hr Inspection Line (425) 990-1430

TUKWILA, WA 98168-1050 (TB52)

PO Box 69050
12806 Gateway Drive
(206) 835-1000 FAX (206) 835-1199
24 Hr Inspection Line (206) 835-1198

REGION THREE

BREMERTON, WA 98837-1904 (WB07)

500 Pacific Avenue, Suite 400
(360) 415-4000 FAX (360) 415-4048
24 Hr Inspection Line (360) 415-4039

PORT ANGELES, WA 98362-4628 (PTAN)

1605 E Front St, Suite C
(360) 417-2702 FAX (360) 417-2733
24 Hr Inspection Line (360) 417-2722

TACOMA, WA 98402-4453 (WT21)

950 Broadway, Suite 200
(253) 596-3808 FAX (253) 596-3956
24 Hr Inspection Line (253) 596-3822

REGION FOUR

TUMWATER, WA (4814)

PO Box 44814
Olympia WA 98504-4814
7273 Linderson Way SW MS 4814
Tumwater WA 98501-5414
(360) 902-6350 FAX (360) 902-6340
24 Hr Inspection Line (360) 902-5242

ABERDEEN, WA 98520-0013 (WA42)

415 W Wishkah, Suite 1B
(360) 533-8200 FAX (360) 533-8220
24 Hr Inspection Line (360) 533-8229

VANCOUVER, WA 98684-3508 (S14)

312 SE Stonemill Dr, Suite 120
(360) 896-2360 FAX (360) 896-2345
24 Hr Inspection Line (360) 896-2350

KELSO, WA 98626-2650 (S10)

711 Vine St
(360) 575-6900 FAX (360) 575-6918
24 Hr Inspection Line (360) 575-6923

REGION FIVE

KENNEWICK, WA 99338 (KENN)

4310 W 24th Avenue
(509) 735-0100 FAX (509) 735-0120
24 Hr Inspection Line (509) 735-0148 EAST
WENATCHEE, WA 98802-5459 (EWEN)
519 Grant Rd
(509) 886-6500 FAX (509) 886-6510
24 Hr Inspection Line (509) 886-6520

MOSES LAKE, WA 98837-2907 (MLAK)

3001 W Broadway Ave
(509) 764-6900 FAX (509) 764-6923
24 Hr Inspection Line (509) 764-6966

YAKIMA, WA 98902-3480 (YAKI)

15 W Yakima Ave Suite 100
(509) 454-3760 FAX (509) 454-3710
24 Hr Inspection Line 1-800-442-7516

REGION SIX

SPOKANE, WA 99201-2149 (SPOK)

901 N Monroe Suite 100
(509) 324-2640 FAX (509) 324-2655
24 Hr Inspection Line (509) 324-2650

PULLMAN, WA 99163-2416 (PULL)

PO Box 847
1250 Bishop Blvd SE Suite G
(509) 334-5296 or 1-800-509-0025
FAX (509) 334-3417
24 Hr Inspection Line (509) 334-4226

Chapter 19.28 RCW

ELECTRICIANS AND ELECTRICAL INSTALLATIONS

Effective Date June 12, 2014

Table of Contents

PROVISIONS APPLICABLE TO ELECTRICAL INSTALLATIONS	3
19.28.006 Definitions	3
19.28.010 Electrical wiring requirements — General — Exceptions	4
19.28.021 Disputes regarding local regulations — Arbitration — Appeal	4
19.28.031 Rules, regulations, and standards	4
19.28.041 License required — General or specialty licenses — Fees — Application — Bond or cash deposit	5
19.28.051 Examinations — Fees	6
19.28.061 Electrical contractors — Designee of firm to take master electrician or administrator's examination — Administrator's certificate — Fee — Certificate duration, denial, renewal, nontransferable — Master electrician or administrator's duties	6
19.28.071 Licensee's bond — Action on — Priorities — Cash deposit, payment from	7
19.28.081 Actions — Local permits — Proof of licensure	8
19.28.091 Licensing — Exemptions	8
19.28.095 Equipment repair specialty — Scope of work	8
19.28.101 Inspections — Notice to repair and change — Disconnection — Entry — Concealment — Accessibility — Connection to utility — Permits, fees — Limitation — Waiver of provisions during state of emergency	9
19.28.111 Nonconforming installations — Disputes — Reference to board	10
19.28.121 Board — Request for ruling — Fee — Costs	10
19.28.131 Specialty electrical contractor license — Written warning, penalty — Violations of RCW 19.28.010 through 19.28.141 and 19.28.311 through 19.28.361 — Schedule of penalties — Appeal	10
19.28.141 RCW 19.28.101 inapplicable in certain cities and towns, electricity supply agency service areas, and rights-of-way of state highways	11
19.28.151 RCW 19.28.010 through 19.28.141 and 19.28.311 through 19.28.361 inapplicable to telegraph or telephone companies exercising certain functions	11
19.28.161 Certification — Apprentices and trainees — Supervision — Ratio of noncertified and certified workers — Trainee hours verification	11
19.28.171 Electrical trainee hours — Audit — Rules — Confidentiality	12
19.28.181 Application for certificate of competency	13
19.28.191 Certificate of competency — Eligibility for examination — Rules	13
19.28.201 Examination — Times — Certification of results — Contents — Fees	15
19.28.205 In-class education requirements	15
19.28.211 Certificate of competency — Issuance — Renewal — Continuing education — Fees — Effect	16
19.28.221 Persons engaged in trade or business on July 16, 1973	16
19.28.231 Temporary permits	16
19.28.241 Revocation of certificate of competency — Grounds — Procedure	17
19.28.251 Powers and duties of director — Administration of RCW 19.28.161 through 19.28.271 by the department	17
19.28.261 Exemptions from RCW 19.28.161 through 19.28.271	17

19.28.271 Violations of RCW 19.28.161 through 19.28.271 — Schedule of penalties — Appeal.....	18
19.28.281 Electric vehicle infrastructure — Rule adoption.....	18
19.28.291 Violations of chapter — Issuance of subpoenas — Application.	18
PROVISIONS APPLICABLE TO ELECTRICAL INSTALLATIONS AND TELECOMMUNICATIONS INSTALLATIONS	19
19.28.301 Application — Subchapter heading.....	19
19.28.311 Electrical board.	19
19.28.321 Enforcement — State electrical inspectors — Qualifications — Salaries and expenses.....	19
19.28.331 Inspection reports.....	20
19.28.341 Revocation or suspension of license — Grounds — Appeal to board — Fee — Costs.	20
19.28.351 Electrical license fund.	20
19.28.361 Liability for injury or damage.	21
19.28.371 Medical device — Installation, maintenance, or repair — Compliance with chapter — Limit of exemption.....	21
19.28.381 Denial of renewal of certificate or license for outstanding penalties — Notice — Appeal — Hearing.....	21
PROVISIONS APPLICABLE TO TELECOMMUNICATIONS INSTALLATIONS	21
19.28.400 Definitions.	21
19.28.410 Telecommunications systems installations — Subject to this subchapter.....	22
19.28.420 Telecommunications contractor license — Application — Bond — Issuance of license.	22
19.28.430 Administrator's examination — Certificate — Administrator's requirements.....	24
19.28.440 Examination for telecommunications administrators' certificates.	24
19.28.450 Local enforcement of subchapter — Enforcement of chapter.	24
19.28.460 Disputes regarding local regulations — Arbitration — Panel.....	25
19.28.470 Inspections — Report — Required repairs/changes — Accessibility of telecommunications systems.....	25
19.28.480 Unlawful acts — Interpretation of chapter.	26
19.28.490 Violation of chapter — Penalty — Appeal.....	26
19.28.501 Insurance/financial responsibility.....	26
19.28.511 Individual certification not required.....	27
19.28.521 Limitation of action — Proof of valid license required.....	27
19.28.531 Unlawful installation/maintenance — Disputed interpretation — Board to determine methods.....	27
19.28.541 Entity desiring board decision — Process.....	27
19.28.551 Director's authority — Adoption of rules.....	27
19.28.900 Severability — 1935 c 169.	27
19.28.910 Effective date — 1963 c 207.....	28
19.28.911 Severability — 1983 c 206.	28

PROVISIONS APPLICABLE TO ELECTRICAL INSTALLATIONS

19.28.006 Definitions.

The definitions in this section apply throughout this subchapter.

- (1) "Administrator" means a person designated by an electrical contractor to supervise electrical work and electricians in accordance with the rules adopted under this chapter.
- (2) "Basic electrical work" means the work classified in (a) and (b) of this subsection as class A and class B basic electrical work:
 - (a) "Class A basic electrical work" means the like-in-kind replacement of a: Contactor, relay, timer, starter, circuit board, or similar control component; household appliance; circuit breaker; fuse; residential luminaire; lamp; snap switch; dimmer; receptacle outlet; thermostat; heating element; luminaire ballast with an exact same ballast; ten horsepower or smaller motor; or wiring, appliances, devices, or equipment as specified by rule.
 - (b) "Class B basic electrical work" means work other than class A basic electrical work that requires minimal electrical circuit modifications and has limited exposure hazards. Class B basic electrical work includes the following:
 - (i) Extension of not more than one branch electrical circuit limited to one hundred twenty volts and twenty amps each where:
 - (A) No cover inspection is necessary; and
 - (B) The extension does not supply more than two outlets;
 - (ii) Like-in-kind replacement of a single luminaire not exceeding two hundred seventy-seven volts and twenty amps;
 - (iii) Like-in-kind replacement of a motor larger than ten horsepower;
 - (iv) The following low voltage systems:
 - (A) Repair and replacement of devices not exceeding one hundred volt-amperes in Class 2, Class 3, or power limited low voltage systems in one and two-family dwellings;
 - (B) Repair and replacement of the following devices not exceeding one hundred volt-amperes in Class 2, Class 3, or power limited low voltage systems in other buildings, provided the equipment is not for fire alarm or nurse call systems and is not located in an area classified as hazardous by the national electrical code; or
 - (v) Wiring, appliances, devices, or equipment as specified by rule.
- (3) "Board" means the electrical board under [RCW 19.28.311](#).
- (4) "Chapter" or "subchapter" means the subchapter, if no chapter number is referenced.
- (5) "Department" means the department of labor and industries.
- (6) "Director" means the director of the department or the director's designee.
- (7) "Electrical construction trade" includes, but is not limited to, installing or maintaining electrical wires and equipment that are used for light, heat, or power and installing and maintaining remote control, signaling, power limited, or communication circuits or systems.
- (8) "Electrical contractor" means a person, firm, partnership, corporation, or other entity that offers to undertake, undertakes, submits a bid for, or does the work of installing or maintaining wires or equipment that convey electrical current.
- (9) "Equipment" means any equipment or apparatus that directly uses, conducts, insulates, or is operated by electricity but does not mean: Plug-in appliances; or plug-in equipment as determined by the department by rule.
- (10) "Industrial control panel" means a factory-wired or user-wired assembly of industrial control equipment such as motor controllers, switches, relays, power supplies, computers, cathode ray tubes, transducers, and auxiliary devices. The panel may include disconnect means and motor branch circuit protective devices.
- (11) "Journey level electrician" means a person who has been issued a journey level electrician certificate of competency by the department.
- (12) "Like-in-kind" means having similar characteristics such as voltage requirements, current draw, and function, and being in the same location.
- (13) "Master electrician" means either a master journey level electrician or master specialty electrician.
- (14) "Master journey level electrician" means a person who has been issued a master journey level electrician certificate of competency by the department and who may be designated by an electrical contractor to supervise electrical work and electricians in accordance with rules adopted under this chapter.
- (15) "Master specialty electrician" means a person who has been issued a specialty electrician certificate of competency by the department and who may be designated by an electrical contractor to supervise electrical work and electricians in accordance with rules adopted under this chapter.
- (16) "Specialty electrician" means a person who has been issued a specialty electrician certificate of competency by the department.

19.28.010 Electrical wiring requirements — General — Exceptions.

- (1) All wires and equipment, and installations thereof, that convey electric current and installations of equipment to be operated by electric current, in, on, or about buildings or structures, except for telephone, telegraph, radio, and television wires and equipment, and television antenna installations, signal strength amplifiers, and coaxial installations pertaining thereto shall be in strict conformity with this chapter, the statutes of the state of Washington, and the rules issued by the department, and shall be in conformity with approved methods of construction for safety to life and property. All wires and equipment that fall within section 90.2(b)(5) of the National Electrical Code, 1981 edition, are exempt from the requirements of this chapter. The regulations and articles in the National Electrical Code, the national electrical safety code, and other installation and safety regulations approved by the national fire protection association, as modified or supplemented by rules issued by the department in furtherance of safety to life and property under authority hereby granted, shall be *prima facie* evidence of the approved methods of construction. All materials, devices, appliances, and equipment used in such installations shall be of a type that conforms to applicable standards or be indicated as acceptable by the established standards of any electrical product testing laboratory which is accredited by the department. Industrial control panels, utilization equipment, and their components do not need to be listed, labeled, or otherwise indicated as acceptable by an accredited electrical product testing laboratory unless specifically required by the National Electrical Code, 1993 edition.
- (2) Residential buildings or structures moved into or within a county, city, or town are not required to comply with all of the requirements of this chapter, if the original occupancy classification of the building or structure is not changed as a result of the move. This subsection shall not apply to residential buildings or structures that are substantially remodeled or rehabilitated.
- (3) This chapter shall not limit the authority or power of any city or town to enact and enforce under authority given by law, any ordinance, rule, or regulation requiring an equal, higher, or better standard of construction and an equal, higher, or better standard of materials, devices, appliances, and equipment than that required by this chapter. A city or town shall require that its electrical inspectors meet the qualifications provided for state electrical inspectors in accordance with RCW [19.28.321](#). In a city or town having an equal, higher, or better standard the installations, materials, devices, appliances, and equipment shall be in accordance with the ordinance, rule, or regulation of the city or town. Electrical equipment associated with spas, hot tubs, swimming pools, and hydromassage bathtubs shall not be offered for sale or exchange unless the electrical equipment is certified as being in compliance with the applicable product safety standard by bearing the certification mark of an approved electrical products testing laboratory.
- (4) Nothing in this chapter may be construed as permitting the connection of any conductor of any electric circuit with a pipe that is connected with or designed to be connected with a waterworks piping system, without the consent of the person or persons legally responsible for the operation and maintenance of the waterworks piping system.

19.28.021 Disputes regarding local regulations — Arbitration — Appeal.

Disputes arising under RCW [19.28.010](#)(3) regarding whether the city or town's electrical rules, regulations, or ordinances are equal to the rules adopted by the department shall be resolved by arbitration. The department shall appoint two members of the board to serve on the arbitration panel, and the city or town shall appoint two persons to serve on the arbitration panel. These four persons shall choose a fifth person to serve. If the four persons cannot agree on a fifth person, the presiding judge of the superior court of the county in which the city or town is located shall choose a fifth person. A decision of the arbitration panel may be appealed to the superior court of the county in which the city or town is located within thirty days after the date the panel issues its final decision.

19.28.031 Rules, regulations, and standards.

- (1) Prior to January 1st of each year, the director shall obtain an authentic copy of the national electrical code, latest revision. The department, after consulting with the board and receiving the board's recommendations, shall adopt reasonable rules in furtherance of safety to life and property. All rules shall be kept on file by the department. Compliance with the rules shall be *prima facie* evidence of compliance with this chapter. The department upon request shall deliver to all persons, firms, partnerships, corporations, or other entities licensed under this chapter a copy of the rules.
- (2) The department shall also obtain and keep on file an authentic copy of any applicable regulations and standards of any electrical product testing laboratory which is accredited by the department prescribing rules, regulations, and standards for electrical materials, devices, appliances, and equipment, including any modifications and changes that have been made during the previous year.

19.28.041 License required — General or specialty licenses — Fees — Application — Bond or cash deposit.

(1) It is unlawful for any person, firm, partnership, corporation, or other entity to advertise, offer to do work, submit a bid, engage in, conduct, or carry on the business of installing or maintaining wires or equipment to convey electric current, or installing or maintaining equipment to be operated by electric current as it pertains to the electrical industry, without having an unrevoked, unsuspended, and unexpired electrical contractor license, issued by the department in accordance with this chapter. All electrical contractor licenses expire twenty-four calendar months following the day of their issue. The department may issue an electrical contractor license for a period of less than twenty-four months only for the purpose of equalizing the number of electrical contractor licenses that expire each month. Application for an electrical contractor license shall be made in writing to the department, accompanied by the required fee. The application shall state:

- (a) The name and address of the applicant; in case of firms or partnerships, the names of the individuals composing the firm or partnership; in case of corporations, the names of the managing officials thereof;
- (b) The location of the place of business of the applicant and the name under which the business is conducted;
- (c) Employer social security number;
- (d) Evidence of workers' compensation coverage for the applicant's employees working in Washington, as follows:
 - (i) The applicant's industrial insurance account number issued by the department;
 - (ii) The applicant's self-insurer number issued by the department; or
 - (iii) For applicants domiciled in a state or province of Canada subject to an agreement entered into under RCW 51.12.120(7), as permitted by the agreement, filing a certificate of coverage issued by the agency that administers the workers' compensation law in the applicant's state or province of domicile certifying that the applicant has secured the payment of compensation under the other state's or province's workers' compensation law;
- (e) Employment security department number;
- (f) State excise tax registration number;
- (g) Unified business identifier (UBI) account number may be substituted for the information required by (d) of this subsection if the applicant will not employ employees in Washington, and by (e) and (f) of this subsection; and
- (h) Whether a general or specialty electrical contractor license is sought and, if the latter, the type of specialty. Electrical contractor specialties include, but are not limited to: Residential, pump and irrigation, limited energy system, signs, nonresidential maintenance, restricted nonresidential maintenance, appliance repair, and a combination specialty. A general electrical contractor license shall grant to the holder the right to engage in, conduct, or carry on the business of installing or maintaining wires or equipment to carry electric current, and installing or maintaining equipment, or installing or maintaining material to fasten or insulate such wires or equipment to be operated by electric current, in the state of Washington. A specialty electrical contractor license shall grant to the holder a limited right to engage in, conduct, or carry on the business of installing or maintaining wires or equipment to carry electrical current, and installing or maintaining equipment; or installing or maintaining material to fasten or insulate such wires or equipment to be operated by electric current in the state of Washington as expressly allowed by the license.

(2) The department may verify the workers' compensation coverage information provided by the applicant under subsection (1)(d) of this section, including but not limited to information regarding the coverage of an individual employee of the applicant. If coverage is provided under the laws of another state, the department may notify the other state that the applicant is employing employees in Washington.

(3) The application for an electrical contractor license shall be accompanied by a bond in the sum of four thousand dollars with the state of Washington named as obligee in the bond, with good and sufficient surety, to be approved by the department. The bond shall at all times be kept in full force and effect, and any cancellation or revocation thereof, or withdrawal of the surety therefrom, suspends the license issued to the principal until a new bond has been filed and approved as provided in this section. Upon approval of a bond, the department shall on the next business day deposit the fee accompanying the application in the electrical license fund and shall file the bond in the office. The department shall upon request furnish to any person, firm, partnership, corporation, or other entity a certified copy of the bond upon the payment of a fee that the department shall set by rule. The fee shall cover but not exceed the cost of furnishing the certified copy. The bond shall be conditioned that in any installation or maintenance of wires or equipment to convey electrical current, and equipment to be operated by electrical current, the principal will comply with the provisions of this chapter and with any electrical ordinance, building code, or regulation of a city or town adopted pursuant to RCW 19.28.010(3) that is in effect at the time of entering into a contract. The bond shall be conditioned further that the principal will pay for all labor, including employee benefits, and material furnished or used upon the work, taxes and contributions to the state of Washington, and all damages that may be sustained by any person, firm, partnership, corporation, or other entity due to a failure of the principal to make the installation or maintenance in accordance with this chapter or any applicable ordinance, building code, or regulation of a city or town adopted pursuant to RCW 19.28.010(3). In lieu of the surety bond required by this section, the license applicant may file with the department a cash deposit or other negotiable security acceptable to the department. If the license applicant has filed a cash deposit, the department shall deposit the funds in a special trust savings account in a commercial bank, mutual savings bank, or savings and loan association and shall pay annually to the depositor the interest derived from the account.

(4) The department shall issue general or specialty electrical contractor licenses to applicants meeting all of the requirements of this chapter. The provisions of this chapter relating to the licensing of any person, firm, partnership, corporation, or other entity including the requirement of a bond with the state of Washington named as obligee therein and the collection

of a fee therefor, are exclusive, and no political subdivision of the state of Washington may require or issue any licenses or bonds or charge any fee for the same or a similar purpose. No person, firm, partnership, corporation, or other entity holding more than one specialty contractor license under this chapter may be required to pay an annual fee for more than one such license or to post more than one four thousand dollar bond, equivalent cash deposit, or other negotiable security.

- (5) To obtain a general or specialty electrical contractor license, the applicant must designate an individual who currently possesses a valid master journey level electrician's certificate of competency, master specialty electrician's certificate of competency in the specialty for which application has been made, or administrator's certificate as a general electrical contractor administrator or as a specialty electrical contractor administrator in the specialty for which application has been made.
- (6) Administrator certificate specialties include, but are not limited to: Residential, pump and irrigation or domestic pump, limited energy system, signs, nonresidential maintenance, restricted nonresidential maintenance, appliance repair, and combination specialty. To obtain an administrator's certificate, an individual must pass an examination as set forth in RCW 19.28.051 unless the applicant was a licensed electrical contractor at any time during 1974. Applicants who were electrical contractors licensed by the state of Washington at any time during 1974 are entitled to receive a general electrical contractor administrator's certificate without examination if the applicants apply prior to January 1, 1984. The board of electrical examiners shall certify to the department the names of all persons who are entitled to either a general or specialty electrical contractor administrator's certificate.
- (7) For a contractor doing domestic water pumping system work as defined by RCW 18.106.010(10)(c), the department shall consider the requirements of subsections (1)(a) through (h), (2), and (3) of this section to have been met to be a pump and irrigation or domestic pump licensed electrical contractor if the contractor has met the contractor registration requirements of chapter 18.27 RCW. The department shall establish a single registration/licensing document for those who qualify for both general contractor registration as defined in chapter 18.27 RCW and a pump and irrigation or domestic pump electrical contractor license as defined by this chapter.

19.28.051 Examinations — Fees.

It shall be the purpose and function of the board to establish, in addition to a general electrical contractors' license, such classifications of specialty electrical contractors' licenses as it deems appropriate with regard to individual sections pertaining to state adopted codes in this chapter. In addition, it shall be the purpose and function of the board to establish and administer written examinations for general electrical administrators' certificates and the various specialty electrical administrators' certificates. Examinations shall be designed to reasonably ensure that general and specialty electrical administrators' certificate holders are competent to engage in and supervise the work covered by this statute and their respective licenses. The examinations shall include questions from the following categories to ensure proper safety and protection for the general public: (1) Safety, (2) state electrical code, and (3) electrical theory. The department with the consent of the board shall be permitted to enter into a contract with a professional testing agency to develop, administer, and score these examinations, or accept certifications or other appropriate demonstrations established by independent entities that otherwise fulfill the examination requirements of this section. Individuals who can provide evidence to the department, prior to January 1, 2007, that they have been employed as a pump installer in the pump and irrigation or domestic pump business by an appropriately licensed electrical contractor, registered general contractor defined by chapter 18.27 RCW, or appropriate general specialty contractor defined by chapter 18.27 RCW for not less than eight thousand hours in the most recent six calendar years shall be issued the appropriate administrator's certificate by the department upon receiving such documentation and applicable fees. The fee for the examination may be set by the department in its contract with the professional testing agency. The department may direct that the applicant pay the fee to the professional testing agency. The fee shall cover but not exceed the costs of preparing and administering the examination. It shall be the further purpose and function of this board to advise the director as to the need of additional electrical inspectors and compliance officers to be utilized by the director on either a full-time or part-time employment basis and to carry out the duties enumerated in RCW 19.28.161 through 19.28.271 as well as generally advise the department on all matters relative to RCW 19.28.161 through 19.28.271.

19.28.061 Electrical contractors — Designee of firm to take master electrician or administrator's examination — Administrator's certificate — Fee — Certificate duration, denial, renewal, nontransferable — Master electrician or administrator's duties.

- (1) Each applicant for an electrical contractor's license, other than an individual, shall designate a supervisory employee or member of the firm to take the required master electrician's or administrator's examination. Effective July 1, 1987, a supervisory employee designated as the electrical contractor's master electrician or administrator shall be a full-time supervisory employee. This person shall be designated as master electrician or administrator under the license. No person may concurrently qualify as master electrician or administrator for more than one contractor. If the relationship of the master electrician or administrator with the electrical contractor is terminated, the contractor's license is void within

ninety days unless another master electrician or administrator is qualified by the board. However, if the master electrician or administrator dies or is otherwise incapacitated, the contractor's license is void within one hundred eighty days unless another master electrician or administrator is qualified by the board. The contractor must notify the department in writing within ten days if the master electrician's or administrator's relationship with the contractor terminates due to the master electrician's or administrator's death or incapacitation.

(2) The department must issue an administrator's certificate to all applicants who have passed the examination as provided in RCW [19.28.051](#) and this section, and who have complied with the rules adopted under this chapter. The administrator's certificate must bear the date of issuance, expires on the holder's birthday, and is nontransferable. The certificate must be renewed every three years, upon application, on or before the holder's birthday.

- (a) If the certificate holder demonstrates to the department that he or she has satisfactorily completed an annual eight-hour continuing education course, the certificate may be renewed by appropriate application without examination unless the certificate has been revoked, suspended, or not renewed within ninety days after the expiration date. For holders of pump and irrigation or domestic pump specialty administrator certificates, the continuing education may comprise both electrical and plumbing education.
- (b) The contents and requirements for satisfactory completion of the continuing education course must be determined by the director and approved by the board.
- (c) The department must accept proof of a certificate holder's satisfactory completion of a continuing education course offered in another state as meeting the requirements for maintaining a current Washington state certificate if the department is satisfied the course is comparable in nature to that required in Washington state for maintaining a current certificate.

(3) A fee must be assessed for each administrator's certificate and for each renewal. An individual holding more than one administrator's certificate under this chapter is not required to pay fees for more than one certificate. The department must set the fees by rule for issuance and renewal of a certificate. The fees must cover, but not exceed, the costs of issuing the certificates and of administering and enforcing the administrator certification requirements of this chapter.

(4) The department may deny an application for an administrator's certificate for up to two years if the applicant's previous administrator's certificate has been revoked for a serious violation and all appeals concerning the revocation have been exhausted. For the purposes of this section only, a serious violation is a violation that presents imminent danger to the public. The certificate may be renewed for a three-year period without examination by appropriate application unless the certificate has been revoked, suspended, or not renewed within ninety days after the expiration date. If the certificate is not renewed before the expiration date, the individual shall pay twice the usual fee. A person may take the administrator's examination as many times as necessary to pass without limit.

(5) The designated master electrician or administrator shall:

- (a) Be a member of the firm or a supervisory employee and shall be available during working hours to carry out the duties of an administrator under this section;
- (b) Ensure that all electrical work complies with the electrical installation laws and rules of the state;
- (c) Ensure that the proper electrical safety procedures are used;
- (d) Ensure that all electrical labels, permits, and licenses required to perform electrical work are used;
- (e) See that corrective notices issued by an inspecting authority are complied with; and
- (f) Notify the department in writing within ten days if the master electrician or administrator terminates the relationship with the electrical contractor.

(6) The department shall not by rule change the administrator's duties under subsection (5) of this section.

19.28.071 Licensee's bond — Action on — Priorities — Cash deposit, payment from.

Any person, firm, or corporation sustaining any damage or injury by reason of the principal's breach of the conditions of the bond required under RCW [19.28.041](#) may bring an action against the surety named therein, joining in the action the principal named in the bond; the action shall be brought in the superior court of any county in which the principal on the bond resides or transacts business, or in the county in which the work was performed as a result of which the breach is alleged to have occurred; the action shall be maintained and prosecuted as other civil actions. Claims or actions against the surety on the bond shall be paid in full in the following order of priority: (1) Labor, including employee benefits, (2) materials and equipment used upon such work, (3) taxes and contributions due to the state, (4) damages sustained by any person, firm or corporation due to the failure of the principal to make the installation in accordance with the provisions of chapter [19.28](#) RCW, or any ordinance, building code, or regulation applicable thereto: PROVIDED, That the total liability of the surety on any bond shall not exceed the sum of four thousand dollars and the surety on the bond shall not be liable for monetary penalties; and any action shall be brought within one year from the completion of the work in the performance of which the breach is alleged to have occurred. The surety shall mail a conformed copy of the judgment against the bond to the department within seven days.

In the event that a cash or securities deposit has been made in lieu of the surety bond, and in the event of a judgment being entered against such depositor and deposit, the director shall upon receipt of a certified copy of a final judgment, pay said judgment from such deposit.

19.28.081 Actions — Local permits — Proof of licensure.

No person, firm or corporation engaging in, conducting or carrying on the business of installing wires or equipment to convey electric current, or installing apparatus to be operated by said current, shall be entitled to commence or maintain any suit or action in any court of this state pertaining to any such work or business, without alleging and proving that such person, firm or corporation held, at the time of commencing and performing such work, an unexpired, unrevoked and unsuspended license issued under the provisions of this chapter; and no city or town requiring by ordinance or regulation a permit for inspection or installation of such electrical work, shall issue such permit to any person, firm or corporation not holding such license.

19.28.091 Licensing — Exemptions.

- (1) No license under the provision of this chapter shall be required from any utility or any person, firm, partnership, corporation, or other entity employed by a utility because of work in connection with the installation, repair, or maintenance of lines, wires, apparatus, or equipment owned by or under the control of a utility and used for transmission or distribution of electricity from the source of supply to the point of contact at the premises and/or property to be supplied and service connections and meters and other apparatus or appliances used in the measurement of the consumption of electricity by the customer.
- (2) No license under the provisions of this chapter shall be required from any utility because of work in connection with the installation, repair, or maintenance of the following:
 - (a) Lines, wires, apparatus, or equipment used in the lighting of streets, alleys, ways, or public areas or squares;
 - (b) Lines, wires, apparatus, or equipment owned by a commercial, industrial, or public institution customer that are an integral part of a transmission or distribution system, either overhead or underground, providing service to such customer and located outside the building or structure: PROVIDED, That a utility does not initiate the sale of services to perform such work;
 - (c) Lines and wires, together with ancillary apparatus, and equipment, owned by a customer that is an independent power producer who has entered into an agreement for the sale of electricity to a utility and that are used in transmitting electricity from an electrical generating unit located on premises used by such customer to the point of interconnection with the utility's system.
- (3) Any person, firm, partnership, corporation, or other entity licensed under RCW 19.28.041 may enter into a contract with a utility for the performance of work under subsection (2) of this section.
- (4) No license under the provisions of this chapter shall be required from any person, firm, partnership, corporation, or other entity because of the work of installing and repairing ignition or lighting systems for motor vehicles.
- (5) No license under the provisions of this chapter shall be required from any person, firm, partnership, corporation, or other entity because of work in connection with the installation, repair, or maintenance of wires and equipment, and installations thereof, exempted in RCW 19.28.010.
- (6) The department may by rule exempt from licensing requirements under this chapter work performed on premanufactured electric power generation equipment assemblies and control gear involving the testing, repair, modification, maintenance, or installation of components internal to the power generation equipment, the control gear, or the transfer switch.
- (7) This chapter does not require an electrical contractor license if: (a) An appropriately certified electrician or a properly supervised certified electrical trainee is performing the installation, repair, or maintenance of wires and equipment for a nonprofit corporation that holds a current tax exempt status as provided under 26 U.S.C. Sec. 501(c)(3) or a nonprofit religious organization; (b) the certified electrician or certified electrical trainee is not compensated for the electrical work; and (c) the value of the electrical work does not exceed thirty thousand dollars.
- (8) An entity that currently holds a valid specialty or general plumbing contractor's registration under chapter 18.27 RCW may employ a certified plumber, a certified residential plumber, or a plumber trainee meeting the requirements of chapter 18.106 RCW to perform electrical work that is incidentally, directly, and immediately appropriate to the like-in-kind replacement of a household appliance or other small household utilization equipment that requires limited electric power and limited waste and/or water connections. A plumber trainee must be supervised by a certified plumber or a certified residential plumber while performing electrical work. The electrical work is subject to the permitting and inspection requirements of this chapter.

19.28.095 Equipment repair specialty — Scope of work.

- (1) The scope of work for the equipment repair specialty involves servicing, maintaining, repairing, or replacing utilization equipment.
- (2) "Utilization equipment" means equipment that is: (a) Self-contained on a single skid or frame; (b) factory built to standardized sizes or types; (c) listed or field evaluated by a laboratory or approved by the department under WAC 296-46B-030; and (d) connected as a single unit to a single source of electrical power limited to a maximum of six hundred volts. The equipment may also be connected to a separate single source of electrical control power limited to a maximum

of two hundred fifty volts. Utilization equipment does not include devices used for occupant space heating by industrial, commercial, hospital, educational, public, and private commercial buildings, and other end users.

(3) "Servicing, maintaining, repairing, or replacing utilization equipment" includes:

- (a) The like-in-kind replacement of the equipment if the same unmodified electrical circuit is used to supply the equipment being replaced;
- (b) The like-in-kind replacement or repair of remote control components that are integral to the operation of the equipment;
- (c) The like-in-kind replacement or repair of electrical components within the equipment; and
- (d) The disconnection, replacement, and reconnection of low-voltage control and line voltage supply whips not over six feet in length provided there are no modifications to the characteristics of the branch circuit.

(4) "Servicing, maintaining, repairing, or replacing utilization equipment" does not include:

- (a) The installation, repair, or modification of wiring that interconnects equipment and/or remote components, branch circuit conductors, services, feeders, panelboards, disconnect switches, motor control centers, remote magnetic starters/contactors, or raceway/conductor systems interconnecting multiple equipment or other electrical components;
- (b) Any work providing electrical feeds into the power distribution unit or installation of conduits and raceways; or
- (c) Any electrical work governed under article(s) 500, 501, 502, 503, 504, 505, 510, 511, 513, 514, 515, or 516 NEC (i.e., classified locations), except for electrical work in sewage pumping stations.

19.28.101 Inspections — Notice to repair and change — Disconnection — Entry — Concealment — Accessibility — Connection to utility — Permits, fees — Limitation — Waiver of provisions during state of emergency.

(1) The director shall cause an inspector to inspect all wiring, appliances, devices, and equipment to which this chapter applies except for basic electrical work as defined in this chapter. The department may not require an electrical work permit for class A basic electrical work unless deficiencies in the installation or repair require inspection. The department may inspect class B basic electrical work on a random basis as specified by the department in rule. Nothing contained in this chapter may be construed as providing any authority for any subdivision of government to adopt by ordinance any provisions contained or provided for in this chapter except those pertaining to cities and towns pursuant to RCW 19.28.010(3).

(2) Upon request, electrical inspections will be made by the department within forty-eight hours, excluding holidays, Saturdays, and Sundays. If, upon written request, the electrical inspector fails to make an electrical inspection within twenty-four hours, the serving utility may immediately connect electrical power to the installation if the necessary electrical work permit is displayed: PROVIDED, That if the request is for an electrical inspection that relates to a mobile home installation, the applicant shall provide proof of a current building permit issued by the local government agency authorized to issue such permits as a prerequisite for inspection approval or connection of electrical power to the mobile home.

(3) Whenever the installation of any wiring, device, appliance, or equipment is not in accordance with this chapter, or is in such a condition as to be dangerous to life or property, the person, firm, partnership, corporation, or other entity owning, using, or operating it shall be notified by the department and shall within fifteen days, or such further reasonable time as may upon request be granted, make such repairs and changes as are required to remove the danger to life or property and to make it conform to this chapter. The director, through the inspector, is hereby empowered to disconnect or order the discontinuance of electrical service to conductors or equipment that are found to be in a dangerous or unsafe condition and not in accordance with this chapter. Upon making a disconnection the inspector shall attach a notice stating that the conductors have been found dangerous to life or property and are not in accordance with this chapter. It is unlawful for any person to reconnect such defective conductors or equipment without the approval of the department, and until the conductors and equipment have been placed in a safe and secure condition, and in a condition that complies with this chapter.

(4) The director, through the electrical inspector, has the right during reasonable hours to enter into and upon any building or premises in the discharge of his or her official duties for the purpose of making any inspection or test of the installation of new construction or altered electrical wiring, electrical devices, equipment, or material contained in or on the buildings or premises. No electrical wiring or equipment subject to this chapter may be concealed until it has been approved by the inspector making the inspection. At the time of the inspection, electrical wiring or equipment subject to this chapter must be sufficiently accessible to permit the inspector to employ any testing methods that will verify conformance with the national electrical code and any other requirements of this chapter.

(5) Persons, firms, partnerships, corporations, or other entities making electrical installations shall obtain inspection and approval from an authorized representative of the department as required by this chapter before requesting the electric utility to connect to the installations. Electric utilities may connect to the installations if approval is clearly indicated by certification of the electrical work permit required to be affixed to each installation or by equivalent means, except that increased or relocated services may be reconnected immediately at the discretion of the utility before approval if an electrical work permit is displayed. The permits shall be furnished upon payment of the fee to the department.

(6) The director, subject to the recommendations and approval of the board, shall set by rule a schedule of license and electrical work permit fees that will cover the costs of administration and enforcement of this chapter. The rules shall be

adopted in accordance with the administrative procedure act, chapter 34.05 RCW. No fee may be charged for plug-in mobile homes, recreational vehicles, or portable appliances.

(7) Nothing in this chapter shall authorize the inspection of any wiring, appliance, device, or equipment, or installations thereof, by any utility or by any person, firm, partnership, corporation, or other entity employed by a utility in connection with the installation, repair, or maintenance of lines, wires, apparatus, or equipment owned by or under the control of the utility. All work covered by the national electric code not exempted by the 1981 edition of the national electric code 90-2(B)(5) shall be inspected by the department.

(8) During a state of emergency declared under RCW 43.06.010(12), the governor may waive or suspend the collection of fees under this section or any portion of this section or under any administrative rule, and issue any orders to facilitate the operation of state or local government or to promote and secure the safety and protection of the civilian population.

19.28.111 Nonconforming installations — Disputes — Reference to board.

It is unlawful for any person, firm, partnership, corporation, or other entity to install or maintain any electrical wiring, appliances, devices, or equipment not in accordance with this chapter. In cases where the interpretation and application of the installation or maintenance standards prescribed in this chapter is in dispute or in doubt, the board shall, upon application of any interested person, firm, partnership, corporation, or other entity, determine the methods of installation or maintenance or the materials, devices, appliances, or equipment to be used in the particular case submitted for its decision.

19.28.121 Board — Request for ruling — Fee — Costs.

Any person, firm, partnership, corporation, or other entity desiring a decision of the board pursuant to RCW 19.28.111 shall, in writing, notify the director of such desire and shall accompany the notice with a certified check payable to the department in the sum of two hundred dollars. The notice shall specify the ruling or interpretation desired and the contention of the person, firm, partnership, corporation, or other entity as to the proper interpretation or application on the question on which a decision is desired. If the board determines that the contention of the applicant for a decision was proper, the two hundred dollars shall be returned to the applicant; otherwise it shall be used in paying the expenses and per diem of the members of the board in connection with the matter. Any portion of the two hundred dollars not used in paying the per diem and expenses of the board in the case shall be paid into the electrical license fund.

19.28.131 Specialty electrical contractor license — Written warning, penalty — Violations of RCW 19.28.010 through 19.28.141 and 19.28.311 through 19.28.361 — Schedule of penalties — Appeal.

*****CHANGE IN 2014 – Effective 07/01/2015*** (SEE 2146-S.SL)*****

Until July 1, 2007, the department shall issue a written warning to any specialty contractor, performing the scope of work defined by rule for the pump and irrigation or domestic pump specialties, not having a valid electrical contractor license. The warning will state that the contractor must be qualified for and apply for a specialty electrical contractor license under the requirements in RCW 19.28.041 within thirty calendar days of the warning. Only one warning will be issued to any contractor. If the contractor fails to comply with this section, the department shall issue a penalty or penalties as authorized in this section to the contractor. Any person, firm, partnership, corporation, or other entity violating any of the provisions of RCW 19.28.010 through 19.28.141 and 19.28.311 through 19.28.361 shall be assessed a penalty of not less than fifty dollars or more than ten thousand dollars. The department shall set by rule a schedule of penalties for violating RCW 19.28.010 through 19.28.141 and 19.28.311 through 19.28.361. The department shall notify the person, firm, partnership, corporation, or other entity violating any of the provisions of RCW 19.28.010 through 19.28.141 and 19.28.311 through 19.28.361 of the amount of the penalty and of the specific violation using a method by which the mailing can be tracked or the delivery can be confirmed sent to the last known address of the assessed party. Any penalty is subject to review by an appeal to the board. The filing of an appeal stays the effect of the penalty until the board makes its decision. The appeal shall be filed within twenty days after notice of the penalty is given to the assessed party using a method by which the mailing can be tracked or the delivery can be confirmed, sent to the last known address of the assessed party and shall be made by filing a written notice of appeal with the department. The notice shall be accompanied by a certified check for two hundred dollars, which shall be returned to the assessed party if the decision of the department is not sustained by the board. If the board sustains the decision of the department, the two hundred dollars shall be applied by the department to the payment of the per diem and expenses of the members of the board incurred in the matter, and any balance remaining after payment of per diem and expenses shall be paid into the electrical license fund. The hearing and review procedures shall be conducted in accordance with chapter 34.05 RCW. The board shall assign its hearings to an administrative law judge to conduct the hearing and issue a proposed decision and order. The board shall be allowed a minimum of twenty days to review a proposed decision and shall issue its decision no later than the next regularly scheduled board meeting.

19.28.141 RCW 19.28.101 inapplicable in certain cities and towns, electricity supply agency service areas, and rights-of-way of state highways.

(1) Except as provided in subsection (2) of this section, the provisions of RCW 19.28.101 shall not apply:

- (a) Within the corporate limits of any incorporated city or town which has heretofore adopted and enforced or subsequently adopts and enforces an ordinance requiring an equal, higher or better standard of construction and of materials, devices, appliances and equipment than is required by this chapter.
- (b) Within the service area of an electricity supply agency owned and operated by a city or town which is supplying electricity and enforcing a standard of construction and materials outside its corporate limits [on] July 1, 1963. The city, town, or agency shall enforce by inspection within its service area outside its corporate limits the same standards of construction and of materials, devices, appliances and equipment as are enforced by the department of labor and industries under this chapter. Fees charged in connection with such enforcement shall not exceed those established in RCW 19.28.101.
- (c) Within the rights-of-way of state highways, provided the state department of transportation maintains and enforces an equal, higher or better standard of construction and of materials, devices, appliances and equipment than is required by RCW 19.28.010 through 19.28.141 and 19.28.311 through 19.28.361.

(2) A city, town, or electrical supply agency is permitted, but not required, to enforce the same permitting and inspection standards applicable to basic electrical work as are enforced by the department of labor and industries.

19.28.151 RCW 19.28.010 through 19.28.141 and 19.28.311 through 19.28.361 inapplicable to telegraph or telephone companies exercising certain functions.

The provisions of RCW 19.28.010 through 19.28.141 and 19.28.311 through 19.28.361 shall not apply to the work of installing, maintaining or repairing any and all electrical wires, apparatus, installations or equipment used or to be used by a telegraph company or a telephone company in the exercise of its functions and located outdoors or in a building or buildings used exclusively for that purpose.

19.28.161 Certification — Apprentices and trainees — Supervision — Ratio of noncertified and certified workers — Trainee hours verification.

(1) No person may engage in the electrical construction trade without having a valid master journey level electrician certificate of competency, journey level electrician certificate of competency, master specialty electrician certificate of competency, or specialty electrician certificate of competency issued by the department in accordance with this chapter. Electrician certificate of competency specialties include, but are not limited to: Residential, pump and irrigation, limited energy system, signs, nonresidential maintenance, restricted nonresidential maintenance, and appliance repair. Until July 1, 2007, the department of labor and industries shall issue a written warning to any specialty pump and irrigation or domestic pump electrician not having a valid electrician certification. The warning will state that the individual must apply for an electrical training certificate or be qualified for and apply for electrician certification under the requirements in RCW 19.28.191(1)(g) within thirty calendar days of the warning. Only one warning will be issued to any individual. If the individual fails to comply with this section, the department shall issue a penalty as defined in RCW 19.28.271 to the individual.

(2) A person who is indentured in an apprenticeship program approved under chapter 49.04 RCW for the electrical construction trade or who is learning the electrical construction trade may work in the electrical construction trade if supervised by a certified master journey level electrician, journey level electrician, master specialty electrician in that electrician's specialty, or specialty electrician in that electrician's specialty. All apprentices and individuals learning the electrical construction trade shall obtain an electrical training certificate from the department. The certificate shall authorize the holder to learn the electrical construction trade while under the direct supervision of a master journey level electrician, journey level electrician, master specialty electrician working in that electrician's specialty, or specialty electrician working in that electrician's specialty. The certificate may include a photograph of the holder. The holder of the electrical training certificate shall renew the certificate biennially. At the time of renewal, the holder shall provide the department with an accurate list of the holder's employers in the electrical construction industry for the previous biennial period and the number of hours worked for each employer. The holder shall also provide proof of sixteen hours of: Approved classroom training covering this chapter, the national electrical code, or electrical theory; or equivalent classroom training taken as part of an approved apprenticeship program under chapter 49.04 RCW or an approved electrical training program under RCW 19.28.191(1)(h). The number of hours of approved classroom training required for certificate renewal shall increase as follows: (a) Beginning on July 1, 2011, the holder of an electrical training certificate shall provide the department with proof of thirty-two hours of approved classroom training; and (b) beginning on July 1, 2013, the holder of an electrical training certificate shall provide the department with proof of forty-eight hours of approved classroom training. At the request of the chairs of the house of representatives commerce and labor committee

and the senate labor, commerce and consumer protection committee, or their successor committees, the department of labor and industries shall provide information on the implementation of the new classroom training requirements for electrical trainees to both committees by December 1, 2012. A biennial fee shall be charged for the issuance or renewal of the certificate. The department shall set the fee by rule. The fee shall cover but not exceed the cost of administering and enforcing the trainee certification and supervision requirements of this chapter. Apprentices and individuals learning the electrical construction trade shall have their electrical training certificates in their possession at all times that they are performing electrical work. They shall show their certificates to an authorized representative of the department at the representative's request.

- (3) Any person who has been issued an electrical training certificate under this chapter may work if that person is under supervision. Supervision shall consist of a person being on the same job site and under the control of either a certified master journey level electrician, journey level electrician, master specialty electrician working in that electrician's specialty, or specialty electrician working in that electrician's specialty. Either a certified master journey level electrician, journey level electrician, master specialty electrician working in that electrician's specialty, or specialty electrician working in that electrician's specialty shall be on the same job site as the noncertified individual for a minimum of seventy-five percent of each working day unless otherwise provided in this chapter.
- (4) The ratio of noncertified individuals to certified master journey level electricians, journey level electricians, master specialty electricians, or specialty electricians on any one job site is as follows:
 - (a) When working as a specialty electrician, not more than two noncertified individuals for every certified master specialty electrician working in that electrician's specialty, specialty electrician working in that electrician's specialty, master journey level electrician, or journey level electrician, except that the ratio requirements are one certified master specialty electrician working in that electrician's specialty, specialty electrician working in that electrician's specialty, master journey level electrician, or journey level electrician working as a specialty electrician to no more than four students enrolled in and working as part of an electrical construction program at public community or technical colleges, or not-for-profit nationally accredited trade or technical schools licensed by the workforce training and education coordinating board under chapter 28C.10 RCW. In meeting the ratio requirements for students enrolled in an electrical construction program at a trade school, a trade school may receive input and advice from the electrical board; and
 - (b) When working as a journey level electrician, not more than one noncertified individual for every certified master journey level electrician or journey level electrician, except that the ratio requirements shall be one certified master journey level electrician or journey level electrician to no more than four students enrolled in and working as part of an electrical construction program at public community or technical colleges, or not-for-profit nationally accredited trade or technical schools licensed by the workforce training and education coordinating board under chapter 28C.10 RCW. In meeting the ratio requirements for students enrolled in an electrical construction program at a trade school, a trade school may receive input and advice from the electrical board.

An individual who has a current training certificate and who has successfully completed or is currently enrolled in an approved apprenticeship program or in an electrical construction program at public community or technical colleges, or not-for-profit nationally accredited technical or trade schools licensed by the workforce training and education coordinating board under chapter 28C.10 RCW, may work without direct on-site supervision during the last six months of meeting the practical experience requirements of this chapter.

- (5) For the residential (as specified in WAC 296-46B-920(2)(a)), pump and irrigation (as specified in WAC 296-46B-920(2)(b)), sign (as specified in WAC 296-46B-920(2)(d)), limited energy (as specified in WAC 296-46B-920(2)(e)), nonresidential maintenance (as specified in WAC 296-46B-920(2)(g)), restricted nonresidential maintenance as determined by the department in rule, or other new nonresidential specialties, not including appliance repair, as determined by the department in rule, either a master journey level electrician, journey level electrician, master specialty electrician working in that electrician's specialty, or specialty electrician working in that electrician's specialty must be on the same job site as the noncertified individual for a minimum of seventy-five percent of each working day. Other specialties must meet the requirements specified in RCW 19.28.191(1)(g)(ii). When the ratio of certified electricians to noncertified individuals on a job site is one certified electrician to three or four noncertified individuals, the certified electrician must:
 - (a) Directly supervise and instruct the noncertified individuals and the certified electrician may not directly make or engage in an electrical installation; and
 - (b) Be on the same job site as the noncertified individual for a minimum of one hundred percent of each working day.
- (6) The electrical contractor shall accurately verify and attest to the electrical trainee hours worked by electrical trainees on behalf of the electrical contractor.

19.28.171 Electrical trainee hours — Audit — Rules — Confidentiality.

The department may audit the records of an electrical contractor that has verified the hours of experience submitted by an electrical trainee to the department under RCW 19.28.161(2) in the following circumstances: Excessive hours were reported; hours reported outside the normal course of the contractor's business; the type of hours reported do not reasonably match the type of permits purchased; or for other similar circumstances in which the department demonstrates a likelihood of excessive hours being reported. The department shall limit the audit to records necessary to verify hours. The department shall adopt

rules implementing audit procedures. Information obtained from an electrical contractor under the provisions of this section is confidential and is not open to public inspection under chapter 42.56 RCW.

19.28.181 Application for certificate of competency.

Any person desiring to be issued a certificate of competency as provided in this chapter shall deliver evidence in a form prescribed by the department affirming that said person has met the qualifications required under RCW 19.28.191 and 19.28.205. An electrician from another jurisdiction applying for a certificate of competency must provide evidence in a form prescribed by the department affirming that the person has the equivalent qualifications to those required under RCW 19.28.191.

19.28.191 Certificate of competency — Eligibility for examination — Rules.

- (1) Upon receipt of the application, the department shall review the application and determine whether the applicant is eligible to take an examination for the master journey level electrician, journey level electrician, master specialty electrician, or specialty electrician certificate of competency.
 - (a) Before July 1, 2005, an applicant who possesses a valid journey level electrician certificate of competency in effect for the previous four years and a valid general administrator's certificate may apply for a master journey level electrician certificate of competency without examination.
 - (b) Before July 1, 2005, an applicant who possesses a valid specialty electrician certificate of competency, in the specialty applied for, for the previous two years and a valid specialty administrator's certificate, in the specialty applied for, may apply for a master specialty electrician certificate of competency without examination.
 - (c) Before December 1, 2003, the following persons may obtain an equipment repair specialty electrician certificate of competency without examination:
 - (i) A person who has successfully completed an apprenticeship program approved under chapter 49.04 RCW for the machinist trade; and
 - (ii) A person who provides evidence in a form prescribed by the department affirming that:
 - (A) He or she was employed as of April 1, 2003, by a factory-authorized equipment dealer or service company; and
 - (B) he or she has worked in equipment repair for a minimum of four thousand hours.
 - (d) To be eligible to take the examination for a master journey level electrician certificate of competency, the applicant must have possessed a valid journey level electrician certificate of competency for four years.
 - (e) To be eligible to take the examination for a master specialty electrician certificate of competency, the applicant must have possessed a valid specialty electrician certificate of competency, in the specialty applied for, for two years.
 - (f) To be eligible to take the examination for a journey level certificate of competency, the applicant must have:
 - (i) Worked in the electrical construction trade for a minimum of eight thousand hours, of which four thousand hours shall be in industrial or commercial electrical installation under the supervision of a master journey level electrician or journey level electrician and not more than a total of four thousand hours in all specialties under the supervision of a master journey level electrician, journey level electrician, master specialty electrician working in that electrician's specialty, or specialty electrician working in that electrician's specialty. Specialty electricians with less than a four thousand hour work experience requirement cannot credit the time required to obtain that specialty towards qualifying to become a journey level electrician; or
 - (ii) Successfully completed an apprenticeship program approved under chapter 49.04 RCW for the electrical construction trade.
- (g) (i) To be eligible to take the examination for a specialty electrician certificate of competency, the applicant must have:
 - (A) Worked in the residential (as specified in WAC 296-46B-920(2)(a)), pump and irrigation (as specified in WAC 296-46B-920(2)(b)), sign (as specified in WAC 296-46B-920(2)(d)), limited energy (as specified in WAC 296-46B-920(2)(e)), nonresidential maintenance (as specified in WAC 296-46B-920(2)(g)), or other new nonresidential specialties as determined by the department in rule under the supervision of a master journey level electrician, journey level electrician, master specialty electrician working in that electrician's specialty, or specialty electrician working in that electrician's specialty for a minimum of four thousand hours;
 - (B) Worked in the appliance repair specialty as determined by the department in rule, restricted nonresidential maintenance as determined by the department in rule, the equipment repair specialty as determined by the department in rule, the pump and irrigation specialty other than as defined by (g)(i) of this subsection or domestic pump specialty as determined by the department in rule, or a specialty other than the designated specialties in (g)(i) of this subsection for a minimum of the initial ninety days, or longer if set by rule by the department.

The restricted nonresidential maintenance specialty is limited to a maximum of 277 volts and 20 amperes for lighting branch circuits and/or a maximum of 250 volts and 60 amperes for other circuits, but excludes the replacement or repair of circuit breakers. The initial period must be spent under one hundred percent supervision of a master journey level electrician, journey level electrician, master specialty electrician working in that electrician's specialty, or specialty electrician working in that electrician's specialty. After this initial period, a person may take the specialty examination. If the person passes the examination, the person may work unsupervised for the balance of the minimum hours required for certification. A person may not be certified as a specialty electrician in the appliance repair specialty or in a specialty other than the designated specialties in (g)(i)(A) of this subsection, however, until the person has worked a minimum of two thousand hours in that specialty, or longer if set by rule by the department;

(C) Successfully completed an approved apprenticeship program under chapter 49.04 RCW for the applicant's specialty in the electrical construction trade.

(ii) In meeting the training requirements for the pump and irrigation or domestic pump specialties, the individual shall be allowed to obtain the experience required by this section at the same time the individual is meeting the experience required by RCW 18.106.040(1)(c). After meeting the training requirements provided in this section, the individual may take the examination and upon passing the examination, meeting additional training requirements as may still be required for those seeking a pump and irrigation, or a domestic pump specialty certificate as defined by rule, and paying the applicable fees, the individual must be issued the appropriate certificate. The department may include an examination for specialty plumbing certificate defined in RCW 18.106.010(10)(c) with the examination required by this section. The department, by rule and in consultation with the electrical board, may establish additional equivalent ways to gain the experience requirements required by this subsection. Individuals who are able to provide evidence to the department, prior to January 1, 2007, that they have been employed as a pump installer in the pump and irrigation or domestic pump business by an appropriately licensed electrical contractor, registered general contractor defined by chapter 18.27 RCW, or appropriate general specialty contractor defined by chapter 18.27 RCW for not less than eight thousand hours in the most recent six calendar years shall be issued the appropriate certificate by the department upon receiving such documentation and applicable fees. The department shall establish a single document for those who have received both an electrical specialty certification as defined by this subsection and have also met the certification requirements for the specialty plumber as defined by RCW 18.106.010(10)(c), showing that the individual has received both certifications. No other experience or training requirements may be imposed.

(iii) Before July 1, 2015, an applicant possessing an electrical training certificate issued by the department is eligible to apply one hour of every two hours of unsupervised telecommunications system installation work experience toward eligibility for examination for a limited energy system certificate of competency (as specified in WAC 296-46B-920(2)(e)), if:

(A) The telecommunications work experience was obtained while employed by a contractor licensed under this chapter as a general electrical contractor (as specified in WAC 296-46B-920(1)) or a limited energy system specialty contractor (as specified in WAC 296-46B-920(e)); and

(B) Evidence of the telecommunications work experience is submitted in the form of an affidavit prescribed by the department.

(h) Any applicant for a journey level electrician certificate of competency who has successfully completed a two-year program in the electrical construction trade at public community or technical colleges, or not-for-profit nationally accredited technical or trade schools licensed by the workforce training and education coordinating board under chapter 28C.10 RCW, may substitute up to two years of the technical or trade school program for two years of work experience under a master journey level electrician or journey level electrician. The applicant shall obtain the additional two years of work experience required in industrial or commercial electrical installation prior to the beginning, or after the completion, of the technical school program. Any applicant who has received training in the electrical construction trade in the armed service of the United States may be eligible to apply armed service work experience towards qualification to take the examination for the journey level electrician certificate of competency.

(i) An applicant for a specialty electrician certificate of competency who, after January 1, 2000, has successfully completed a two-year program in the electrical construction trade at a public community or technical college, or a not-for-profit nationally accredited technical or trade school licensed by the workforce training and education coordinating board under chapter 28C.10 RCW, may substitute up to one year of the technical or trade school program for one year of work experience under a master journey level electrician, journey level electrician, master specialty electrician working in that electrician's specialty, or specialty electrician working in that electrician's specialty. Any applicant who has received training in the electrical construction trade in the armed services of the United States may be eligible to apply armed service work experience towards qualification to take the examination for an appropriate specialty electrician certificate of competency.

(j) The department must determine whether hours of training and experience in the armed services or school program are in the electrical construction trade and appropriate as a substitute for hours of work experience. The

department must use the following criteria for evaluating the equivalence of classroom electrical training programs and work in the electrical construction trade:

- (i) A two-year electrical training program must consist of three thousand or more hours.
- (ii) In a two-year electrical training program, a minimum of two thousand four hundred hours of student/instructor contact time must be technical electrical instruction directly related to the scope of work of the electrical specialty. Student/instructor contact time includes lecture and in-school lab.
- (iii) The department may not allow credit for a program that accepts more than one thousand hours transferred from another school's program.
- (iv) Electrical specialty training school programs of less than two years will have all of the above student/instructor contact time hours proportionately reduced. Such programs may not apply to more than fifty percent of the work experience required to attain certification.
- (v) Electrical training programs of less than two years may not be credited towards qualification for journey level electrician unless the training program is used to gain qualification for a four thousand hour electrical specialty.

(k) No other requirement for eligibility may be imposed.

(2) The department shall establish reasonable rules for the examinations to be given applicants for certificates of competency. In establishing the rules, the department shall consult with the board. Upon determination that the applicant is eligible to take the examination, the department shall so notify the applicant, indicating the time and place for taking the examination.

(3) No noncertified individual may work unsupervised more than one year beyond the date when the trainee would be eligible to test for a certificate of competency if working on a full-time basis after original application for the trainee certificate. For the purposes of this section, "full-time basis" means two thousand hours.

19.28.201 Examination — Times — Certification of results — Contents — Fees.

The department, in coordination with the board, shall prepare an examination to be administered to applicants for master journey level electrician, journey level electrician, master specialty electrician, and specialty electrician certificates of competency.

The department, with the consent of the board, may enter into a contract with a professional testing agency to develop, administer, and score electrician certification examinations. The department may set the examination fee by contract with the professional testing agency.

The department must, at least four times annually, administer the examination to persons eligible to take it under RCW 19.28.191. The fee must cover, but not exceed, the costs of preparing and administering the examination.

The department must certify the results of the examination upon the terms and after such a period of time as the department, in cooperation with the board, deems necessary and proper.

- (1)
 - (a) The master electrician's certificates of competency examinations must include questions from the following categories to ensure proper safety and protection for the general public: (i) Safety; (ii) the state electrical code; and (iii) electrical theory.
 - (b) A person may take the master electrician examination as many times as necessary without limit. All applicants must, before taking the examination, pay the required examination fee to the agency administering the examination.
- (2) The journey level electrician and specialty electrician examinations shall be constructed to determine:
 - (a) Whether the applicant possesses varied general knowledge of the technical information and practical procedures that are identified with the status of journey level electrician or specialty electrician; and
 - (b) Whether the applicant is sufficiently familiar with the applicable electrical codes and the rules of the department pertaining to electrical installations and electricians.

A person may take the examination as many times as necessary without limit. All applicants must, before taking the examination, pay the required examination fee to the agency administering the examination.

19.28.205 In-class education requirements.

(1) An applicant for a journey level certificate of competency under RCW 19.28.191(1)(f) or a specialty electrician certificate of competency under RCW 19.28.191(1)(g) must demonstrate to the satisfaction of the department completion of in-class education as follows:

- (a) Twenty-four hours of in-class education if two thousand hours or more but less than four thousand hours of work are required for the certificate;

- (b) Forty-eight hours of in-class education if four thousand or more but less than six thousand hours of work are required for the certificate;
- (c) Seventy-two hours of in-class education if six thousand or more but less than eight thousand hours of work are required for the certificate;
- (d) Ninety-six hours of in-class education if eight thousand or more hours of work are required for the certificate.

(2) For purposes of this section, "in-class education" means approved classroom training covering this chapter, the national electric code, or electrical theory; or equivalent classroom training taken as part of an approved apprenticeship program under chapter 49.04 RCW or an approved electrical training program under RCW 19.28.191(1)(h).

(3) Classroom training taken to qualify for trainee certificate renewal under RCW 19.28.161 qualifies as in-class education under this section.

19.28.211 Certificate of competency — Issuance — Renewal — Continuing education — Fees — Effect.

- (1) The department shall issue a certificate of competency to all applicants who have passed the examination provided in RCW 19.28.201, met the in-class education requirements of RCW 19.28.205 if applicable, and who have complied with RCW 19.28.161 through 19.28.271 and the rules adopted under this chapter. The certificate may include a photograph of the holder. The certificate shall bear the date of issuance, and shall expire on the holder's birthday. The certificate shall be renewed every three years, upon application, on or before the holder's birthdate. A fee shall be assessed for each certificate and for each annual renewal.
- (2) If the certificate holder demonstrates to the department that he or she has satisfactorily completed an annual eight-hour continuing education course, the certificate may be renewed without examination by appropriate application unless the certificate has been revoked, suspended, or not renewed within ninety days after the expiration date. For pump and irrigation or domestic pump specialty electricians, the continuing education course may combine both electrical and plumbing education provided that there is a minimum of four hours of electrical training in the course.
 - (a) The contents and requirements for satisfactory completion of the continuing education course shall be determined by the director and approved by the board.
 - (b) The department shall accept proof of a certificate holder's satisfactory completion of a continuing education course offered in another state as meeting the requirements for maintaining a current Washington state certificate of competency if the department is satisfied the course is comparable in nature to that required in Washington state for maintaining a current certificate of competency.
- (3) If the certificate is not renewed before the expiration date, the individual shall pay twice the usual fee. The department shall set the fees by rule for issuance and renewal of a certificate of competency. The fees shall cover but not exceed the costs of issuing the certificates and of administering and enforcing the electrician certification requirements of this chapter.
- (4) The certificates of competency and temporary permits provided for in this chapter grant the holder the right to work in the electrical construction trade as a master electrician, journey level electrician, or specialty electrician in accordance with their provisions throughout the state and within any of its political subdivisions without additional proof of competency or any other license, permit, or fee to engage in such work.

19.28.221 Persons engaged in trade or business on July 16, 1973.

No examination shall be required of any applicant for a certificate of competency who, on July 16, 1973, was engaged in a bona fide business or trade as a journey level electrician in the state of Washington. Applicants qualifying under this section shall be issued a certificate by the department upon making an application as provided in RCW 19.28.181 and paying the fee required under RCW 19.28.201: PROVIDED, That no applicant under this section shall be required to furnish such evidence as required by RCW 19.28.181.

19.28.231 Temporary permits.

The department is authorized to grant and issue temporary permits in lieu of certificates of competency whenever an electrician coming into the state of Washington from another state requests the department for a temporary permit to engage in the electrical construction trade as an electrician during the period of time between filing of an application for a certificate as provided in RCW 19.28.181 and the date the results of taking the examination provided for in RCW 19.28.201 are furnished to the applicant. The temporary permit may include a photograph of the holder. The department is authorized to enter into reciprocal agreements with other states providing for the acceptance of such states' journey level and specialty electrician certificate of competency or its equivalent when such states requirements are equal to the standards set by this chapter. No temporary permit shall be issued to:

- (1) Any person who has failed to pass the examination for a certificate of competency, except that any person who has failed the examination for competency under this section shall be entitled to continue to work under a temporary permit for ninety days if the person is enrolled in a journey level electrician refresher course and shows evidence to the department

that he or she has not missed any classes. The person, after completing the journey level electrician refresher course, shall be eligible to retake the examination for competency at the next scheduled time.

(2) Any applicant under this section who has not furnished the department with such evidence required under RCW 19.28.181.

(3) Any apprentice electrician.

19.28.241 Revocation of certificate of competency — Grounds — Procedure.

(1) The department may revoke any certificate of competency upon the following grounds:

- (a) The certificate was obtained through error or fraud;
- (b) The holder thereof is judged to be incompetent to work in the electrical construction trade as a journey level electrician or specialty electrician;
- (c) The holder thereof has violated any of the provisions of RCW 19.28.161 through 19.28.271 or any rule adopted under this chapter; or
- (d) The holder thereof has committed a serious violation of this chapter or any rule adopted under this chapter. A serious violation is a violation that presents imminent danger to the public.

(2) The department may deny an application for a certificate of competency for up to two years if the applicant's previous certificate of competency has been revoked.

(3) Before any certificate of competency shall be revoked, the holder shall be given written notice of the department's intention to do so, mailed by registered mail, return receipt requested, to the holder's last known address. The notice shall enumerate the allegations against the holder, and shall give the holder the opportunity to request a hearing before the board. At the hearing, the department and the holder may produce witnesses and give testimony. The hearing shall be conducted in accordance with chapter 34.05 RCW. The board shall render its decision based upon the testimony and evidence presented, and shall notify the parties immediately upon reaching its decision. A majority of the board shall be necessary to render a decision.

(4) The department shall immediately suspend the license or certificate of a person who has been certified pursuant to RCW 74.20A.320 by the department of social and health services as a person who is not in compliance with a support order. If the person has continued to meet all other requirements for reinstatement during the suspension, reissuance of the license or certificate shall be automatic upon the department's receipt of a release issued by the department of social and health services stating that the licensee is in compliance with the order.

19.28.251 Powers and duties of director — Administration of RCW 19.28.161 through 19.28.271 by the department.

The director may promulgate rules, make specific decisions, orders, and rulings, including demands and findings, and take other necessary action for the implementation and enforcement of RCW 19.28.161 through 19.28.271. In the administration of RCW 19.28.161 through 19.28.271 the department shall not enter any controversy arising over work assignments with respect to the trades involved in the construction industry.

19.28.261 Exemptions from RCW 19.28.161 through 19.28.271.

(1) Nothing in RCW 19.28.161 through 19.28.271 shall be construed to require that a person obtain a license or a certified electrician in order to do electrical work at his or her residence or farm or place of business or on other property owned by him or her unless the electrical work is on the construction of a new building intended for rent, sale, or lease. However, if the construction is of a new residential building with up to four units intended for rent, sale, or lease, the owner may receive an exemption from the requirement to obtain a license or use a certified electrician if he or she provides a signed affidavit to the department stating that he or she will be performing the work and will occupy one of the units as his or her principal residence. The owner shall apply to the department for this exemption and may only receive an exemption once every twenty-four months. It is intended that the owner receiving this exemption shall occupy the unit as his or her principal residence for twenty-four months after completion of the units.

(2) Nothing in RCW 19.28.161 through 19.28.271 shall be intended to derogate from or dispense with the requirements of any valid electrical code enacted by a city or town pursuant to RCW 19.28.010(3), except that no code shall require the holder of a certificate of competency to demonstrate any additional proof of competency or obtain any other license or pay any fee in order to engage in the electrical construction trade.

(3) RCW 19.28.161 through 19.28.271 shall not apply to common carriers subject to Part I of the *Interstate Commerce Act, nor to their officers and employees.

(4) Nothing in RCW 19.28.161 through 19.28.271 shall be deemed to apply to the installation or maintenance of telephone, telegraph, radio, or television wires and equipment; nor to any electrical utility or its employees in the installation, repair, and maintenance of electrical wiring, circuits, and equipment by or for the utility, or comprising a part of its plants, lines, or systems.

(5) The licensing provisions of RCW 19.28.161 through 19.28.271 shall not apply to:

- (a) Persons making electrical installations on their own property or to regularly employed employees working on the premises of their employer, unless the electrical work is on the construction of a new building intended for rent, sale, or lease;
- (b) Employees of an employer while the employer is performing utility type work of the nature described in RCW 19.28.091 so long as such employees have registered in the state of Washington with or graduated from a state-approved outside lineworker apprenticeship course that is recognized by the department and that qualifies a person to perform such work;
- (c) Any work exempted under RCW 19.28.091(6); and
- (d) Certified plumbers, certified residential plumbers, or plumber trainees meeting the requirements of chapter 18.106 RCW and performing exempt work under RCW 19.28.091(8).

(6) Nothing in RCW 19.28.161 through 19.28.271 shall be construed to restrict the right of any householder to assist or receive assistance from a friend, neighbor, relative, or other person when none of the individuals doing the electrical installation hold themselves out as engaged in the trade or business of electrical installations.

(7) Nothing precludes any person who is exempt from the licensing requirements of this chapter under this section from obtaining a journey level or specialty certificate of competency if they otherwise meet the requirements of this chapter.

19.28.271 Violations of RCW 19.28.161 through 19.28.271 — Schedule of penalties — Appeal.

- (1) It is unlawful for any person, firm, partnership, corporation, or other entity to employ an individual for purposes of RCW 19.28.161 through 19.28.271 who has not been issued a certificate of competency, a temporary permit, or a training certificate. It is unlawful for any individual to engage in the electrical construction trade or to maintain or install any electrical equipment or conductors without having in his or her possession a certificate of competency, a temporary permit, or a training certificate under RCW 19.28.161 through 19.28.271, and photo identification. The department may establish by rule a requirement that the individual also wear and visibly display his or her certificate or permit.
- (2) Any person, firm, partnership, corporation, or other entity found in violation of RCW 19.28.161 through 19.28.271 shall be assessed a penalty of not less than fifty dollars or more than five hundred dollars. The department shall set by rule a schedule of penalties for violating RCW 19.28.161 through 19.28.271. An appeal may be made to the board as is provided in RCW 19.28.131. The appeal shall be filed within twenty days after the notice of the penalty is given to the assessed party using a method by which the mailing can be tracked or the delivery can be confirmed, sent to the last known address of the assessed party and shall be made by filing a written notice of appeal with the department. Any equipment maintained or installed by any person who does not possess a certificate of competency under RCW 19.28.161 through 19.28.271 shall not receive an electrical work permit and electrical service shall not be connected or maintained to operate the equipment. Each day that a person, firm, partnership, corporation, or other entity violates RCW 19.28.161 through 19.28.271 is a separate violation.
- (3) A civil penalty shall be collected in a civil action brought by the attorney general in the county wherein the alleged violation arose at the request of the department if any of RCW 19.28.161 through 19.28.271 or any rules adopted under RCW 19.28.161 through 19.28.271 are violated.

19.28.281 Electric vehicle infrastructure — Rule adoption.

The director shall adopt by rule standards for the installation of electric vehicle infrastructure, including all wires and equipment that convey electric current and any equipment to be operated by electric current, in, on, or about buildings or structures. The rules must be consistent with rules adopted under RCW 19.27.540.

19.28.291 Violations of chapter — Issuance of subpoenas — Application.

- (1) If he or she has reason to believe there has been a violation of this chapter, the director and the director's authorized representatives may issue subpoenas to enforce the production and examination of any information, whether written or electronic, necessary to enforce this chapter. The subpoena must describe the possible violation, cite the relevant sections of this chapter and rules adopted under this chapter, and must explain how the information being subpoenaed is reasonably related to the possible violation.
- (2) The subpoena may be issued only if an electrical contractor, administrator, electrician, or other entity or person to which this chapter applies fails to provide the above information when requested by the department. The department's request for information must describe the possible violation, cite the relevant sections of this chapter and rules adopted under this chapter, and must explain how the information being requested is reasonably related to the possible violation.
- (3) The superior court has the power to enforce such a subpoena by proper proceedings.
- (4) This section applies to all electrical contractors, administrators, electricians, other entities and persons, and electrical work to which this chapter applies.

PROVISIONS APPLICABLE TO ELECTRICAL INSTALLATIONS AND TELECOMMUNICATIONS INSTALLATIONS

19.28.301 Application — Subchapter heading.

- (1) RCW 19.28.311 through 19.28.381 apply throughout this chapter.
- (2) RCW 19.28.311 through 19.28.381 constitute the subchapter "provisions applicable to electrical installations and telecommunications installations."

19.28.311 Electrical board.

There is hereby created an electrical board, consisting of fifteen members to be appointed by the governor with the advice of the director of labor and industries as herein provided. It shall be the purpose and function of the board to advise the director on all matters pertaining to the enforcement of this chapter including, but not limited to, standards of electrical and telecommunications installation, minimum inspection procedures, and the adoption of rules pertaining to the electrical inspection division: PROVIDED, HOWEVER, That no rules shall be amended or repealed until the electrical board has first had an opportunity to consider any proposed amendments or repeals and had an opportunity to make recommendations to the director relative thereto. The members of the electrical board shall be selected and appointed as follows: One member shall be an employee or officer of a corporation or public agency generating or distributing electric power; one member must be an employee or officer of a facilities-based telecommunications service provider regulated by the Washington state utilities and transportation commission; three members shall be licensed electrical contractors: PROVIDED, That one of these members may be a representative of a trade association in the electrical industry; one member shall be a licensed telecommunications contractor; one member shall be an employee, or officer, or representative of a corporation or firm engaged in the business of manufacturing or distributing electrical and telecommunications materials, equipment, or devices; one member shall be a person with knowledge of the electrical industry, not related to the electrical industry, to represent the public; three members shall be certified electricians; one member shall be a telecommunications worker; one member shall be a licensed professional electrical engineer qualified to do business in the state of Washington and designated as a registered communications distribution designer; one member shall be an outside line worker; and one nonvoting member must be a building official from an incorporated city or town with an electrical inspection program established under RCW 19.28.141. The regular term of each member shall be four years: PROVIDED, HOWEVER, The original board shall be appointed on June 9, 1988, for the following terms: The first term of the member representing a corporation or public agency generating or distributing electric power shall serve four years; two members representing licensed electrical contractors shall serve three years; the member representing a manufacturer or distributor of electrical equipment or devices shall serve three years; the member representing the public and one member representing licensed electrical contractors shall serve two years; the three members selected as certified electricians shall serve for terms of one, two, and three years, respectively; the member selected as the licensed professional electrical engineer shall serve for one year. In appointing the original board, the governor shall give due consideration to the value of continuity in membership from predecessor boards. Thereafter, the governor shall appoint or reappoint board members for terms of four years and to fill vacancies created by the completion of the terms of the original members. When new positions are created, the governor may appoint the initial members to the new positions to staggered terms of one to three years. The governor shall also fill vacancies caused by death, resignation, or otherwise for the unexpired term of such members by appointing their successors from the same business classification. The same procedure shall be followed in making such subsequent appointments as is provided for the original appointments. The board, at this first meeting shall elect one of its members to serve as chair. Any person acting as the chief electrical inspector shall serve as secretary of the board during his or her tenure as chief state inspector. Meetings of the board shall be held at least quarterly in accordance with a schedule established by the board. Each member of the board shall receive compensation in accordance with RCW 43.03.240 and shall be reimbursed for travel expenses in accordance with RCW 43.03.050 and 43.03.060 which shall be paid out of the electrical license fund, upon vouchers approved by the director of labor and industries.

19.28.321 Enforcement — State electrical inspectors — Qualifications — Salaries and expenses.

The director of labor and industries of the state of Washington and the officials of all incorporated cities and towns where electrical inspections are required by local ordinances shall have power and it shall be their duty to enforce the provisions of this chapter in their respective jurisdictions. The director of labor and industries shall appoint a chief electrical inspector and may appoint other electrical inspectors as the director deems necessary to assist the director in the performance of the director's duties. The chief electrical inspector, subject to the review of the director, shall be responsible for providing the final interpretation of adopted state electrical standards, rules, and policies for the department and its inspectors, assistant inspectors, electrical plan examiners, and other individuals supervising electrical program personnel. If a dispute arises within the department regarding the interpretation of adopted state electrical standards, rules, or policies, the chief electrical inspector, subject to the review of the director, shall provide the final interpretation of the disputed standard, rule, or policy. All electrical inspectors appointed by the director of labor and industries shall have not less than: Four years experience as

journeyperson electricians in the electrical construction trade installing and maintaining electrical wiring and equipment, or two years electrical training in a college of electrical engineering of recognized standing and four years continuous practical electrical experience in installation work, or four years of electrical training in a college of electrical engineering of recognized standing and two years continuous practical electrical experience in electrical installation work; or four years experience as a journeyperson electrician performing the duties of an electrical inspector employed by the department or a city or town with an approved inspection program under RCW 19.28.141, except that for work performed in accordance with the national electrical safety code and covered by this chapter, such inspections may be performed by a person certified as an outside journeyperson lineworker, under RCW 19.28.261(5)(b), with four years experience or a person with four years experience as a certified outside journeyperson lineworker performing the duties of an electrical inspector employed by an electrical utility. Such state inspectors shall be paid such salary as the director of labor and industries shall determine, together with their travel expenses in accordance with RCW 43.03.050 and 43.03.060 as now existing or hereafter amended. As a condition of employment, inspectors hired exclusively to perform inspections in accordance with the national electrical safety code must possess and maintain certification as an outside journeyperson lineworker. The expenses of the director of labor and industries and the salaries and expenses of state inspectors incurred in carrying out the provisions of this chapter shall be paid entirely out of the electrical license fund, upon vouchers approved by the director of labor and industries.

19.28.331 Inspection reports.

If any inspection made under this chapter requires any correction or change in the work inspected, a written report of the inspection shall be made by the inspector, in which report the corrections or changes required shall be plainly stated. A copy of the report shall be furnished to the person, firm, partnership, corporation, or other entity doing the installation work, and a copy shall be filed with the department.

19.28.341 Revocation or suspension of license — Grounds — Appeal to board — Fee — Costs.

- (1) The department has the power, in case of serious noncompliance with the provisions of this chapter, to revoke or suspend for such a period as it determines, any electrical or telecommunications contractor license or electrical or telecommunications contractor administrator certificate issued under this chapter. The department shall notify the holder of the license or certificate of the revocation or suspension using a method by which the mailing can be tracked or the delivery can be confirmed. A revocation or suspension is effective twenty days after the holder receives the notice. Any revocation or suspension is subject to review by an appeal to the board. The filing of an appeal stays the effect of a revocation or suspension until the board makes its decision. The appeal shall be filed within twenty days after notice of the revocation or suspension is given using a method by which the mailing can be tracked or the delivery can be confirmed sent to the address of the holder of the license or certificate as shown on the application for the license or certificate, and shall be effected by filing a written notice of appeal with the department, accompanied by a certified check for two hundred dollars, which shall be returned to the holder of the license or certificate if the decision of the department is not sustained by the board. The hearing shall be conducted in accordance with chapter 34.05 RCW. If the board sustains the decision of the department, the two hundred dollars shall be applied by the department to the payment of the per diem and expenses of the members of the board incurred in the matter, and any balance remaining after payment of per diem and expenses shall be paid into the electrical license fund.
- (2) The department shall immediately suspend the license or certificate of a person who has been certified pursuant to RCW 74.20A.320 by the department of social and health services as a person who is not in compliance with a support order. If the person has continued to meet all other requirements for reinstatement during the suspension, reissuance of the license or certificate shall be automatic upon the department's receipt of a release issued by the department of social and health services stating that the licensee is in compliance with the order.

19.28.351 Electrical license fund.

All sums received from licenses, permit fees, or other sources, herein shall be paid to the state treasurer and placed in a special fund designated as the "electrical license fund," and paid out upon vouchers duly and regularly issued therefor and approved by the director of labor and industries or the director's designee following determination by the board that the sums are necessary to accomplish the intent of chapter 19.28 RCW. The treasurer shall keep an accurate record of payments into, or receipts of, the fund, and of all disbursements therefrom.

During the 2013-2015 biennium, the legislature may transfer moneys from the electrical license fund to the state general fund such amounts as reflect the excess fund balance of the fund.

19.28.361 Liability for injury or damage.

Nothing contained in this chapter will be construed to relieve from or lessen the responsibility or liability of any person for injury or damage to person or property caused by or resulting from any defect of any nature in any electrical or telecommunications work performed by said person or in any electrical or telecommunications equipment owned, controlled, installed, operated or used by him or her; nor shall the state of Washington, or any officer, agent, or employee thereof incur or be held as assuming any liability by reason or in consequence of any permission, certificate of inspection, inspection or approval authorized herein, or issued or given as herein provided, or by reason of consequence of any things done or acts performed pursuant to any provision of this chapter.

19.28.371 Medical device — Installation, maintenance, or repair — Compliance with chapter — Limit of exemption.

- (1) A medical device which is not in violation of the Medical Device Amendments of 1976, Public Law No. 94-295, 90 Stat. 539, as amended from time to time, and as interpreted by the Food and Drug Administration of the United States Department of Health and Human Services or its successor, shall be deemed to be in compliance with all requirements imposed by this chapter.
- (2) The installation, maintenance, or repair of a medical device deemed in compliance with this chapter is exempt from licensing requirements under RCW [19.28.091](#), certification requirements under RCW [19.28.161](#), and inspection and permitting requirements under RCW [19.28.101](#). This exemption does not include work providing electrical feeds into the power distribution unit or installation of conduits and raceways. This exemption covers only those factory engineers or third-party service companies with equivalent training who are qualified to perform such service.

19.28.381 Denial of renewal of certificate or license for outstanding penalties — Notice — Appeal — Hearing.

*** CHANGE IN 2014 – Effective 07/01/2015 *** (SEE [2146-S.SL](#)) ***

The department may deny renewal of a certificate or license issued under this chapter, if the applicant for renewal owes outstanding penalties for a final judgment under this chapter. The department shall notify the applicant of the denial by registered mail, return receipt requested, to the address on the application. The applicant may appeal the denial within twenty days by filing a notice of appeal with the department accompanied by a certified check for two hundred dollars which shall be returned to the applicant if the decision of the department is not upheld by the board. The office of administrative hearings shall conduct the hearing under chapter [34.05](#) RCW. The electrical board shall review the proposed decision at the next regularly scheduled board meeting. If the board sustains the decision of the department, the two hundred dollars must be applied to the cost of the hearing.

PROVISIONS APPLICABLE TO TELECOMMUNICATIONS INSTALLATIONS

19.28.400 Definitions.

The definitions in this section apply throughout this subchapter unless the context clearly requires otherwise.

- (1) "Telecommunications backbone cabling systems" means a system that provides interconnections between telecommunications closets, equipment rooms, and entrance facilities in the telecommunications cabling system structure. Backbone cabling consists of the backbone cables, intermediate and main cross-connects, mechanical terminations, and patch cords or jumpers used for backbone to backbone cross-connection. Backbone cabling also includes cabling between buildings.
- (2) "Board" means the electrical board under RCW [19.28.311](#).
- (3) "Department" means the department of labor and industries.
- (4) "Director" means the director of the department or the director's designee.
- (5) "Telecommunications horizontal cabling systems" means the portions of the telecommunications cabling system that extend from the work area telecommunications outlet or connector to the telecommunications closet. The horizontal cabling includes the horizontal cables, the telecommunications outlet or connector in the work area, the mechanical termination, and horizontal cross-connections located in the telecommunications closet.
- (6) "Telecommunications network demarcation point" means the point or interconnection between the service provider's communications cabling, terminal equipment, and protective apparatus and the customer's premises telecommunications cabling system. The location of this point for regulated carriers is determined by federal and state regulations. The carrier should be contacted to determine the location policies in effect in the area.

(7) "Telecommunications scope of work" means the work of a telecommunications contractor. This includes the installation, maintenance, and testing of telecommunications systems, equipment, and associated hardware, pathway systems, and cable management systems, which excludes cable tray and conduit raceway systems. The scope also includes installation of open wiring systems of telecommunications cables, surface nonmetallic raceways designated and used exclusively for telecommunications, optical fiber innerduct raceway, underground raceways designated and used exclusively for telecommunications and installed for additions or extensions to existing telecommunications systems not to exceed fifty feet inside the building, and incidental short sections of circular or surface metal raceway, not to exceed ten feet, for access or protection of telecommunications cabling and installation of cable trays and ladder racks in telecommunications service entrance rooms, spaces, or closets.

(8) A "telecommunications structured cabling system" is the complete collective configuration of cabling and associated hardware at a given site and installed to perform specific telecommunications functions.

(9) "Telecommunications administrator" means a person designated by a telecommunications contractor to supervise the installation of telecommunications systems in accordance with rules adopted under this chapter.

(10) "Telecommunications closet" means a room for housing telecommunications equipment, cable terminations, and cross-connect wiring that serve that particular floor. The closet is the recognized transition point between the backbone and horizontal cabling systems.

(11) "Telecommunications contractor" means a person, firm, partnership, corporation, or other entity that advertises, offers to undertake, undertakes, submits a bid for, or does the work of installing or maintaining telecommunications systems.

(12) "Telecommunications service entrance room or space" means a room or space used as the building serving facility in which the joining of inter-building and intra-building backbone facilities takes place. The service entrance room may also house electronic equipment serving any telecommunications function.

(13) "Telecommunications systems" means structured cabling systems that begin at the demarcation point between the local service provider and the customer's premises structured cabling system.

- (a) Telecommunications systems encompass all forms of information generation, processing, and transporting of signals conveyed electronically or optically within or between buildings, including voice, data, video, and audio.
- (b) Telecommunications systems include structured cabling systems, compatible connecting hardware, telecommunications equipment, premises switching equipment providing operational power to the telecommunications device, infrared, fiber optic, radio-frequency, power distribution associated with telecommunications systems, and other limited-energy interconnections associated with telecommunications systems or appliances.
- (c) Telecommunications systems do not include horizontal cabling used for fire protection signaling systems, intrusion alarms, access control systems, patient monitoring systems, energy management control systems, industrial and automation control systems, HVAC/refrigeration control systems, lighting or lighting control systems, and stand-alone amplified sound or public address systems.
- (d) Telecommunications systems may interface with other building signal systems including security, alarms, and energy management at cross-connection junctions within telecommunications closets or at extended points of demarcation. Horizontal cabling for a telecommunications outlet, necessary to interface with any of these systems outside of a telecommunications closet, is the work of the telecommunications contractor. Telecommunications systems do not include the installation or termination of premises line voltage service, feeder, or branch circuit conductors or equipment.

(14) "Telecommunications worker" means a person primarily and regularly engaged in the installation and/or maintenance of telecommunications systems, equipment, and infrastructure as defined in this chapter.

(15) "Telecommunications workstation" means a building space where the occupant normally interacts with telecommunications equipment. The telecommunications outlet in the work area is the point at which end-user equipment plugs into the building telecommunications utility formed by the pathway, space, and building wiring system.

19.28.410 Telecommunications systems installations — Subject to this subchapter.

- (1) All installations of wires and equipment defined as telecommunications systems are subject to the requirements of this subchapter. Installations shall be in conformity with approved methods of construction for safety to life and property. The national electrical code, approved standards of the telecommunications industries association, the electronic industries association, the American national standards institute, and other safety standards approved by the department shall be evidence of approved methods of installation.
- (2) This chapter may not limit the authority or power of any city or town to enact and enforce under authority given by law in RCW [19.28.141](#), any ordinance, or rule requiring an equal, higher, or better standard of construction and an equal, higher, or better standard of materials, devices, appliances, and equipment than that required by this chapter.

19.28.420 Telecommunications contractor license — Application — Bond — Issuance of license.

- (1) It is unlawful for any person, firm, partnership, corporation, or other entity to advertise, offer to do work, submit a bid, engage in, conduct, or carry on the business of installing or maintaining telecommunications systems without having a telecommunications contractor license. Electrical contractors licensed as general electrical (01) or specialty electrical (06)

contractors under chapter 19.28 RCW and their designated administrators qualify to perform all telecommunications work defined in this chapter. Telecommunications contractors licensed under this chapter are not required to be registered under chapter 18.27 RCW. All telecommunications licenses expire twenty-four calendar months following the day of their issue. A telecommunications contractor license is not required for a licensed specialty electrical contractor to perform telecommunications installations or maintenance integral to the equipment or occupancy limitations of their electrical specialty. A telecommunications contractor license is not required for persons making telecommunications installations or performing telecommunications maintenance on their own property or for regularly employed employees working on the premises of their employer, unless on a new building intended for rent, sale, or lease.

(2) Application for a telecommunications contractor license shall be made in writing to the department accompanied by the required fee. The applications shall state:

- (a) The name and address of the applicant. In the case of firms or partnerships, the applications shall state the names of the individuals composing the firm or partnership. In the case of corporations, the applications shall state the names of the corporation's managing officials;
- (b) The location of the place of business of the applicant and the name under which the business is conducted;
- (c) The employer social security number or tax identification number;
- (d) Evidence of workers' compensation coverage for the applicant's employees working in Washington, as follows:
 - (i) The applicant's industrial insurance account number issued by the department;
 - (ii) The applicant's self-insurer number issued by the department; or
 - (iii) For applicants domiciled in a state or province of Canada subject to an agreement entered into under RCW 51.12.120(7), as permitted by the agreement, filing a certificate of coverage issued by the agency that administers the workers' compensation law in the applicant's state or province of domicile certifying that the applicant has secured the payment of compensation under the other state's or province's workers' compensation law;
- (e) The employment security department number; and
- (f) The state excise tax registration number.

(3) The unified business identifier account number may be substituted for the information required by subsection (2)(d), (e), and (f) of this section if the applicant will not employ employees in Washington.

(4) The department may verify the workers' compensation coverage information provided by the applicant under subsection (2)(d) of this section including, but not limited to, information regarding the coverage of an individual employee of the applicant. If coverage is provided under the laws of another state, the department may notify the other state that the applicant is employing employees in Washington.

(5) To obtain a telecommunications contractor license the applicant must designate an individual who currently possesses a telecommunications administrator certificate. To obtain an administrator's certificate an individual must pass an examination as set forth in this chapter. Examination criteria will be determined by the board.

(6) No examination may be required of any applicant for an initial telecommunications administrator certificate qualifying under this section. Applicants qualifying under this section shall be issued an administrator certificate by the department upon making an application and paying the required fee. Individuals must apply before July 1, 2001, to qualify for an administrator certificate without examination under this section. The board shall certify to the department the names of all persons entitled to this administrator certificate.

Prior to July 1, 2001, bona fide registered contractors under chapter 18.27 RCW engaged in the business of installing or maintaining telecommunications wiring in this state on or before June 8, 2000, may designate the following number of persons to receive a telecommunications administrator certificate without examination:

- (a) One owner or officer of a contractor, registered under chapter 18.27 RCW on or before June 8, 2000, currently engaged in the business of installing telecommunications wiring;
- (b) One employee, principal, or officer, with a minimum of two years experience performing telecommunications installations, per registered telecommunication[s] contractor; and
- (c) One employee for each one hundred employees, or fraction thereof, with a minimum of two years experience performing telecommunications installations.

(7) The application for a contractor license shall be accompanied by a bond in the sum of four thousand dollars with the state of Washington named as obligee in the bond, with good and sufficient surety, to be approved by the department. The bond shall at all times be kept in full force and effect, and any cancellation or revocation thereof, or withdrawal of the surety therefrom, suspends the license issued to the principal until a new bond has been filed and approved as provided in this section. Upon approval of a bond, the department shall, on the next business day, deposit the fee accompanying the application in the electrical license fund and shall file the bond in the office. The department shall, upon request, furnish to any person, firm, partnership, corporation, or other entity a certified copy of the bond upon the payment of a fee that the department shall set by rule. The fee shall cover but not exceed the cost of furnishing the certified copy. The bond shall be conditioned that the principal will pay for all labor, including employee benefits, and material furnished or used upon the work, taxes and contributions to the state of Washington, and all damages that may be sustained by any person, firm, partnership, corporation, or other entity due to a failure of the principal to make the installation or maintenance in accordance with this chapter. In lieu of the surety bond required by this section the applicant may file with the department a cash deposit or other negotiable security acceptable to the department. If the applicant has filed a cash deposit, the department shall deposit the funds in a special trust savings account in a commercial bank, mutual savings bank, or savings and loan association and shall pay annually to the depositor the interest derived from the account.

(8) Any person, firm, or corporation sustaining any damage or injury by reason of the principal's breach of the conditions of the bond required under this section may bring an action against the surety named therein, joining in the action the principal named in the bond; the action shall be brought in the superior court of any county in which the principal on the bond resides or transacts business, or in the county in which the work was performed as a result of which the breach is alleged to have occurred; the action shall be maintained and prosecuted as other civil actions. Claims or actions against the surety on the bond shall be paid in full in the following order of priority: (a) Labor, including employee benefits, (b) materials and equipment used upon such work, (c) taxes and contributions due to the state, (d) damages sustained by any person, firm, or corporation due to the failure of the principal to make the installation in accordance with this chapter, or any ordinance, building code, or regulation applicable thereto. However, the total liability of the surety on any bond may not exceed the sum of four thousand dollars, and the surety on the bond may not be liable for monetary penalties. Any action shall be brought within one year from the completion of the work in the performance of which the breach is alleged to have occurred. The surety shall mail a conformed copy of the judgment against the bond to the department within seven days. In the event that a cash or securities deposit has been made in lieu of the surety bond, and in the event of a judgment being entered against the depositor and deposit, the director shall upon receipt of a certified copy of a final judgment, pay the judgment from the deposit.

(9) The department shall issue a telecommunications contractor license to applicants meeting all of the requirements of this chapter applicable to electrical and telecommunications installations. The provisions of this chapter relating to the licensing of any person, firm, partnership, corporation, or other entity including the requirement of a bond with the state of Washington named as obligee and the collection of a fee for that bond, are exclusive, and no political subdivision of the state of Washington may require or issue any licenses or bonds or charge any fee for the same or a similar purpose.

19.28.430 Administrator's examination — Certificate — Administrator's requirements.

(1) Each applicant for a telecommunications contractor license shall designate a supervisory employee or member of the firm to take the administrator's examination. This person shall be designated as administrator under the contractor's license and must be a full-time supervisory employee of the applicant. No person may qualify as administrator for more than one contractor. If the relationship of the administrator with the telecommunications contractor is terminated, the contractor's license is void within ninety days unless another administrator is qualified by the board. However, if the administrator dies, the contractor's license is void within one hundred eighty days unless another administrator is qualified by the board.

(2) A certificate issued under this section is valid for two years from the nearest birthdate of the administrator, unless revoked or suspended, and is nontransferable. The certificate may be renewed for a two-year period without examination by appropriate application unless the certificate has been revoked, suspended, or not renewed within ninety days after the expiration date. If the certificate is not renewed before the expiration date, the individual shall pay twice the usual fee. A person may take the administrator's test as many times as necessary to pass, without limit.

(3) The administrator shall:

- (a) Be a member of the firm or a supervisory employee and shall be available during working hours to carry out the duties of an administrator under this section;
- (b) Ensure that all telecommunications work complies with the telecommunication[s] installation laws and rules;
- (c) Ensure proper permits are required and inspections made;
- (d) See that corrective notices issued by an inspecting authority are complied with; and
- (e) Notify the department in writing within ten days if the administrator relationship is terminated with the telecommunications contractor.

19.28.440 Examination for telecommunications administrators' certificates.

It is the purpose and function of the board to establish and administer written examinations for telecommunications administrators' certificates. Examinations shall be designed to reasonably ensure that telecommunications administrators' certificate holders are competent to engage in and supervise the work regulated under this subchapter and their respective licenses. The examinations shall include questions to assure proper safety and protection for the general public. The department, with the consent of the board, is permitted to enter into a contract with a professional testing agency to develop, administer, and score these examinations. The fee for the examination may be set by the department in its contract with the professional testing agency. The department may direct that the applicant pay the fee to the professional testing agency. The fee shall cover but not exceed the costs of preparing and administering the examination.

19.28.450 Local enforcement of subchapter — Enforcement of chapter.

(1) The director and the officials of all incorporated cities and towns where electrical inspections are required by local ordinances, allowed by RCW [19.28.141](#), may require by local ordinance the enforcement of this subchapter in their

respective jurisdictions. If an incorporated city or town elects to enforce this subchapter, the city or town has the power and shall enforce the provisions of this subchapter.

(2) The director, through the chief electrical inspector and other inspectors appointed under RCW 19.28.321, shall enforce this chapter. Compliance enforcement may be performed by contractor compliance inspectors appointed under chapter 18.27 RCW. The expenses of the director and the salaries and expenses of state inspectors incurred in carrying out the provisions of this chapter shall be paid entirely out of the electrical license fund, on vouchers approved by the director.

19.28.460 Disputes regarding local regulations — Arbitration — Panel.

Disputes arising under this chapter regarding whether any city or town's telecommunications rules, regulations, or ordinances are equal to the rules adopted by the department shall be resolved by arbitration. The department shall appoint two members of the board to serve on the arbitration panel, and the city or town shall appoint two persons to serve on the arbitration panel. These four persons shall choose a fifth person to serve. If the four persons cannot agree on a fifth person, the presiding judge of the superior court of the county in which the city or town is located shall choose a fifth person. A decision of the arbitration panel may be appealed to the superior court of the county in which the city or town is located within thirty days after the date the panel issues its final decision.

19.28.470 Inspections — Report — Required repairs/changes — Accessibility of telecommunications systems.

(1) The director shall require permits and require an inspector to inspect all installations of telecommunications systems on the customer side of the network demarcation point for projects greater than ten outlets. However:

- (a) All projects penetrating fire barriers, passing through hazardous locations and all backbone installations regardless of size shall be inspected;
- (b) All installations in single-family residences, duplex residences, and horizontal cabling systems within apartment residential units, including cooperatives and condominiums, do not require permits or inspections;
- (c) No permits or inspections may be required for installation or replacement of cord and plug connected telecommunications equipment or for patch cord and jumper cross-connected equipment;
- (d) The chief electrical inspector may allow a building owner or licensed electrical/telecommunications contractor to apply for annual permitting and regularly scheduled inspection of telecommunications installations made by licensed electrical/telecommunications contractors or the building owner for large commercial and industrial installations where:
 - (i) The building owner or licensed electrical/telecommunications contractor has a full-time telecommunications maintenance staff or a yearly maintenance contract with a licensed electrical/telecommunications contractor;
 - (ii) The permit is purchased before beginning any telecommunications work; and
 - (iii) The building owner or licensed electrical/telecommunications contractor assumes responsibility for correcting all installation deficiencies.

(2) Upon request, the department shall make the required inspection within forty-eight hours. The forty-eight hour period excludes holidays, Saturdays, and Sundays.

(3) A written report of the inspection, which plainly and clearly states any corrections or changes required, shall be made by the inspector. A copy of the report shall be furnished to the person or entity doing the installation work, and a copy shall be filed by the department.

(4) Whenever the installation of any telecommunications cabling and associated hardware is not in accordance with this chapter, or is in such a condition as to be dangerous to life or property, the person, firm, partnership, corporation, or other entity owning, using, or operating it shall be notified by the department and shall within fifteen working days, or such further reasonable time as may upon request be granted, make such repairs and changes as are required to remove the danger to life or property and to make it conform to this chapter. The director, through the inspector, is empowered to disconnect or order the discontinuance of the telecommunications cabling or electrical service to conductors or equipment that are found to be in a dangerous or unsafe condition and not in accordance with this chapter. Upon making a disconnection, the inspector shall attach a notice stating that the conductors have been found dangerous to life or property and are not in accordance with this chapter. It is unlawful for any person to reconnect such defective conductors or equipment without the approval of the department, and until the conductors and equipment have been placed in a safe and secure condition that complies with this chapter.

(5) The director, through the electrical inspector, has the right during reasonable hours to enter into and upon any building or premises in the discharge of his or her official duties related to permitting activities for the purpose of making any inspection or test of the installation of new or altered telecommunications systems contained in or on the buildings or premises. No telecommunications cabling subject to this chapter may be concealed until it has been approved by the inspector making the inspection. At the time of the inspection, wiring or equipment subject to this chapter must be sufficiently accessible to permit the inspector to verify installation conformance with the adopted codes and any other requirements of this chapter.

19.28.480 Unlawful acts — Interpretation of chapter.

- (1) It is unlawful for any person, firm, partnership, corporation, or other entity to install or maintain any telecommunications cabling and associated hardware in violation of this chapter. When the interpretation and application of the installation or maintenance standards provided for in this chapter are in dispute or in doubt, the board shall, upon application of any interested person, firm, partnership, corporation, or other entity, determine the methods of installation or maintenance of the cabling materials and hardware to be used in the case submitted for its decision.
- (2) Any person, firm, partnership, corporation, or other entity desiring a decision of the board under this section shall, in writing, notify the director of such desire and shall accompany the notice with a certified check payable to the department in the sum of two hundred dollars. The notice shall specify the ruling or interpretation desired and the contention of the person, firm, partnership, corporation, or other entity as to the proper interpretation or application on the question on which a decision is desired. If the board determines that the contention of the applicant for a decision was proper, the two hundred dollars shall be returned to the applicant; otherwise it shall be used in paying the expenses and per diem of the members of the board in connection with the matter. Any portion of the two hundred dollars not used in paying the per diem and expenses of the board in the case shall be paid into the electrical license fund.

19.28.490 Violation of chapter — Penalty — Appeal.

***** CHANGE IN 2014 – Effective 07/01/2015 *** (SEE 2146-S.SL) *****

Any person, firm, partnership, corporation, or other entity violating any of the provisions of this chapter may be assessed a penalty of not less than one hundred dollars or more than ten thousand dollars per violation. The department, after consulting with the board and receiving the board's recommendations, shall set by rule a schedule of penalties for violating this chapter. The department shall notify the person, firm, partnership, corporation, or other entity violating any of these provisions of the amount of the penalty and of the specific violation. The notice shall be sent using a method by which the mailing can be tracked or the delivery can be confirmed to the last known address of the assessed party. Penalties are subject to review by an appeal to the board. The filing of an appeal stays the effect of the penalty until the board makes its decision. The appeal shall be filed within twenty days after notice of the penalty is given to the assessed party, and shall be made by filing a written notice of appeal with the department. The notice shall be accompanied by a certified check for two hundred dollars, that shall be returned to the assessed party if the decision of the department is not sustained by the board. If the board sustains the decision of the department, the two hundred dollars shall be applied by the department to the payment of the per diem and expenses of the members of the board incurred in the matter, and any balance remaining after payment of per diem and expenses shall be paid into the electrical license fund. The hearing and review procedures shall be conducted in accordance with chapter 34.05 RCW. The board shall assign its hearings to an administrative law judge to conduct the hearing and issue a proposed decision and order. The board shall be allowed a minimum of twenty days to review a proposed decision and shall issue its decision no later than the next regularly scheduled board meeting.

19.28.501 Insurance/financial responsibility.

- (1) At the time of licensing and subsequent relicensing, the applicant shall furnish insurance or financial responsibility in the form of an assigned account in the amount of twenty thousand dollars for injury or damages to property, fifty thousand dollars for injury or damage including death to any one person, and one hundred thousand dollars for injury or damage including death to more than one person, or financial responsibility to satisfy these amounts.
- (2) Failure to maintain insurance or financial responsibility relative to the contractor's activities is cause to suspend or deny the contractor's license.
- (3)
 - (a) Proof of financial responsibility authorized in this section may be given by providing, in the amount required by subsection (1) of this section, an assigned account acceptable to the department. The assigned account shall be held by the department to satisfy any execution on a judgment issued against the contractor for damage to property or injury or death to any person occurring in the contractor's contracting operation, according to the provisions of the assigned account agreement. The department shall have no liability for payment in excess of the amount of the assigned account.
 - (b) The assigned account filed with the director as proof of financial responsibility shall be canceled three years after:
 - (i) The contractor's license has expired or been revoked;
 - (ii) The contractor has furnished proof of insurance as required by subsection (1) of this section; or
 - (iii) No legal action has been instituted against the contractor or on the account at the end of the three-year period.
 - (c) If a contractor chooses to file an assigned account as authorized in this section, the contractor shall, on a contracting project, notify each person with whom the contractor enters into a contract or to whom the contractor submits a bid, that the contractor has filed an assigned account in lieu of insurance and that recovery from the

account for any claim against the contractor for property damage or personal injury or death occurring on the project requires the claimant to obtain a court judgment.

19.28.511 Individual certification not required.

Individual worker certification is not required for work under this subchapter. This subchapter does not preclude any person performing telecommunications work from obtaining a limited energy credit towards an electrical certificate of competency if they otherwise meet the certification requirements under this chapter that are applicable to electrical installations.

19.28.521 Limitation of action — Proof of valid license required.

No person, firm, or corporation engaging in or conducting or carrying on the business of telecommunications installation shall be entitled to commence or maintain any suit or action in any court of this state pertaining to any such work or business, without alleging and proving that such person, firm or corporation held, at the time of commencing and performing such work, an unexpired, unrevoked, and unsuspended license issued under this subchapter; and no city or town requiring by ordinance or regulation a permit for inspection or installation of such telecommunications installation work, shall issue such permit to any person, firm or corporation not holding such license.

19.28.531 Unlawful installation/maintenance — Disputed interpretation — Board to determine methods.

It is unlawful for any person, firm, partnership, corporation, or other entity to install or maintain telecommunications equipment not in accordance with this subchapter. In cases where the interpretation and application of the installation or maintenance standards under this subchapter are in dispute or in doubt, the board shall, upon application of any interested person, firm, partnership, corporation, or other entity, determine the methods of installation or maintenance or the materials, devices, appliances, or equipment to be used in the particular case submitted for its decision.

19.28.541 Entity desiring board decision — Process.

Any person, firm, partnership, corporation, or other entity desiring a decision of the board pursuant to RCW [19.28.531](#) shall, in writing, notify the director of such desire and shall accompany the notice with a certified check payable to the department in the sum of two hundred dollars. The notice shall specify the ruling or interpretation desired and the contention of the person, firm, partnership, corporation, or other entity as to the proper interpretation or application on the question on which a decision is desired. If the board determines that the contention of the applicant for a decision was proper, the two hundred dollars shall be returned to the applicant; otherwise it shall be used in paying the expenses and per diem of the members of the board in connection with the matter. Any portion of the two hundred dollars not used in paying the per diem and expenses of the board in the case shall be paid into the electrical license fund.

19.28.551 Director's authority — Adoption of rules.

- (1) The director may adopt rules, make specific decisions, orders, and rulings, including demands and findings, and take other necessary action for the implementation and enforcement of this subchapter after consultation with the board and receiving the board's recommendations. In the administration of this subchapter the department shall not enter any controversy arising over work assignments with respect to the trades involved in the construction industry.
- (2) Compliance with the rules adopted under subsection (1) of this section is *prima facie* evidence of compliance with the subchapter. Copies of all rules shall be maintained by the department and made available upon request.

19.28.900 Severability — 1935 c 169.


If any section or part of this chapter shall be held and adjudged to be void or unconstitutional such adjudication shall not affect any other section or part of this chapter not adjudged to be void or unconstitutional.

19.28.910 Effective date — 1963 c 207.

This act shall take effect on July 1, 1963.

19.28.911 Severability — 1983 c 206.

If any provision of this act or its application to any person or circumstance is held invalid, the remainder of the act or the application of the provision to other persons or circumstances is not affected.



Electrical Safety Standards, Administration and Installation

State of Washington

WAC 296-46B

Effective July 2017



FIELD SERVICES AND PUBLIC SAFETY

José Rodríguez, Assistant Director

ELECTRICAL PROGRAM

Chief Electrical Inspector

Po Box 44460

Olympia, WA 98504-4460

(360) 902-5249

E-mail: ElectricalProgram@lni.wa.gov

ELECTRICAL LICENSING AND CERTIFICATION

PO Box 44460

Olympia, WA 98504-4460

(360) 902-5269

E-mail: ElectricalProgram@lni.wa.gov

ELECTRICAL PLAN REVIEW

7273 Linderson Way SW

Tumwater, WA 98501-4460

PO Box 44460

Olympia, WA 98504-4460

(360) 902-5246

E-mail: ElectricalProgram@lni.wa.gov

www.lni.wa.gov/TradesLicensing/Electrical

How to Request an Electrical Inspection:

<http://www.lni.wa.gov/TradesLicensing/Electrical/FeePermitInsp/PermitInspe ct/default.asp#3>

REGION ONE

BELLINGHAM, WA 98225-4647 (BHAM)

1720 Ellis St, Suite 200

(360) 647-7300 FAX (360) 647-7310

24 Hr Inspection Line (360) 647-7272

MOUNT VERNON, WA 98273-5500 (MTVE)

525 E College Way, Suite H

(360) 416-3000 FAX (360) 416-3031

24 Hr Inspection Line (360) 416-3005

EVERETT, WA 98208-3727 (TB26)

729 100TH ST SE

(425) 290-1309 FAX (425) 290-1399

24 Hr Inspection Line (425) 290-1310

REGION TWO

BELLEVUE, WA 98005-3037 (NB75)

616 120th Avenue NE, Suite C201

(425) 990-1400 FAX (425) 990-1446

24 Hr Inspection Line (425) 990-1430

TUKWILA, WA 98168-1050 (TB52)

PO Box 69050

12806 Gateway Drive

(206) 835-1000 FAX (206) 835-1199

24 Hr Inspection Line (206) 835-1198

REGION THREE

BREMERTON, WA 98837-1904 (WB07)

500 Pacific Avenue, Suite 400
(360) 415-4000 FAX (360) 415-4048
24 Hr Inspection Line (360) 415-4039

PORT ANGELES, WA 98362-4628

(PTAN)

1605 E Front St, Suite C
(360) 417-2702 FAX (360) 417-2733
24 Hr Inspection Line (360) 417-2722

TACOMA, WA 98402-4453 (WT21)

950 Broadway, Suite 200
(253) 596-3808 FAX (253) 596-3956
24 Hr Inspection Line (253) 596-3822

REGION FOUR

TUMWATER, WA (4814)

PO Box 44814
Olympia WA 98504-4814
7273 Linderson Way SW MS 4814
Tumwater WA 98501-5414
(360) 902-6350 FAX (360) 902-6340
24 Hr Inspection Line (360) 902-5242

ABERDEEN, WA 98520-0013 (WA42)

415 W Wishkah, Suite 1B
(360) 533-8200 FAX (360) 533-8220
24 Hr Inspection Line (360) 533-8229

VANCOUVER, WA 98684-3508 (S14)

312 SE Stonemill Dr, Suite 120
(360) 896-2360 FAX (360) 896-2345
24 Hr Inspection Line (360) 896-2350

KELSO, WA 98626-2650 (S10)

711 Vine St
(360) 575-6900 FAX (360) 575-6918
24 Hr Inspection Line (360) 575-6923

REGION FIVE

KENNEWICK, WA 99338 (KENN)

4310 W 24th Avenue
(509) 735-0100 FAX (509) 735-0120
24 Hr Inspection Line (509) 735-0148 EAST
WENATCHEE, WA 98802-5459 (EWEN)
519 Grant Rd
(509) 886-6500 FAX (509) 886-6510
24 Hr Inspection Line (509) 886-6520

MOSES LAKE, WA 98837-2907 (MLAK)

3001 W Broadway Ave
(509) 764-6900 FAX (509) 764-6923
24 Hr Inspection Line (509) 764-6966

YAKIMA, WA 98902-3480 (YAKI)

15 W Yakima Ave Suite 100
(509) 454-3760 FAX (509) 454-3710
24 Hr Inspection Line 1-800-442-7516

REGION SIX

SPOKANE, WA 99201-2149 (SPOK)

901 N Monroe Suite 100
(509) 324-2640 FAX (509) 324-2655
24 Hr Inspection Line (509) 324-2650

PULLMAN, WA 99163-2416 (PULL)

PO Box 847
1250 Bishop Blvd SE Suite G
(509) 334-5296 or 1-800-509-0025
FAX (509) 334-3417
24 Hr Inspection Line (509) 334-42

Chapter 296-46B WAC

Electrical safety standards, administration, and installation

Last Update: 05/30/17

Table of Contents

Part A – NEC installation amendments, standards, inspections, and definitions	8
WAC 296-46B-010 General.	8
Adopted standards.	8
Inspections - General.	8
Inspection move on buildings and structures.	9
Wiring methods for designated building occupancies.	10
Traffic management systems.	10
WAC 296-46B-100 General definitions.	11
WAC 296-46B-110 General - Requirements for electrical installations.	15
003 Examination, identification, installation, and use of equipment.	15
011 Deteriorating agents.	15
022 Identification of disconnecting means.	15
030 Over 1000 volts – General.	16
WAC 296-46B-210 Wiring and protection — Branch circuits.	16
008(A) Dwelling units GFCI requirements.	16
008(B) Other than dwelling units – GFCI requirements.	16
011 Branch circuits.	16
013 Ground fault protection of equipment.	16
025 Common area branch circuits.	16
052(A)(2) Dwelling unit receptacle outlets.	16
052(C) Countertops.	17
WAC 296-46B-215 Wiring and protection — Feeders.	17
005 Diagrams of feeders.	17
010 Ground fault protection testing.	17
WAC 296-46B-220 Wiring and protection — Branch circuit, feeder, and service calculations.	17
012 Lighting load calculations.	17
WAC 296-46B-225 Wiring and protection — Outside branch circuits and feeders.	18
030 Number of supplies.	18
032 Location of outside feeder disconnecting means.	18
036 Suitable for use as service equipment.	18
WAC 296-46B-230 Wiring and protection — Services.	18
001 General service requirements.	18
028 Service or other masts.	18
040 Service conductors - Two-family and multiple-occupancy buildings.	23
042 Service conductor - Size and rating.	23
043 Wiring methods for 1000 volts, nominal or less.	23
070 Service equipment – Disconnecting means.	24
095 Ground-fault protection of equipment.	24

200 Wiring methods exceeding 1000 volts.	24
WAC 296-46B-240 Overcurrent Protection.	24
024(C) Not exposed to physical damage.	24
024(F) Not located over steps.	25
WAC 296-46B-250 Wiring and protection — Grounding and bonding.	25
028(D)(3) Separately derived system with more than one enclosure.	25
052 Grounding electrodes.	25
053(A)(2) Resistance of rod, pipe, and, plate electrodes.	25
064 Grounding electrode conductor installation – Physical protection	25
068 Accessibility.	26
090 Bonding.	26
104(B) Bonding – Other metal piping.	26
184 Solidly grounded neutral systems over 1000 volts.	26
WAC 296-46B-300 Wiring methods and materials — Wiring methods.	27
005 Underground installations.	27
011 Support of raceways, cables, or boxes in suspended ceilings.	27
017 Conductors in raceway.	28
WAC 296-46B-314 Wiring methods and materials — Outlet, device, pull, and junction boxes.	28
001 Boxes and fittings.	28
023(H) Flexible cord connection of pendant boxes.	28
WAC 296-46B-334 Wiring methods and materials — Nonmetallic-sheathed cable.	29
010 Nonmetallic-sheathed cable.	29
015 Exposed work.	29
WAC 296-46B-336 Power and Control Tray Cable – Type TC.	29
010 Uses permitted.	29
WAC 296-46B-358 Wiring methods and materials — Electrical metallic tubing.	29
012 Electrical metallic tubing.	29
WAC 296-46B-394 Wiring methods and materials — Concealed knob-and-tube wiring.	29
001 Knob-and-tube wiring.	29
WAC 296-46B-406R Equipment for general use – Receptacles.	30
012 Tamper-resistant receptacles.	30
WAC 296-46B-410 Equipment for general use — Luminaires.	30
010 Luminaires.	30
062 Flexible cord connection of electric discharge luminaires.	30
WAC 296-46B-422 Equipment for general use — Appliances.	30
010 Water heater circuit.	30
WAC 296-46B-430 Motors, motor circuits, and controllers.	31
007 Marking on motors and multimotor equipment.	31
WAC 296-46B-440 Fixed electric space heating equipment.	31
014 Disconnecting means.	31
WAC 296-46B-450 Equipment for general use — Transformers and transformer vaults.	31
027 Flammable-liquid or oil-filled transformers installed outdoors.	31
Figure 450-1.	31
Figure 450-2.	32

WAC 296-46B-500 Hazardous (Classified) Locations — Classes I, II, and III, Divisions 1 and 2	32
005 Classification of Locations.....	32
WAC 296-46B-501 Special occupancies — NEC Class I locations.....	33
001 Sewage disposal systems.....	33
WAC 296-46B-505 Class I, Zone 0, 1, and 2 Locations.....	33
007 Implementation of Zone Classification	33
WAC 296-46B-513 Special occupancies — Aircraft Hangars.....	34
001 Scope	34
WAC 296-46B-514 Special occupancies — Motor fuel dispensing facilities.....	34
001 General.....	34
003 Classifications of locations.....	34
011 Emergency disconnecting means - Dispensing and service stations.....	34
WAC 296-46B-517 Special occupancies — Health care facilities.....	34
001 Health care facilities.....	34
013 Wiring methods.	35
017 Ground-fault protection.....	35
WAC 296-46B-547 Special occupancies — Agricultural buildings.....	35
001 Scope	35
WAC 296-46B-550 Special occupancies — Mobile homes, manufactured homes, and mobile home parks.	35
001 Mobile/manufactured homes - inspection.	35
032 Mobile/manufactured homes - service	36
033 Mobile/manufactured homes - feeder.....	36
WAC 296-46B-553 Special occupancies — Floating buildings.....	36
004 Floating buildings and similar facilities – Services and feeders.....	36
007 Floating buildings and similar installations - Wiring methods.....	36
WAC 296-46B-555 Special occupancies — Marinas, boatyards, and commercial and noncommercial docking facilities.....	36
WAC 296-46B-590 Special occupancies — Temporary installations.....	37
001 Temporary installations.	37
003 Temporary installations – time constraints.....	37
004 Temporary installations - splices.....	37
WAC 296-46B-600 Special equipment — Electric signs and outline lighting.	37
001 Electrical signs - General.	37
004 Markings.	38
007 Grounding and bonding.....	38
010 Portable or mobile outdoor electrical signs.	38
030 Neon tubing.	38
WAC 296-46B-680 Special equipment — Swimming pools, fountains, and similar installations.....	38
001 General.....	38
040 Spas and hot tubs.	39
070 Hydromassage bathtubs.	39
WAC 296-46B-690 Solar Photovoltaic Systems.	39
002 Definitions.....	39
004 Installation.	39

007 Maximum voltage.....	39
053 Direct-current photovoltaic power source.....	39
WAC 296-46B-694 Wind electric systems.....	40
WAC 296-46B-700 Emergency systems.....	40
001 Emergency systems - General.....	40
007 Signs.....	40
009 Emergency systems - Equipment identification.....	40
032 Coordination.....	40
WAC 296-46B-701 Legally required standby systems.....	40
007 Signs.....	40
027 Coordination.....	40
WAC 296-46B-702 Optional standby systems.....	41
007 Signs.....	41
WAC 296-46B-705 Interconnected electric power production sources.....	41
031 Location of overcurrent protection.....	41
WAC 296-46B 760 Fire alarm systems.....	41
WAC 296-46B 800 Communications systems — Communications circuits.....	41
General.....	41
001 Installation.....	41
002 Definitions.....	42
Part B – Electrical Plan Review.....	43
WAC 296-46B-900 Electrical plan review.....	43
Definition of occupancies.....	43
Plan review for educational, institutional, or health care facilities/buildings.....	44
Table 900-1 Health or Personal Care Facilities	46
Table 900-2 Educational and Institutional Facilities, Places of Assembly, or Other Facilities	46
Part C – Permits and fees.....	47
WAC 296-46B-901 General — Electrical work permits and fees.....	47
General.....	47
Permit - Responsibility for.....	47
Permit - Requirements for.....	47
Inspection and approval.....	49
Permit - Duration/refunds.....	49
Permit - Annual telecommunications.....	49
Permit - Annual electrical.....	49
Permit - Temporary construction project installations.....	50
Posting of corrections.....	50
WAC 296-46B-902 Equipment standards approval — City ordinances.....	50
Evaluation engineers, testing laboratories, and equipment standards.....	50
WAC 296-46B-903 Equipment standards.....	51
General.....	51
Industrial control panel and industrial utilization equipment inspection.....	51
WAC 296-46B-906 Inspection fees.	53
Part D – Provisional permits.....	60
WAC 296-46B-907 Provisional permits.....	60
Provisional electrical work permit - Use/duration/refunds.....	60

Part E – Class B permits.....	61
WAC 296-46B-908 – Class B permits.....	61
Class B electrical work permit - Use.	61
Part F – Administrative.....	63
WAC 296-46B-909 Electrical/telecommunications contractor's license, administrator certificate and examination, master electrician certificate and examination, electrician certificate and examination, copy, and miscellaneous fees.	63
WAC 296-46B-911 Electrical testing laboratory and engineer accreditation fees.	66
WAC 296-46B-915 Civil penalty schedule.	67
WAC 296-46B-920 Electrical/telecommunications license/certificate types and scope of work.	71
General Electrical. (01).....	71
Specialties.	71
WAC 296-46B-925 Electrical/telecommunications contractor's license.....	78
General.....	78
Electrical/telecommunications contractor bond, cash or securities deposit.	78
Telecommunications contractor insurance.....	78
Electrical/telecommunications contractor exemptions.	79
Exemptions - Electrical utility and electrical utility's contractor.	80
Exemptions - Electrical utility telecommunications transition equipment installations, maintenance and repair.	81
Exemptions - Independent electrical power production equipment exemption.	81
Exemptions - Telegraph and telephone utility and telegraph and telephone utility's contractor.	82
Exemptions - Manufacturers of electrical/telecommunications products.	82
Premanufactured electric power generation equipment assemblies and control gear.	82
Photovoltaic equipment.	83
WAC 296-46B-930 Assignment — Administrator or master electrician.	83
WAC 296-46B-935 Administrator certificate.....	84
General.....	84
Qualifying for examination.	84
Original - Administrator certificates.	84
Combination - Specialty administrator certificate.	84
Renewal - Administrator certificate.	84
WAC 296-46B-940 Electrician/certificate of competency required.	85
General.....	85
Electrician - Certificate of competency required.....	85
Original certificates of competency.	86
Renewal - Master electrician, journey level, and specialty electrician certificates of competency.	86
Exemptions - Lineworker.....	87
Exemptions - Plumbers.	87
WAC 296-46B-942 Training certificate required.	87
General.....	87
Original training certificates.	87
Specialty specific – Zero percent and seventy-five percent supervision modified training certificates.	87
Renewal of training certificates.	88
Trainees without supervision present on the job site.	89
Trainees seeking a journey level electrician certificate – Working with no supervision.	89

Trainees seeking certain specialty electrician certificates – Working with reduced or no supervision.	89
WAC 296-46B-945 Qualifying for master, journey level, specialty electrician examinations.....	90
General.....	90
Qualifying for the master electrician examination.....	90
Qualifying for the master electrician examination from out-of-state.....	90
Qualifying for the journey level electrician competency examination.....	90
Qualifying for a specialty electrician certificate of competency or examination.....	91
Table 945-1 Experience Hours.....	91
Qualifying for a certificate of competency when the Washington electrical work experience is exempt from certification requirements in RCW 19.28.261	92
General – Qualifying hours gained by applicants seeking work experience credit without a Washington electrician training certificate.....	92
Training school credit.....	92
Qualifying for the journey level/specialty electrician competency examination when work was performed in a state requiring electrician certification.....	93
Qualifying for the journey level/specialty electrician competency examination when work was performed in a state that does not require electrician certification.....	93
Military/shipyard experience.....	93
Experience in another country.....	93
WAC 296-46B-960 Administrator and electrician certificate of competency examinations.....	94
General.....	94
Special accommodations for examination.....	94
Failed examination appeal procedures.....	95
Failing an administrator certificate exam or electrician certificate of competency examination.....	95
Cheating on an examination.....	95
Examination confidentiality.....	95
WAC 296-46B-970 Continuing education and classroom education requirements.....	96
(1) Definitions - for purposes of this section.....	96
(2) General.....	96
(3) Class and instructor – General approval process.....	97
(4) Class approval process.....	98
(5) Instructor approval process.....	99
(6) Forms.....	100
(7) Class attendance.....	100
WAC 296-46B-971 Training schools.....	100
WAC 296-46B-975 Electrical audit. — General.....	102
Trainee hours.....	102
Administrator/master electrician - status.....	102
WAC 296-46B-980 Enforcement — Installations, licensing, and certification requirements.....	102
WAC 296-46B-985 Penalties for false statements or material misrepresentations.....	103
WAC 296-46B-990 Failure to comply with the electrical contractor licensing, administrator certification, or electrician certification laws	103
General.....	103
Suspension or revocation - Of an electrical contractor's license, administrator's certificate, master electrician's certificate of competency, electrician's certificate of competency, or training certificate.....	103

Confiscation - Of an electrical contractor's license, administrator certificate, electrician certificate of competency, or training certificate.	104
WAC 296-46B-995 Electrical board -Appeal rights and hearings	104
General.....	104
Appeals.....	105
Appearance and practice before board.....	106
WAC 296-46B-997 Engineer approval.....	107
Accreditation - General.....	107
Suspension or revocation.....	108
Business structure, practices, and personnel.	108
Recordkeeping and reporting - General.....	109
WAC 296-46B-999 Electrical testing laboratory requirements — General	109
Accreditation - General.....	110
Suspension or revocation.....	111
Business structure, practices, and personnel.	111
Recordkeeping and reporting - General.....	112
Recordkeeping and reporting - Certification.....	112
Recordkeeping and reporting - Field evaluation.	112
Facilities and equipment.....	113
Standards.	113
Product certification.....	113
Certification laboratory/manufacturer - Agreement.	114
Certification mark.	114
Certification laboratory product - Assurance/follow up.....	114
Field evaluation - Requirements.	115
Field evaluation mark.	115

Part A – NEC installation amendments, standards, inspections, and definitions

WAC 296-46B-010 General.

Adopted standards.

(1) The 2017 edition of the National Electrical Code (NFPA 70 - 2017) including Annex A, B, and C; Commercial Building Telecommunications Cabling Standard (ANSI/TIA-568-C series, February 2009); Commercial Building Standard for Telecommunications Pathway and Spaces (TIA-569-B, October 2004); Commercial Building Grounding and Bonding Requirements for Telecommunications (ANSI/TIA-607-B, August 2011); Residential Telecommunications Cable Standard (ANSI/TIA/EIA 570-B-2004); and the National Electrical Safety Code (NESC C2-2012 excluding Appendixes A and B) are hereby adopted by reference as part of this chapter.

This chapter will be followed where there is any conflict between this chapter and the above adopted standards.

The National Electrical Code will be followed where there is any conflict between the National Electrical Code and ANSI/TIA/EIA 568-C, ANSI/TIA/EIA 569-B, ANSI/TIA/EIA 607-B, ANSI/TIA/EIA 570-B, or the NESC C2.

Inspections - General.

(2) Electrical inspectors will give information as to the interpretation or application of the standards in this chapter, but will not lay out work or act as consultants for contractors, owners, or users.

(3) A variance from the electrical installation requirements of chapter [19.28](#) RCW or this chapter may be granted by the department or the city that has electrical inspection jurisdiction when it is assured that equivalent objectives can be achieved by establishing and maintaining effective safety.

- (a) Any electrical permit holder may request a variance.
- (b) The permit holder must make the request in writing, using a form provided by the department, to the chief electrical inspector or to the city that has electrical inspection jurisdiction. The request must include:
 - (i) A description of the installation as installed or proposed;
 - (ii) A detailed list of the applicable code violations;
 - (iii) A detailed list of safety violations;
 - (iv) A description of the proposal for meeting equivalent objectives for code and/or safety violations; and
 - (v) Appropriate variance application fee as listed in chapter [296-46B](#) WAC, Part C.

(4) Electrical wiring or equipment subject to this chapter must be sufficiently accessible, at the time of inspection, to allow the inspector to visually inspect the installation to verify conformance with the NEC and any other electrical requirements of this chapter with the exception of not more than 8 feet of electrical conduit in a foundation of a one- or two-family dwelling or residential outbuilding for use as service entrance raceway.

(5) All required equipment grounding conductors installed in concealed cable or flexible conduit systems must be completely installed and made up at the time of the rough-in cover inspection.

(6) The installation of all structural elements and mechanical systems (e.g., framing, plumbing, ducting, etc.) must be complete in the area(s) where electrical inspection is requested. Prior to completion of an exterior wall cover inspection, either:

- (a) The exterior shear panel/sheathing nail inspection must be completed by the building code inspector and, where siding nails or fasteners which penetrate into the wall cavity are to be used, all siding must be installed; or
- (b) All wiring and device boxes must be a minimum of 2 1/2 inches from the exterior surface of the framing member; or
- (c) All wiring and device boxes must be protected by a steel plate a minimum of 1/16 inch thick and of appropriate width and height installed to cover the area of the wiring or box.

(7) In order to meet the minimum electrical safety standards for installations, all materials, devices, appliances, and equipment, not exempted in chapter [19.28](#) RCW, must conform to applicable electrical product standards recognized by the department, be listed, or field evaluated. For any equipment that requires an amusement operating permit under chapter [67.42](#) RCW, the operating permit is *prima facie* evidence of an appropriate standard. Other than as authorized by the chief electrical inspector or a city authorized to do electrical inspection, equipment must not be energized until such standards are met.

(8) The state department of transportation is recognized as the inspection authority for telecommunications systems installations within the rights of way of state highways provided the department of transportation maintains and enforces an equal, higher or better standard of construction, and of materials, devices, appliances, and equipment than is required for telecommunications systems installations by chapter [19.28](#) RCW and this chapter.

Inspection move on buildings and structures.

(9) All buildings or structures relocated into or within the state:

- (a) Other than residential, wired inside the United States (U.S.) must be inspected to ensure compliance with current requirements of chapter [19.28](#) RCW and the rules developed by the department.
- (b) Wired outside the U.S. or Canada must be inspected to ensure compliance with all current requirements of chapter [19.28](#) RCW and the rules developed by the department.

(10) Residential buildings or structures wired in the U.S., to NEC requirements, and moved into or within a county, city, or town must be inspected to ensure compliance with the NEC requirements in effect at the time and place the original wiring was made. The building or structure must be inspected to ensure compliance with all current requirements of chapter [19.28](#) RCW and the rules developed by the department if:

- (a) The original occupancy classification of the building or structure is changed as a result of the move; or
- (b) The building or structure has been substantially remodeled or rehabilitated as a result of the move.

(11) Residential buildings or structures wired in Canada to Canadian Electrical Code (CEC) standards and moved into or within a county, city, or town, must be inspected to ensure compliance with the following minimum safety requirements:

- (a) Service, service grounding, and service bonding must comply with the current chapter [19.28](#) RCW and rules adopted by the department.
- (b) Canadian Standards Association (CSA) listed Type NMD cable is allowed with the following qualifications:
 - (i) CSA listed Type NMD cable, American Wire Gauge #10 and smaller installed after 1964 utilizing an equipment grounding conductor smaller than the phase conductors, must be:
 - (A) Replaced with a cable utilizing a full-size equipment grounding conductor; or
 - (B) Protected by a ground fault circuit interrupter protection device.
 - (ii) CSA listed Type NMD cable, #8 AWG and larger, must:
 - (A) Utilize an equipment grounding conductor sized according to the requirements of the NEC in effect at the time of the installation;
 - (B) Be protected by a ground fault circuit interrupter protection device; or
 - (C) Be replaced.

(c) Other types of wiring and cable must be:

- (i) Replaced with wiring listed or field evaluated in accordance with U.S. standards by a laboratory approved by the department; or
- (ii) Protected by a ground fault circuit interrupter protection device and arc fault circuit protection device.

(d) Equipment, other than wiring or panelboards, manufactured and installed prior to 1997 must be listed and identified by laboratory labels approved by the department or CSA labels.

(e) All panelboards must be listed and identified by testing laboratory labels approved by the department with the following qualifications:

- (i) CSA listed panelboards labeled "Suitable for Use as Service Equipment" will be considered to be approved as "Suitable for Use only as Service Equipment."
- (ii) CSA listed panelboards used as panelboards as described in the NEC, must meet all current requirements of the NEC and this chapter.

(f) Any wiring or panelboards replaced or changed as a result of the move must meet current requirements of chapter [19.28](#) RCW and this chapter.

(g) The location, type, and ground fault circuit interrupter protection of receptacles and equipment in a bathroom, kitchen, basement, garage, or outdoor area must meet the Washington requirements in effect at the time the wiring was installed.

(h) 4, 15-ampere, kitchen small appliance circuits will be accepted in lieu of 2, 20-ampere, kitchen small appliance circuits. Receptacles will not be required to be added on kitchen peninsular or island counters.

(i) Spacing requirements for all other receptacles must meet the Washington requirements in effect at the time the wiring was installed.

(j) Receptacles installed above baseboard or fixed wall space heaters must be removed and the outlet box covered with a blank cover. The receptacle is required to be relocated as closely as possible to the existing location.

(k) Lighting outlet and switch locations must meet the Washington requirements in effect at the time the wiring was installed.

- (l) Dedicated 20-ampere small appliance circuits are not required in dining rooms.
- (m) Electric water heater branch circuits must be adequate for the load.
- (n) The location, type, and circuit protection of feeders must meet the Washington requirements in effect at the time the wiring was installed.

Wiring methods for designated building occupancies.

- (12) Wiring methods in educational or institutional facilities as defined in this chapter must be metallic or nonmetallic raceways, MI, MC, or AC cable. Places of assembly located within these facilities must comply with NEC 518.4(A).
- (13) Assisted living facility generator systems may be wired and installed per NEC 517.
- (14) Lawfully installed existing electrical installations that do not comply with the provisions of this chapter and remain in compliance, with the code at the time of the installation, will be permitted to be continued without change (i.e. without circuitry or occupancy change). Additions, alterations, modifications, or repairs to the electrical system must conform to the current requirements of this chapter.
- (15) See WAC 296-46B-406R for tamper-resistant receptacle requirements in psychiatric patient care facilities.

Traffic management systems.

- (16) The department or city authorized to do electrical inspections will perform the electrical inspection and acceptance of traffic management systems within its jurisdiction. A traffic management system includes:
 - (a) Traffic illumination systems;
 - (b) Traffic signal systems;
 - (c) Traffic monitoring systems;
 - (d) The electrical service cabinet and all related components and equipment installed on the load side of the service cabinet supplying electrical power to the traffic management system; and
 - (e) Signalization system(s) necessary for the operation of a light rail system.A traffic management system can provide signalization for controlling vehicular traffic, pedestrian traffic, or rolling stock.
- (17) The department or city authorized to do electrical inspections recognizes that traffic signal conductors, pole and bracket cables, signal displays, traffic signal controllers/cabinets, and associated components used in traffic management systems are acceptable for the purpose of meeting the requirements of chapter [19.28](#) RCW provided they conform with the following standards or are listed on the Washington state department of transportation (WSDOT) qualified products list.
 - (a) WSDOT/APWA Standard Specifications and Plans;
 - (b) WSDOT Design Manual;
 - (c) International Municipal Signal Association (IMSA);
 - (d) National Electrical Manufacturer's Association (NEMA);
 - (e) Federal Standards 170/Controller Cabinets;
 - (f) Manual for Uniform Road, Bridge, and Municipal Construction;
 - (g) Institute of Transportation Engineers (ITE); or
 - (h) Manual of Uniform Traffic Control Devices (MUTCD).
- (18) Associated induction detection loop or similar circuits will be accepted by the department or city authorized to do electrical inspections without inspection.
- (19) For the licensing requirements of chapter [19.28](#) RCW, jurisdictions will be considered owners of traffic management systems when doing electrical work for another jurisdiction(s) under a valid interlocal agreement, as permitted by chapter [39.34](#) RCW. Interlocal agreements for traffic management systems must be filed with the department or city authorized to do electrical inspections prior to work being performed for this provision to apply.
- (20) Jurisdictions, with an established electrical inspection authority, and WSDOT may perform electrical inspection on their rights of way for each other by interlocal agreement. They may not perform electrical inspection on other rights of way except as allowed in chapter [19.28](#) or [39.34](#) RCW.
- (21) Underground installations.
 - (a) In other than open trenching, raceways will be considered "fished" according to the NEC and do not require visual inspection.
 - (b) The department or city authorized to do electrical inspections will conduct inspections in open trenching within its jurisdiction. The electrical work permit purchaser must coordinate the electrical inspection. A written request (e.g., letter, email, fax, etc.) for inspection, made to the department or city authorized to do electrical inspections office having the responsibility to perform the inspection, must be made a minimum of two working days prior to the day inspection is needed (e.g., two working days 10:00 a.m. Tuesday request for a 10:00 a.m. Thursday inspection, excluding holidays and weekends).

If, after proper written request, the department or city authorized to do electrical inspections fails to make an electrical inspection at the time requested, underground conduit may be covered after inspection by the local government jurisdiction's project inspector/designee. Written documentation of a local government jurisdiction inspection must be provided to the department or city authorized to do electrical inspections when requested. Written documentation will include:

- (i) Date and time of inspection;
- (ii) Location;
- (iii) Installing firm;
- (iv) Owner;
- (v) Type of conduit;
- (vi) Size of conduit;
- (vii) Depth of conduit; and
- (viii) Project inspector/designee name and contact information.

(22) Identification of traffic management system components. Local government jurisdictions or WSDOT may act as the certifying authority for the safety evaluation of all components.

- (a) An electrical service cabinet must contain only listed components. The electrical service cabinet enclosure is not required to be listed but will conform to the standards in subsection (17) of this section.
- (b) The local government jurisdiction must identify, as acceptable, the controller cabinet or system component(s) with an identification plate. The identification plate must be located inside the cabinet and may be attached with adhesive.

(23) Conductors of different circuits in same cable, enclosure, or raceway. All traffic management system circuits will be permitted to occupy the same cable, enclosure, or raceway without regard to voltage characteristics, provided all conductors are insulated for the maximum voltage of any conductor in the cable, enclosure, or raceway.

WAC 296-46B-100 General definitions.

All definitions listed in the National Electrical Code and chapter [19.28](#) RCW are recognized in this chapter unless other specific definitions are given in this chapter and chapter [19.28](#) RCW. The definitions in this section apply to all parts of this chapter. Some sections may have definitions specific to that section.

"Accreditation" is a determination by the department that a laboratory meets the requirements of this chapter and is therefore authorized to evaluate electrical products that are for sale in the state of Washington.

"Administrative law judge" means an administrative law judge (ALJ) appointed pursuant to chapter [34.12](#) RCW and serving in board proceedings pursuant to chapter [19.28](#) RCW and this chapter.

"ANSI" means American National Standards Institute. Copies of ANSI standards are available from the National Conference of States on Building Codes and Standards, Inc.

"Appeal" is a request for review of a department action by the board as authorized by chapter [19.28](#) RCW.

"Appellant" means any person, firm, partnership, corporation, or other entity that has filed an appeal or request for board review.

"Appliance" means household appliance.

"ASTM" means the American Society for Testing and Materials. Copies of ASTM documents are available from ASTM International.

"AWG" means American Wire Gauge.

"Basement" means that portion of a building that is partly or completely below grade plane. A basement will be considered as a story above grade plane and not a basement where the finished surface of the floor above the basement is:

- (a) More than 6 feet above grade plane;
- (b) More than 6 feet above the finished ground level for more than 50% of the total building perimeter; or
- (c) More than 12 feet above the finished ground level at any point.

Also see "mezzanine" and "story."

"Board" means the electrical board established and authorized under chapter [19.28](#) RCW.

"Category list" is a list of manufacturing safety standards or product types determined by the department.

A "certified electrical product" is an electrical product to which a laboratory, accredited by the state of Washington, has the laboratory's certification mark attached.

A "certification mark" is a specified laboratory label, symbol, or other identifying mark that indicates the manufacturer produced the product in compliance with appropriate standards or that the product has been tested for specific end uses.

"Certificate of competency" includes the certificates of competency for master journey level electrician, master specialty electrician, journey level, and specialty electrician.

A laboratory "certification program" is a specified set of testing, inspection, and quality assurance procedures, including appropriate implementing authority, regulating the evaluation of electrical products for certification marking by an electrical products certification laboratory.

A "complete application" includes the submission of all appropriate fees, documentation, and forms.

"Chapter" means chapter 296-46B WAC unless expressly used for separate reference.

"Construction," for the purposes of chapter [19.28](#) RCW, means electrical construction.

"Coordination (selective)" as defined in NEC 100 must be determined and documented by a professional engineer registered under chapter [18.43](#) RCW.

"Department" means the department of labor and industries of the state of Washington.

"Director" means the director of the department, or the director's designee.

"Egress – unobstructed (as applied to NEC 110.26(C)(2)(a))" means an egress path that allows a worker to travel to the exit from any other area in the room containing the equipment described in NEC 110.26(C)(2) without having to pass through that equipment's required working space.

"Electrical equipment" includes electrical conductors, conduit, raceway, apparatus, materials, components, and other electrical equipment not exempted by RCW [19.28.006](#)(9). Any conduit/raceway of a type listed for electrical use is considered to be electrical equipment even if no wiring is installed in the conduit/raceway at the time of the conduit/raceway installation.

An "electrical products certification laboratory" is a laboratory or firm accredited by the state of Washington to perform certification of electrical products.

An "electrical products evaluation laboratory" is a laboratory or firm accredited by the state of Washington to perform on-site field evaluation of electrical products for safety.

"Field evaluated" means an electrical product to which a field evaluation mark is attached. Field evaluation must include job site inspection unless waived by the department, and may include component sampling and/or laboratory testing.

"Field evaluation mark" is a specified laboratory label, symbol, or other identifying mark indicating the manufacturer produced the product in essential compliance with appropriate standards or that the product has been evaluated for specific end uses.

A "field evaluation program" is a specified set of testing, inspection, and quality assurance procedures, including appropriate implementing authority regulating the testing and evaluation of electrical products for field evaluation marking.

The "filing" is the date the document is actually received in the office of the chief electrical inspector.

"Final judgment" means any money that is owed to the department under this chapter, including fees and penalties, or any money that is owed to the department as a result of an individual's or contractor's unsuccessful appeal of a citation.

"Fished wiring" is when cable or conduit is installed within the finished surfaces of an existing building or building structure (e.g., wall, floor or ceiling cavity).

"Household appliance" means utilization equipment installed in a dwelling unit that is built in standardized sizes or types and is installed or connected as a unit to perform one or more functions such as cooking and other equipment installed in a kitchen, clothes drying, clothes washing, portable room air conditioning units and portable heaters, etc. Fixed electric space-heating equipment covered in NEC 424 (furnaces, baseboard and wall heaters, electric heat cable, etc.) and fixed air-conditioning/heat pump equipment (NEC 440) are not household appliances. Household appliance does not mean any utilization equipment that:

- (a) Supplies electrical power, other than Class 2, to other utilization equipment; or
- (b) Receives electrical power, other than Class 2, through other utilization equipment.

HVAC/refrigeration specific definitions:

- (a) "HVAC/refrigeration" means heating, ventilation, air conditioning, and refrigeration.
- (b) "HVAC/refrigeration component" means electrical power and limited energy components within the "HVAC/refrigeration system," including, but not limited to: Pumps, compressors, motors, heating coils, controls, switches, thermostats, humidistats, low-voltage damper controls, outdoor sensing controls, outside air dampers, stand-alone duct smoke detectors, air monitoring devices, zone control valves and equipment for monitoring of HVAC/refrigeration control panels and low-voltage connections. This definition excludes equipment and components of non-HVAC/refrigeration control systems."
- (c) "HVAC/refrigeration control panel" means an enclosed, manufactured assembly of electrical components designed specifically for the control of a HVAC/refrigeration system. Line voltage equipment that has low voltage, NEC Class 2 control or monitoring components incidental to the designed purpose of the equipment is not an HVAC/refrigeration control panel (e.g., combination starters).
- (d) "HVAC/refrigeration control system" means a network system regulating and/or monitoring a HVAC/refrigeration system. Equipment of a HVAC/refrigeration control system includes, but is not limited to: Control panels, data centers, relays, contactors, sensors, and cables related to the monitoring and control of a HVAC/refrigeration system(s).

(e) "HVAC/refrigeration equipment" means the central unit primary to the function of the "HVAC/refrigeration system." HVAC/refrigeration includes, but is not limited to: Heat pumps, swamp coolers, furnaces, compressor packages, and boilers.

(f) "HVAC/refrigeration system" means a system of HVAC/refrigeration: Wiring, equipment, and components integrated to generate, deliver, or control heated, cooled, filtered, refrigerated, or conditioned air. This definition excludes non-HVAC/refrigeration control systems (e.g., fire alarm systems, intercom systems, building energy management systems, and similar non-HVAC/refrigeration systems).

"IBC" means the International Building Code. Copies of the IBC are available from the International Code Council.

An "individual" or "party" or "person" means an individual, firm, partnership, corporation, association, government subdivision or unit thereof, or other entity.

An "installation" includes the act of installing, connecting, repairing, modifying, or otherwise performing work on an electrical system, component, equipment, or wire except as exempted by WAC [296-46B-925](#). An installation is not the passive testing or operational programming of an electrical system, component, equipment, or wire. See "passive testing."

An "identification plate" is suitable for the environment and is a printed or etched adhesive label approved by the department or a phenolic or metallic plate or other similar material engraved in block letters at least $\frac{1}{4}$ inch high unless specifically required to be larger by this chapter, suitable for the environment and application. The letters and the background must be in contrasting colors. Screws, rivets, permanent adhesive, or methods specifically described in this chapter must be used to affix an identification plate to the equipment or enclosure.

"Job site" means a specific worksite having a single address or specific physical location (e.g., a single-family residence, a building, a structure, a marina, an individual apartment building with a specific address, etc.)

"Journey level electrician" means a person who has been issued a journey level electrician certificate of competency by the department. "The terms "journey level" and "journeyperson" in chapter 19.28 RCW are synonymous."

"Labeled" means an electrical product that bears a certification mark issued by a laboratory accredited by the state of Washington.

A "laboratory" may be either an electrical product(s) certification laboratory or an electrical product(s) evaluation laboratory.

A "laboratory operations control manual" is a document to establish laboratory operation procedures and may include a laboratory quality control manual.

"License" means a license required under chapter 19.28 RCW.

"Like-in-kind" means having the same overcurrent protection requirements and similar characteristics such as voltage requirement, current draw, short circuit characteristics, and function within the system and being in the same location. Like-in-kind also includes any equipment component authorized by the manufacturer as a suitable component replacement part.

For the purpose of WAC [296-46B-940](#), a "lineworker" is a person employed by a serving electrical utility or employed by a licensed general electrical contractor who carries, on their person, evidence that they:

- (a) Have graduated from a department-approved lineworker's apprenticeship course; or
- (b) Are currently registered in a department-approved lineworker's apprenticeship course and are working under the direct one hundred percent supervision of a journey level electrician or a graduate of a lineworker's apprenticeship course approved by the department. The training received in the lineworker's apprenticeship program must include training in applicable articles of the currently adopted National Electrical Code.

"Listed" means equipment has been listed and identified by a laboratory approved by the state of Washington for the appropriate equipment standard per this chapter.

"Low voltage" means:

- (a) NEC, Class 1 power limited circuits at 30 volts maximum.
- (b) NEC, Class 2 circuits powered by a Class 2 power supply as defined in NEC 725.121(A).
- (c) NEC, Class 3 circuits powered by a Class 3 power supply as defined in NEC 725.121(A).
- (d) Circuits of telecommunications systems as defined in chapter [19.28](#) RCW.

"Member of the firm" means the member(s) on file with the Department of Licensing for sole proprietorships/partnerships or with the Secretary of State for corporations.

"Mezzanine" is the intermediate level or levels between the floor and ceiling of any story with an aggregate floor area of not more than one-third of the area of the room or space in which the level or levels are located. Also see "basement" and "story."

"NEC" means National Electrical Code. Copies of the NEC are available from the National Fire Protection Association.

"NEMA" means National Electrical Manufacturer's Association. Copies of NEMA standards are available from the National Electrical Manufacturer's Association.

"NESC" means National Electrical Safety Code. Copies of the NESC are available from the Institute of Electrical and Electronics Engineers, Inc.

"NETA" means International Electrical Testing Association, Inc. Copies of the NETA standards and information are available from the International Electrical Testing Association, Inc.

"NFPA" means the National Fire Protection Association. Copies of NFPA documents are available from the National Fire Protection Association.

"NRTL" means Nationally Recognized Testing Laboratory accredited by the federal Occupational Safety and Health Administration (OSHA) after meeting the requirements of 29 C.F.R. 1910.7.

"Passive testing" (e.g., pressing of test buttons, use of testing equipment like voltage testers, clamp-on meters, removal of a device head where the wiring is terminated on a separate base plate, etc.) means testing that does not require any:

- (a) Physical modification to the electrical system wiring; or
- (b) Wiring to be disconnected or terminated, except as necessary for an approved electrical testing laboratory or approved engineer performing an equipment evaluation.

"Point of contact" or "point of connection" means the service point.

"Proceeding" means any matter regarding an appeal before the board including hearings before an administrative law judge.

"Public area or square" is an area where the public has general, clear, and unrestricted access.

A "quality control manual" is a document to maintain the quality control of the laboratory's method of operation. It consists of specified procedures and information for each test method responding to the requirements of the product standard. Specific information must be provided for portions of individual test methods when needed to comply with the standard's criteria or otherwise support the laboratory's operation.

"RCW" means the Revised Code of Washington. Copies of electrical RCW are available from the department and the office of the code reviser.

"Readily accessible" means the definition as defined in NEC 100. In addition, it means that, except for keys, no tools or other devices are necessary to gain access (e.g., covers secured with screws, etc.)

Service specific definitions replacing those found in NEC Article 100:

- (a) "Service drop" means the overhead service conductors from the service point to the connection to the service-entrance conductors at the building or other structure.
- (b) "Service-entrance conductors, overhead system" means the service conductors between the terminals of the service equipment and a point usually outside the building, clear of building walls, where joined by tap or splice to the service drop or service point.
- (c) "Service-entrance conductors, underground system" means the service conductors between the terminals of the service equipment and the point of connection to the service lateral or service point. Where the service equipment is located outside the building walls, there may be no service-entrance conductors or they may be entirely outside the building.
- (d) "Service lateral" means the underground service conductors from the service point to the point of connection to the service-entrance conductors in a terminal box, meter, or other enclosure. Where there is not a terminal box, meter, or other enclosure, the point of connection is the point of entrance of the service conductors into the building.

A "stand-alone amplified sound or public address system" is a system that has distinct wiring and equipment for audio signal generation, recording, processing, amplification, and reproduction. This definition does not apply to telecommunications installations.

"Service" or "served" means that as defined in RCW [34.05.010](#)(19) when used in relation to department actions or proceedings.

A "sign," when required by the NEC, for use as an identification method (e.g., legibly marked, legible warning notice, marked, field marked, permanent plaque/directory, etc.) means "identification plate."

"Story" is that portion of a building included between the upper surface of a floor and the upper surface of the floor or roof next above. Next above means vertically and not necessarily directly above. Also see "basement" and "mezzanine."

"Structure," for the purposes of this chapter and in addition to the definition in the NEC, means something constructed either in the field or factory that is used or intended for supporting or sheltering any use or occupancy as defined by the IBC.

"Supervision" for the purpose of supervising electrical trainees, means that the appropriately certified supervising electrician is on the same job site as the trainee being supervised. The trainee is not considered to be on the same job site if the supervising electrician and the trainee are working:

- (a) In separate buildings at a single address (e.g., a campus, multibuilding industrial complex, multibuilding apartment complex, etc.) except for a single-family residence; or
- (b) On an outdoor project (e.g., irrigation system, farm, street lighting, traffic signalization, etc.) where the trainee is more than 1,000 feet from the supervising electrician or where the trainee is more than 200 feet from the supervising electrician and out of sight.

"System design review" means a set of design documents that include the manufacturer's installation information, a legible one-line diagram of the system design, and calculations used to determine voltage and current within the system. The one-line diagram must show the system equipment, devices, overcurrent protection, conductor sizing, grounding, ground fault protection if required, and any system interconnection points. The review must be available to the inspector during all inspections.

A "telecommunications local service provider" is a regulated or unregulated (e.g., by the Federal Communications Commission or the utilities and transportation commission as a telephone or telecommunications provider) firm providing telecommunications service ahead of the telecommunications network demarcation point to an end-user's facilities.

"TIA/EIA" means the Telecommunications Industries Association/Electronic Industries Association which publishes the TIA/EIA Telecommunications Building Wiring Standards. Standards and publications are adopted by TIA/EIA in accordance with the American National Standards Institute (ANSI) patent policy.

A "training school" is a public community or technical college or not-for-profit nationally accredited technical or trade school licensed by the work force training and education coordinating board under chapter 28C.10 RCW.

"Under the control of a utility" for the purposes of RCW [19.28.091](#) and [19.28.101](#) is when electrical equipment is not owned by a utility and:

- (a) Is located in a vault, room, closet, or similar enclosure that is secured by a lock or seal so that access is restricted to the utility's personnel; or
- (b) The utility is obligated by contract to maintain the equipment and the contract provides that access to the equipment is restricted to the utility's personnel or other qualified personnel.

"UL" means Underwriters Laboratory.

"Utility" means an electrical utility.

"Utility system" means electrical equipment owned by or under the control of a serving utility that is used for the transmission or distribution of electricity from the source of supply to the point of contact and is defined in section 90.2(b)(5) of the National Electrical Code, 1981 edition (see RCW [19.28.010](#)(1)).

"Utilization voltage" means the voltage level employed by the utility's customer for connection to lighting fixtures, motors, heaters, or other electrically operated equipment other than power transformers.

"Variance" is a modification of the electrical requirements as adopted in chapter [19.28](#) RCW or any other requirements of this chapter that may be approved by the chief electrical inspector if assured that equivalent objectives can be achieved by establishing and maintaining effective safety.

"WAC" means the Washington Administrative Code. Copies of this chapter of the WAC are available from the department and the office of the code reviser.

WAC 296-46B-110 General - Requirements for electrical installations.

003 Examination, identification, installation, and use of equipment.

(1) Listed electrical conduit can only be installed and used in accordance with its listing (i.e. as an electrical raceway for electrical conductors). If used as a sleeve for electrical conductors or other listed electrical conduits, the installation of a listed electrical conduit will be assumed to be for use as an electrical raceway and must be installed as allowed by chapter [19.28](#) RCW and this chapter (e.g., owner exemption, electrical contractor, etc.).

011 Deteriorating agents.

(2) Electrical equipment and wiring that has been submerged or exposed to water must comply with the following:

- (a) All breakers, fuses, controllers, receptacles, lighting switches/dimmers, electric heaters, and any sealed device/equipment (e.g., relays, contactors, etc.) must be replaced.
- (b) All other electrical equipment (e.g., wiring, breaker panelboards, disconnect switches, switchgear, motor control centers, boiler controls, HVAC/R equipment, electric motors, transformers, appliances, water heaters, and similar appliances) must be replaced or reconditioned by the original manufacturer or by its approved representative.

022 Identification of disconnecting means.

(3) For the purposes of legibly marking a disconnecting means, as required in NEC 110.22, an identification plate is required unless the disconnect is a circuit breaker/fused switch installed within a panelboard and the circuit breaker/fused switch is identified by a panelboard schedule. In other than dwelling units, the identification plate must include the identification designation of the circuit source panelboard that supplies the disconnecting means.

030 Over 1000 volts – General.

4) Each cable operating at over 1000 volts and installed on customer-owned systems must be legibly marked in a permanent manner at each termination point and at each point the cable is accessible. The required marking must use phase designation, operating voltage, and circuit number if applicable.

WAC 296-46B-210 Wiring and protection — Branch circuits.

008(A) Dwelling units GFCI requirements.

(1) In a garage or unfinished basement, a red receptacle, with a red cover plate, supplying a fire alarm system is not required to have ground-fault circuit-interrupter protection. The receptacle must be identified for use only with the fire alarm system by an identification plate or engraved cover with letters at least $\frac{1}{4}$ inch high.

(2) All fixed electrical equipment with exposed grounded metal parts within an enclosed shower area or within 5 feet of the top inside edge of a bathtub must have ground fault circuit interrupter protection.

008(B) Other than dwelling units – GFCI requirements.

(3) GFCI requirements. GFCI protection for personnel will not be required for three-phase receptacles unless specifically required elsewhere in the NEC.

For the purposes of NEC 210.8(B), kitchen means any area where utensils, dishes, etc., are cleaned or where food or beverages are prepared or cooked.

011 Branch circuits.

(4) A raceway system or one dedicated 15 – ampere minimum, 120 volt circuit must be taken to all unfinished space areas adaptable to future dwelling unit living areas that are not readily accessible to the service or branch circuit panelboard. One circuit or raceway is required for each 480 square feet or less of unfinished space area. If the total adjacent unfinished space area is less than 480 square feet, the circuit can be an extension of an existing circuit. The circuits must terminate in a suitable box(es). The box must contain an identification of the intended purpose of the circuit(s). The branch circuit panelboard must have adequate space and capacity for the intended load(s).

013 Ground fault protection of equipment.

(5) Equipment ground fault protection systems required by the NEC must be tested prior to being placed into service to verify proper installation and operation of the system as determined by the manufacturer's published instructions. A firm having qualified personnel and proper equipment must perform the tests required. A copy of the manufacturer's performance testing instructions and a written performance acceptance test record signed by the person performing the test must be available at the time of inspection. The performance acceptance test record must include test details including, but not limited to, all trip settings and measurements taken during the test.

025 Common area branch circuits.

(6) For the purpose of NEC 210.25, loads for septic or water well systems that are shared by no more than two dwelling units may be supplied from either of the two dwelling units if approved by the local building official and local health department.

052(A)(2) Dwelling unit receptacle outlets.

(7) For the purpose of NEC 210.52(A)(2)(1), "similar openings" include the following configurations that are a permanent part of the dwelling configuration or finish:

- Window seating; and
- Bookcases or cabinets that extend from the floor to a level at least 5 feet 6 inches above the floor.

Any outlets eliminated by such window seating, bookcases, or cabinets must be installed elsewhere within the room.

052(C) Countertops.

(8) A receptacle in a wall countertop space shall be permitted to serve as the receptacle for a peninsular countertop space where the spaces are contiguous and the receptacle is located within 8 feet of the outside edge of the peninsular countertop.

WAC 296-46B-215 Wiring and protection — Feeders.

005 Diagrams of feeders.

(1) Other than plan review projects, the installer must provide a one-line diagram showing the service and feeder details for the project before the initial inspection can be approved for all non-dwelling services or feeders:

- (a) Larger than 400 amperes; or
- (b) Over 600 volts.

The diagram must be signed and dated by the project owner if the owner is doing the work, the assigned administrator or master electrician if an electrical contractor is doing the work, or stamped with an engineer's mark and signature who is registered under chapter [18.43](#) RCW. The diagram must show:

- (c) All services including: wire size(s), wire type(s), service size(s) (e.g. voltage, phase, ampacity), overcurrent protection, available symmetrical fault current at the service point, equipment short-circuit rating, total load before and after demand factors have been applied including any demand factors used, and a panel schedule where multiple disconnecting devices are present; and
- (d) All feeders including: wire size(s), wire type(s), feeder size(s) (e.g. voltage, phase, ampacity), overcurrent protection, total calculated load before and after demand factors have been applied including any demand factors used, and a panel schedule(s) where multiple disconnecting devices are present.

If the installer deviates, in any way, from the service/feeder design shown on the diagram, a supplemental diagram must be supplied to the inspector showing the most recent design before inspection can proceed. Load reductions and moving branch circuit locations within a panelboard do not require a supplemental diagram.

Written documentation must also be provided to the inspector that the supplemental diagram was provided to the project owner at the time of submission to the inspector.

The diagram must be available on the job site during the inspection process.

010 Ground fault protection testing.

(2) Equipment ground fault protection systems required by the NEC must be tested prior to being placed into service to verify proper installation and operation of the system as determined by the manufacturer's published instructions. This test or a subsequent test must include all system feeders unless the installer can demonstrate, in a manner acceptable to the inspector, that there are no grounded conductor connections to the feeder(s). A firm having qualified personnel and proper equipment must perform the tests required. A copy of the manufacturer's performance testing instructions and a written performance acceptance test record signed by the person performing the test must be available at the time of inspection. The performance acceptance test record must include test details including, but not limited to, all trip settings and measurements taken during the test.

WAC 296-46B-220 Wiring and protection — Branch circuit, feeder, and service calculations.

012 Lighting load calculations.

In determining feeder and service entrance conductor sizes and equipment ratings, a building that is designed and constructed to comply with the currently adopted Washington state energy code unit lighting power allowance table and footnotes may be used in lieu of NEC 220.12. The requirements of NEC 220.12 Exception No. 1, items 1, 2, and 3 do not apply.

WAC 296-46B-225 Wiring and protection — Outside branch circuits and feeders.

030 Number of supplies.

(1) For the purposes of NEC 225.30(A) and this section, a building/structure that is supplied from a remote service, may be supplied by no more than six feeders originating from the service equipment and with each feeder terminating in a single disconnecting means at the building/structure. The service equipment must contain overcurrent protection appropriate to each feeder. The building disconnecting means required by NEC 225.32 must be grouped, within sight and all be within 10' of each other.

032 Location of outside feeder disconnecting means.

(2) The disconnecting means required by NEC 225.32 must be provided to disconnect all ungrounded conductors that supply or pass through a building/structure in accordance with the requirements of NEC 225.32 with the following exceptions.

- (a) Outside location: A feeder disconnecting means, including that required by NEC 700, 701, or 702 for a generator, is considered in the building if installed on the outside of the building/structure or within sight and within fifteen feet of the building/structure. The building disconnecting means may supply only one building/structure unless the secondary building(s)/structure(s) has a separate building disconnecting means meeting the requirements of the NEC and this subsection. The disconnecting means must have an identification plate with at least one-half-inch high letters identifying:
 - (i) The building/structure served; and
 - (ii) Its function as the building/structure main disconnect(s).
- (b) Inside location: The feeder disconnecting means may be installed anywhere inside a building/structure when there is a feeder disconnecting means, located elsewhere on the premises, with overcurrent protection sized for the feeder conductors.

036 Suitable for use as service equipment.

(3) A generator disconnecting means installed per (2)(a) or (2)(b) of this section, is not required to be suitable for use as service equipment.

WAC 296-46B-230 Wiring and protection — Services.

001 General service requirements.

- (1) The owner, the owner's agent, or the electrical contractor making the installation must consult the serving utility regarding the utility's service entrance requirements for equipment location and meter equipment requirements before installing the service and equipment. Provisions for a meter and related equipment, an attachment of a service drop, or an underground service lateral must be made at a location acceptable to the serving utility. The point of contact for a service drop must permit the clearances required by the NEC.
- (2) A firewall must have a minimum two-hour rating as defined by the local building official to be considered a building separation in accordance with Article 100 NEC.
- (3) The height of the center of the service meter must be as required by the serving utility. Secondary instrument transformer metering conductor(s) are not permitted in the service raceway.


028 Service or other masts.

- (4) Conduit extended through the roof to provide means of attaching:
 - (a) All overhead drops for service, feeder, or branch circuits exceeding #1 AWG aluminum or #3 AWG copper must be rigid steel galvanized conduit no smaller than 2 inches.
 - (b) All overhead drops for service, feeder or branch circuits not exceeding #1 AWG aluminum or #3 AWG copper must be rigid steel galvanized conduit no smaller than 1 1/4 inches. The installation must comply with drawings E-101 and/or E-102, or must provide equivalent strength by other approved means. Masts for altered or relocated installations will be permitted to comply with drawing E-103.


(c) For the purposes of NEC 225.19 and 230.24, a residential patio cover, that is not over one story and not over 12 feet in height and is used only for recreation or outdoor living purposes and not as a carport, garage, storage room or habitable room as described in Appendix Chapter I in the IBC and Appendix Chapter H in the IRC, is not considered a roof. Overhead conductor spans must maintain a minimum 36 inches clearance above these covers.

Revised 2006

Surface Mount Meter Base



Recessed Meter Base




Mast Not Over 26" High - Service Bracket 24" Or Less Above Roof Surface

Service Mast Installation Details


Drawing E-101

Revised 2006

Guying – Cable Type



Guying – Stiff-Leg Type




Mast Over 26" High - Service Bracket Over 24" Above Roof Surface

Service Mast Installation Details

Drawing E-102

Revised 2006



Service Mast Installation Details (Per Note 6)

Drawing E-103

Notes to drawings E-101, E-102, and E-103

(1) An approved roof flashing must be installed on each mast where it passes through a roof. Plastic, nonhardening mastic must be placed between lead-type flashings and the conduit. Neoprene type flashings will also be permitted to be used.
(2) Masts must be braced, secured, and supported in such a manner that no pressure from the attached conductors will be exerted on a roof flashing, meter base, or other enclosures.
(3) Utilization of couplings for a mast is permitted only below the point the mast is braced, secured, or supported. There must be a minimum of two means of support above any couplings used. A properly installed cable or stiff leg type support qualifies as one of the two required means of support.
(4) Except as otherwise required by the serving utility, service mast support guys must be installed if the service drop attaches to the mast more than 24 inches above the roof line or if the service drop is greater than 100 feet in length from the pole or support. Masts for support of other than service drops must comply with this requirement as well.
(5) Intermediate support masts must be installed in an approved manner with methods identical or equal to those required for service masts.
(6) For altered services, where it is impractical to install U bolt mast supports due to interior walls remaining closed, it will be permissible to use other alternate mast support methods such as heavy gauge, galvanized, electrical channel material that is secured to two or more wooden studs with 5/16 inch diameter or larger galvanized lag bolts.
(7) Conductors must extend at least 18 inches from all mastheads to permit connection to the connecting overhead wiring.

040 Service conductors - Two-family and multiple-occupancy buildings.

(5) Two-family and multiple-occupancy buildings. A second or additional service drop or lateral to a building having more than one occupancy will be permitted to be installed at a location separate from other service drops or laterals to the building provided that all the following conditions are complied with:

- Each service drop or lateral must be sized in accordance with the NEC for the calculated load to be served by the conductors;
- Each service drop or lateral must terminate in listed metering/service equipment;
- Each occupant must have access to the occupant's service disconnecting means;
- No more than six service disconnects may be supplied from a single transformer;
- All service drops or laterals supplying a building must originate at the same transformer or power supply;
- A permanent identification plate must be placed at each service disconnect location that identifies all other service disconnect locations in or on the building, the area or units served by each, the total number of service disconnecting means on the building/structure and the area or units served. If a structure consists of multiple buildings (i.e., by virtue of fire separation), all service disconnects in or on the entire structure must be labeled to identify all service disconnects in or on the structure; and
- A permanent identification plate must be placed at each feeder disconnecting means identifying the area or units served if the feeder disconnecting means is remote from the area or unit served.

042 Service conductor - Size and rating.

(6) If the service conductors have a lesser ampacity than the overcurrent protection, permitted by NEC 230.90 or NEC 310.15, or the equipment rating that they terminate in or on, an identification plate showing the ampacity of the conductors must be installed on the service equipment.

043 Wiring methods for 1000 volts, nominal or less.

(7) The installation of service conductors not exceeding 1000 volts, nominal, within a building or structure is limited to the following methods: Galvanized or aluminum rigid metal conduit; galvanized intermediate metal conduit; wireways; busways; auxiliary gutters; minimum schedule 40 rigid polyvinyl chloride conduit; cablebus; or mineral-insulated, metal-sheathed cable (type MI).

- (8) Electrical metallic tubing must not be installed as the wiring method for service entrance conductors inside a building. Existing electrical metallic tubing, installed prior to October 1984, which is properly grounded and used for service entrance conductors may be permitted to remain if the conduit is installed in a nonaccessible location and is the proper size for the installed conductors.
- (9) In addition to methods allowed in the NEC, the grounded service conductor is permitted to be identified with a yellow jacket or with one or more yellow stripes.

070 Service equipment – Disconnecting means.

- (10) In addition to the requirements of NEC 230.70(A), service equipment, subpanels, and similar electrical equipment must be installed so that they are readily accessible and may not be installed in clothes closets, toilet rooms, or shower rooms. All indoor service equipment and subpanel equipment must have adequate working space and be adequately illuminated.
- (11) The service disconnecting means must be installed at a readily accessible location in accordance with (a) or (b) of this subsection.
 - (a) Outside location: Service disconnecting means will be permitted on the building or structure or within sight and within fifteen feet of the building or structure served. The building disconnecting means may supply only one building/structure. The service disconnecting means must have an identification plate with one-half-inch high letters identifying:
 - (i) The building/structure served; and
 - (ii) Its function as the building/structure main service disconnect(s).
 - (b) Inside location: When the service disconnecting means is installed inside the building or structure, it must be located so that the service raceway extends no more than fifteen feet inside the building/structure.

095 Ground-fault protection of equipment.

- (12) Equipment ground-fault protection systems required by the NEC must be tested prior to being placed into service to verify proper installation and operation of the system as determined by the manufacturer's published instructions. This test or a subsequent test must include all service voltage feeders unless the installer can demonstrate, in a manner acceptable to the department, that there are no grounded conductor connections to the feeder(s). A firm having qualified personnel and proper equipment must perform the tests required. A copy of the manufacturer's performance testing instructions and a written performance acceptance test record signed by the person performing the test must be available for the inspector at the time of inspection. The performance acceptance test record must include test details including, but not limited to, all trip settings and measurements taken during the test.

200 Wiring methods exceeding 1000 volts.

- (13) The installation of service conductors exceeding 1000 volts, nominal, within a building or structure must be limited to the following methods: Galvanized rigid metal conduit, galvanized intermediate metal conduit, schedule 80 polyvinyl chloride conduit, metal-clad cable that is exposed for its entire length, cablebus, or busways.
- (14) In addition to methods allowed in the NEC, the grounded service conductor is permitted to be identified with a yellow jacket or with one or more yellow stripes.

WAC 296-46B-240 Overcurrent Protection.

024(C) Not exposed to physical damage.

- (1) Where the NEC or manufacturer's instructions do not specify minimum height requirements for equipment enclosures, enclosures installed outdoors containing an overcurrent device(s) shall be installed so the bottom of the enclosure containing the overcurrent device(s) is not less than 24 inches above finished grade unless:
 - (a) The equipment enclosure or listed equipment on which the enclosure is mounted is approved for pad-, floor-, ground-, dock-, or pier-mounting; or
 - (b) The equipment enclosure is located over:
 - (i) Concrete or asphalt paving that extends 3 or more feet horizontally from the surface of the enclosure; or
 - (ii) Roofs

024(F) Not located over steps.

(2) If the overcurrent device is a part of a panelboard that is being repaired or replaced in an existing location, the installation is allowed to be made above the steps.

WAC 296-46B-250 Wiring and protection — Grounding and bonding.

028(D)(3) Separately derived system with more than one enclosure.

(1) NEC 250.28(D)(3) is amended to read: Where a separately derived system supplies more than a single enclosure, the system bonding jumper for each enclosure shall be sized in accordance with 250.28(D)(1) based on the largest ungrounded feeder/tap conductor serving that enclosure, or a single system bonding jumper shall be installed at the source and sized in accordance with 250.28(D)(1) based on the equivalent size of the largest supply conductor determined by the largest sum of the areas of the corresponding conductors of each set.

052 Grounding electrodes.

(2) Except for mobile/manufactured homes, a concrete encased grounding electrode must be installed and used at each new building or structure that is built upon a permanent concrete foundation. The electrode must comply with NEC 250.52(A)(3). Inspection of the electrode may be accomplished by the following methods:

- (a) At the time of inspection of other work on the project, providing the concrete encased electrode is accessible for a visual inspection;
- (b) At the time of the service inspection providing the installer has provided a method so the inspector can verify the continuity of the electrode conductor along its entire length, with a minimum 20 foot linear span between testing points (e.g., attaching a length of copper wire to one end of the electrode that reaches the location of the grounding electrode conductor that will enable the inspector to measure the resistance with a standard resistance tester). The concrete encased electrode does not have to be accessible for a visual inspection; or
- (c) Other method when prior approval, on a job site basis, is given by the inspector.
If a special inspection trip is required to inspect a grounding electrode conductor, a trip fee will be charged for that inspection in addition to the normal permit fee.

Exception:

If the concrete encased grounding electrode is not available for connection, a ground ring must be installed per NEC 250 or other grounding electrode installed per NEC 250 verified to measure 25 ohms or less to ground. Resistance verification testing must be performed by an independent firm having qualified personnel and proper equipment. A copy of the testing procedures used and a written resistance test record signed by the person performing the test must be available at the time of inspection. The resistance test record must include test details including, but not limited to, the type of test equipment used, the last calibration date of the test equipment, and all measurements taken during the test.

053(A)(2) Resistance of rod, pipe, and, plate electrodes

- (3) For rod, pipe, and plate electrodes, if a ground resistance test is not performed to ensure a resistance to ground of 25 ohms or less, two or more electrodes as specified in NEC 250.52 must be installed a minimum of 6 feet apart. A temporary construction service is not required to have more than one made electrode.
- (4) For services only, when multiple buildings or structures are located adjacent, but structurally separate from each other, any installed rod, pipe, or plate electrodes used for those services must be installed so that each building's or structure's electrodes are not less than 6 feet apart from the adjacent building's or structure's electrodes.

064 Grounding electrode conductor installation — Physical protection

(5) Grounding electrode conductors will be considered to be not exposed to physical damage when the conductor(s) are:

- (a) Buried more than 12 inches deep in the earth outside the building's footprint;
- (b) Encased or covered by 2 inches of concrete or asphalt;
- (c) Located inside the building footprint and protected by the building's structural elements or when inside and determined, by the inspector, to not be subject to physical damage; or

(d) Enclosed by a metal or nonmetallic raceway or enclosure. The raceway or enclosure must be approved to protect from severe physical damage if it is not protected by appropriate physical barriers from contact with vehicles, lawn mowers, and other equipment that might damage the conductor or enclosure.

068 Accessibility.

(6) The termination point of a grounding electrode conductor tap to the grounding electrode conductor must be accessible unless the connection is made using an exothermic or irreversible compression connection.

090 Bonding.

(7) Metallic stubs or valves used in nonmetallic plumbing systems are not required to be bonded to the electrical system unless required by an electrical equipment manufacturer's instructions.

(8) Hot and cold water plumbing lines are not required to be bonded together if, at the time of inspection, the inspector can determine the lines are mechanically and electrically joined by one or more metallic mixing valves.

104(B) Bonding – Other metal piping.

(9) For flexible metal gas piping, installed new or extended from an existing rigid metal piping system, either:

- (a) Provide a copy of the manufacturer's bonding instructions to the inspector at the time of inspection and follow those instructions; or
- (b) The bonding conductor for the gas system must:
 - (i) Be a minimum 6 AWG copper; and
 - (ii) Terminate at:
 - (A) An accessible location at the gas meter end of the gas piping system on either a solid iron gas pipe or a cast flexible gas piping fitting using a listed grounding connector; and
 - (B) Either the service equipment enclosure, service grounding electrode conductor or electrode, or neutral conductor bus in the service enclosure.

184 Solidly grounded neutral systems over 1000 volts.

(10) In addition to the requirements of NEC 250.184(A), the following applies for:

- (a) Existing installations.
 - (i) The use of a concentric shield will be allowed for use as a neutral conductor for extension, replacement, or repair, if all of the following are complied with:
 - (A) The existing system uses the concentric shield as a neutral conductor;
 - (B) Each individual conductor contains a separate concentric shield sized to no less than thirty-three and one-half percent of the ampacity of the phase conductor for three-phase systems or one hundred percent of the ampacity of the phase conductor for single-phase systems;
 - (C) The new or replacement cable's concentric shield is enclosed inside an outer insulating jacket; and
 - (D) Existing cable (i.e., existing cable installed directly in the circuit between the work and the circuit's overcurrent device) successfully passes the following tests:
 - A cable maintenance high potential dielectric test. The test must be performed in accordance with the cable manufacturer's instruction or the 2011 NETA maintenance test specifications; and
 - A resistance test of the cable shield. Resistance must be based on the type, size, and length of the conductor used as the cable shield using the conductor properties described in NEC Table 8 Conductor Properties.

An electrical engineer must provide a specific certification to the electrical plan review supervisor in writing that the test results of the maintenance high potential dielectric test and the resistance test have been reviewed by the electrical engineer and that the cable shield is appropriate for the installation. The electrical engineer must stamp the certification document with the engineer's stamp and signature. The document may be in the form of a letter or electrical plans.

Testing results are valid for a period of seven years from the date of testing. Cable will not be required to be tested at a shorter interval.

- (ii) A concentric shield used as a neutral conductor in a multigrounded system fulfills the requirements of an equipment grounding conductor.
- (b) New installations.
 - (i) New installations do not include extensions of existing circuits.
 - (ii) The use of the concentric shield will not be allowed for use as a neutral conductor for new installations. A listed separate neutral conductor meeting the requirements of NEC 250.184(A) must be installed.

WAC 296-46B-300 Wiring methods and materials — Wiring methods.

- (1) Cables and raceways for power limited, NEC Class 2 and Class 3 conductors must be installed in compliance with Chapter 3 NEC unless other methods are specifically required elsewhere in the NEC, chapter [19.28](#) RCW, or this chapter.

005 Underground installations.

- (2) Induction loops. See [WAC 296-46B-010](#)(18) for induction detection loops that are made in a public roadway and regulated by a governmental agency.

Other induction loops must comply with the following requirements:

- (a) General:
 - (i) A preformed direct burial induction loop is designed to be installed within the road surface base (e.g., concrete or asphalt) or below the road surface of a road with an unpaved surface (e.g., gravel or brick pavers);
 - (ii) A saw-cut induction detection loop is designed to be installed into a groove saw-cut into an existing paved road surface (e.g., concrete or asphalt);
 - (iii) The loop system includes the loop and the lead-in conductor;
 - (iv) The loop system must be:
 - (A) Tested to assure that at 500 volts DC, the resistance between the conductor and ground equals or exceeds 50 megohms; and
 - (B) Without splice; or
 - (C) If spliced, the splice must be soldered and appropriately insulated;
 - (v) The lead-in conductor must comply with the following:
 - (A) Must be stranded and have a lay (i.e., twist) of two turns per foot; and
 - (B) If installed in an electrical raceway;
 - Are not required to be listed or suitable for wet locations; and
 - Must have a burial cover of at least 6 inches; or
 - (C) If direct buried;
 - Must be listed for the use; and
 - Must have a burial cover of at least 18 inches.
- (b) Preformed direct burial induction detection loops must conform with the following:
 - (i) The loop conductor must be rated for direct burial and be a minimum of No. 16 AWG;
 - (ii) The loop design must not allow movement of the loop conductor within the outer jacket. The outer jacket containing the loop conductor is not required to be listed;
 - (iii) The loop yoke casing (i.e., the location where the lead-in conductor is connected to the loop):
 - (A) Includes any device used to house the "loop to lead-in splice" or to otherwise couple the loop with the lead-in electrical raceway;
 - (B) Is not required to be listed; and
 - (C) Must have a coupler that will create a waterproof bond with the electrical raceway, containing the lead-in conductor, or a direct buried lead-in conductor.
- (c) Saw-cut induction detection loops:
 - (i) The loop conductor must be cross-linked polyethylene or EPR Type USE insulation and be a minimum of No. 18 AWG stranded;
 - (ii) The saw-cut groove must not cut into rebar installed within the roadway.

011 Support of raceways, cables, or boxes in suspended ceilings.

- (3) NEC power limited, Class 2, and Class 3 cables must be secured in compliance with NEC 334.30 and must be secured to boxes in compliance with NEC 314.17.

- (4) Telecommunications cables must be secured in a manner that will not cause damage to the cables and at intervals not exceeding five feet. Cables are considered adequately supported when run through holes in building structural elements or other supporting elements. Telecommunications cables may be fished into inaccessible hollow spaces of finished buildings. Clamps or fittings are not required where telecommunications cables enter boxes.
- (5) Optical fiber cables must be secured in a manner that will not cause damage to the cables and at intervals not exceeding five feet. Cables are considered adequately supported when run through holes in building structural elements or other supporting elements. Optical fiber cables may be fished into inaccessible hollow spaces of finished buildings. Supports must allow a bending radius that will not cause damage to the cables.
- (6) Where not restricted by the building code official or Article 300 NEC, the wires required in NEC 300.11(B) may support raceways, cables, or boxes under the following conditions:
 - (a) Raceways and/or cables are not larger than three-quarter-inch trade size;
 - (b) No more than two raceways or cables are supported by a support wire. The two-cable limitation does not apply to telecommunications cables, Class 2 cables, or Class 3 cables on support wires installed exclusively for such cables. The support wire must be adequate to carry the cable(s) weight and all attached cables must be secured with approved fittings; or
 - (c) Raceways and cables are secured to the support wires by fittings designed and manufactured for the purpose.

In addition to (a), (b), and (c) of this subsection, the following conditions must be complied with:

- (d) The support wires are minimum #12 AWG and are securely fastened to the structural ceiling and to the ceiling grid system; and
- (e) The raceways or cables serve equipment that is located within the ceiling cavity or is mounted on or supported by the ceiling grid system. Telecommunications cables, Class 2 cables, or Class 3 cables supported as required by this section, may pass through ceiling cavities without serving equipment mounted on or supported by the ceiling grid system.

017 Conductors in raceway.

- (7) Cables will be permitted in all raceway systems if:
 - (a) The cable is appropriate for the environment; and
 - (b) The percentage fill does not exceed that allowed in NEC Chapter 9, Table 1.

WAC 296-46B-314 Wiring methods and materials — Outlet, device, pull, and junction boxes.

001 Boxes and fittings.

- (1) Conduit bodies, junction, pull, and outlet boxes must be installed so that the wiring contained in them is accessible without removing any part of the building structure, including insulation material.

023(H) Flexible cord connection of pendant boxes.

- (2) The flexible cord and cord connection must comply with NEC 314.23(H) and the following:
 - (a) A suspended pendant box must not contain conduit "knockouts" and connection to a suspended box must utilize an integral threaded hub;
 - (b) The maximum length of the cord for a suspended pendant drop from a permanently installed junction box to a suitable tension take-up device above the pendant box must not exceed 6 feet;
 - (c) The flexible cord must be supported at each end with an approved cord grip or strain relief connector fitting/device that will eliminate all stress on the conductor connections;
 - (d) The flexible cord must be a minimum #14 AWG copper;
 - (e) The flexible cord ampacity must be determined using NEC Table 400.5(A) column A; and
 - (f) The flexible cord must be hard or extra hard usage.

WAC 296-46B-334 Wiring methods and materials — Nonmetallic-sheathed cable.

010 Nonmetallic-sheathed cable.

- (1) The building classification, for subsections (2), (3), and (4) of this section, will be as determined by the building official. For the purposes of this section, Type III, IV and V may be as defined in the International Building Code adopted in the state of Washington. The installer must provide the inspector documentation substantiating the type of building construction and finish material rating(s) prior to any electrical inspection.
- (2) This section replaces NEC 334.10(2). In multifamily dwellings, Type NM, Type NMC, and Type NMS cable(s) may be used in structures of Types III, IV, and V construction except as prohibited in NEC 334.12.
- (3) This section replaces NEC 334.10(3). In all other structures, Type NM, Type NMC, and Type NMS cable(s) may be used in structures of Types III, IV, and V construction except as prohibited in NEC 334.12. All cable(s) must be concealed within walls, floors, or ceilings that provide a thermal barrier of material that has at least a 15-minute finish rating as identified in listings of fire-rated assemblies.
- (4) This section replaces NEC 334.10(4). Cable trays in structures of Types III, IV, and V construction, where the cable(s) is identified for the use, except as prohibited in NEC 334.12.

015 Exposed work.

- (5) Where Type NMC cable is installed in shallow chases in plaster, masonry, concrete, adobe or similar material, the cable must be protected against nails or screws by:
 - (a) A steel plate at least 1/16 inch thick and covered with plaster, adobe, or similar finish; or
 - (b) Being recessed in a chase at least 2 3/4 inches deep, as measured from the finished surface, and covered with plaster, adobe, or similar finish. The cable(s) must be at least 2 1/2 inches from the finished surface.
- (6) The requirements for nonmetallic sheathed cable protection in NEC 334.15(C) do not apply in crawl spaces.

WAC 296-46B-336 Power and Control Tray Cable – Type TC

010 Uses permitted

In addition to the uses allowed in NEC 336.10, Type TC cable may be used in any location allowed for nonmetallic-sheathed cable in NEC 334 if all the installation requirements in NEC 336 and 334 and WAC [296-46B-334](#) are met.

WAC 296-46B-358 Wiring methods and materials — Electrical metallic tubing.

012 Electrical metallic tubing.

- (1) In addition to complying with the provisions of Article 358 NEC, electrical metallic tubing may not be installed in direct contact with the earth or in concrete on or below grade. Also see NEC 300.6 for resistance to corrosion.
- (2) Where electrical metallic tubing is installed in wet locations, an equipment grounding conductor must be provided within the raceway and sized per NEC 250.122.

WAC 296-46B-394 Wiring methods and materials — Concealed knob-and-tube wiring.

001 Knob-and-tube wiring.

Article 394 NEC does not prohibit the installation of loose or rolled thermal insulating material in spaces containing existing knob-and-tube wiring provided that all the following conditions are met:

- (1) The wiring must be surveyed by an appropriately licensed electrical contractor who must certify in writing to the department that the wiring is in good condition with no evidence of improper overcurrent protection, conductor insulation failure or deterioration, and with no improper connections or splices. The electrical inspector must inspect all repairs, alterations, or extensions to the electrical system.

- (2) The insulation must meet Class I specifications as identified in the Uniform Building Code, with a flame spread factor of twenty-five or less as tested using ASTM E84-81a. Foam insulation may not be used with knob-and-tube wiring.
- (3) All knob-and-tube circuits must have overcurrent protection in compliance with NEC Table 310.15(B)(16), 60 degree centigrade, Column C. Overcurrent protection must be either circuit breakers or Type S fuses.

WAC 296-46B-406R Equipment for general use – Receptacles

012 Tamper-resistant receptacles.

In addition to the requirements of NEC 406.12, listed tamper-resistant receptacles are required in all psychiatric patient care facilities where accessible to psychiatric patients and children five years of age and under.

WAC 296-46B-410 Equipment for general use — Luminaires.

010 Luminaires.

- (1) All luminaires within an enclosed shower area or within five feet of the waterline of a bathtub must be enclosed, unless specifically listed for such use; these luminaires, with exposed metal parts that are grounded, must be ground fault circuit interrupter protected.

042 Exposed luminaire (fixture) parts.

- (2) Replacement luminaires that are directly wired or attached to boxes supplied by wiring methods that do not provide a ready means for grounding and that have exposed conductive parts will be permitted only where the luminaires are provided with ground-fault circuit-interrupter protection and marked "no equipment ground."

062 Flexible cord connection of electric discharge luminaires.

- (3) A ground-type attachment plug cap and receptacle connection at the source junction box is not required when the flexible cord complies with NEC 410.62 and the following:
 - (a) Connection to a source junction box must utilize an approved cable connector or clamp;
 - (b) The maximum length of the cord for a suspended pendant drop from a permanently installed junction box to a suitable tension take-up device above the pendant luminaire must not exceed 6 feet;
 - (c) The flexible cord must be supported at each end with an approved cord grip or strain relief connector fitting/device that will eliminate all stress on the conductor connections;
 - (d) The flexible cord must be a minimum #14 AWG copper;
 - (e) The flexible cord ampacity must be determined in NEC Table 400.5(A) column A;
 - (f) The flexible cord must be hard or extra hard usage; and
 - (g) A vertical flexible cord supplying electric discharge luminaires must be secured to the luminaire support as per NEC 334.30(A).

WAC 296-46B-422 Equipment for general use — Appliances.

010 Water heater circuit.

Water heaters with a rated circuit load in excess of 3,500 watts at 208 or 240 volts must be provided with branch circuit conductors not smaller than #10 AWG copper or equal. Overcurrent protection must comply with NEC 422.11(E).

WAC 296-46B-430 Motors, motor circuits, and controllers.

007 Marking on motors and multimotor equipment.

Except as required by the National Electrical Code, there is no requirement for motors to be identified for use or listed/field evaluated by a laboratory. All motors must be manufactured according to National Electrical Manufacturer's Association (NEMA) standards for motors except motors that:

- (1) Are a component part of equipment listed or field evaluated by a laboratory; or
- (2) Are a component part of industrial utilization equipment approved by the department per WAC [296-46B-903](#).

WAC 296-46B-440 Fixed electric space heating equipment.

014 Disconnecting means.


In one and two-family dwelling units, a disconnecting means is required for the indoor unit(s) of a split system HVAC/R system, unless the outside unit's disconnecting means is lockable, disconnects the indoor unit, and an indoor disconnecting means is not required by the manufacturer.

WAC 296-46B-450 Equipment for general use — Transformers and transformer vaults.

027 Flammable-liquid or oil-filled transformers installed outdoors.

(1) Flammable-liquid or oil-filled transformers installed outdoors must meet the following requirements:

- (a) A transformer installed adjacent to a building/structure with any combustible surface may be located only in the shaded "Approved Transformer Area" shown in Figure 450-1;



(b) A transformer installed adjacent to a building/structure with no combustible surface(s) may be located only in the shaded "Approved Transformer Area" shown in Figure 450-2;




Figure 450-2

- (c) In an area in which a transformer is to be installed next to a nonhabitable structure, the transformer may be no closer than 2 feet to the building/structure and must be outside a line extended vertically from the ends of the eaves or rooflines;
- (d) A building/structure may have no doors, windows, stairways, or other openings closer than 8 feet to the transformer;
- (e) The finished grade at the location of the transformer must be such that any oil leaking from the transformer will flow away from the building/structure and will not pool; and
- (f) If transformers are installed in areas subject to traffic other than pedestrian traffic, they must be provided with adequate guarding.

(2) Enclosures for total underground flammable-liquid or oil-filled transformers must not be located within 8 feet of a doorway, operable window, stairways or fire escape. Adequate space must be maintained above the enclosure so that a boom may be used to lift the transformer from the enclosure.

WAC 296-46B-500 Hazardous (Classified) Locations — Classes I, II, and III, Divisions 1 and 2.

005 Classification of Locations.

Classification of locations may only be done by the authority having jurisdiction or a professional engineer registered in Washington who uses appropriate National Fire Protection Standards as a basis for classification. The authority having jurisdiction is allowed to make the final determination in cases of conflict.

WAC 296-46B-501 Special occupancies — NEC Class I locations.

001 Sewage disposal systems.

- (1) Pumping chambers for sewage, effluent, or grinder pumps in on-site and septic tank effluent pump (S.T.E.P.) disposal systems will be considered unclassified when not more than five residential units are connected to the system, residential units are connected to a utility sewage system, or when nonresidential systems have residential loading characteristics and all of the following general installations requirements are complied with:
 - (a) The pumping chamber must be adequately vented. Venting may be accomplished through the building or structure plumbing vents where the system venting has been approved by the local jurisdiction authority or by a direct two-inch minimum vent to the atmosphere;
 - (b) Equipment that in normal operation may cause an arc or spark must not be installed in any pumping chamber;
 - (c) Float switches installed in a pumping chamber must be hermetically sealed to prevent the entrance of gases or vapors;
 - (d) Junction boxes, conduits and fittings installed in the septic atmosphere must be of a noncorrosive type, installed to prevent the entrance of gases or vapors;
 - (e) Where a conduit system is installed between the pumping chamber and the control panel, motor disconnect, or power source, an approved sealing method must be installed to prevent the migration of gases or vapors from the pumping chamber, and must remain accessible; and
 - (f) Wire splices in junction boxes installed in pumping chambers must be suitable for wet locations.
- (2) Residential wastewater loading characteristics in a nonresidential installation:
 - (a) For systems that process less than three thousand five hundred gallons of wastewater per day may be certified by:
 - (i) An on-site wastewater designer licensed under chapter [18.210](#) RCW; or
 - (ii) A professional engineer, engaged in the business of on-site wastewater system design, licensed under chapter [18.43](#) RCW.
 - (b) For systems that process three thousand five hundred gallons or more of wastewater per day may be certified by a professional engineer, engaged in the business of on-site wastewater system design, licensed under chapter [18.43](#) RCW.

Written documentation must be signed and stamped by the designer or engineer and provided to the electrical inspector prior to inspection.
- (3) Any residential or nonresidential system that has building or structure floor drains being discharged into the system is classified as Class I Division 1. Drains from any commercially made tub, shower, basin, sink, or toilet are not considered floor drains.
- (4) Pumping chamber access covers can be covered by gravel, light aggregate, or noncohesive granulated soil, and must be accessible for excavation. Access covers that are buried must have their exact location identified at the electrical panel or other prominent location by an identification plate. The authority having jurisdiction for performing electrical inspections must approve the identification plate location.
- (5) Indoor grinder pumps installed in chambers with less than fifty gallons capacity are not required to meet the requirements of this section, except for the venting requirements in subsection (1)(a) of this section. Indoor grinder pumps installed in chambers with less than fifty gallons capacity are not classified systems as described in Article 500 NEC.
- (6) Secondary treatment effluent pumping chambers such as sand filters are unclassified, and require no special wiring methods.
- (7) Inspection approval is required prior to covering or concealing any portion of the septic electrical system, including the pump. New septic and effluent tanks containing electrical wires and equipment must be inspected and approved prior to being loaded with sewage.

WAC 296-46B-505 Class I, Zone 0, 1, and 2 Locations.

007 Implementation of Zone Classification.

For the purposes of NEC 505.7, qualified person means a professional engineer registered in Washington.

WAC 296-46B-513 Special occupancies — Aircraft Hangars.

001 Scope.

The scope for NEC 513 applies only when the property containing the building is classified or zoned as an aircraft hangar by the Authority Having Jurisdiction.

WAC 296-46B-514 Special occupancies — Motor fuel dispensing facilities.

001 General.

- (1) In addition to the scope included in NEC 514.1, Article 514 NEC must be complied with for all liquefied flammable gas storage or transfer facilities.

003 Classifications of locations.

- (2) For the purposes of NEC 514.3(D)(2), delete Exception No. 1 and No. 2 and replace with:
Dock, pier, or wharf sections that do not support fuel dispensers and may abut a section(s) that supports a fuel dispenser(s) are permitted to be unclassified where documented air space between the sections is provided and where flammable liquids or vapors cannot travel to these sections. See NEC 500.4(A) for documentation requirements.

011 Emergency disconnecting means - Dispensing and service stations.

- (3) An emergency disconnecting means or operator must be provided to disconnect the pump or dispensing equipment serving gasoline, volatile flammable liquids, or liquefied flammable gases. The emergency disconnecting means or operator must disconnect all conductors of the circuit supplying all station dispensers and/or pumps (including the grounded conductor) simultaneously from the source(s) of supply.
- (4) For installations with only one dispensing device, the emergency disconnecting means/operator may be used to satisfy subsection (3) of this section.
- (5) For multicircuit installations, an electrically held normally open contactor operated by a push-button may serve as the disconnecting means to satisfy subsection (3) of this section. If a disconnecting pushbutton is used, the pushbutton may not function as the resetting mechanism for the electrically held contactor. The resetting means must be:
 - (a) Located at least 15 feet or out of sight from the disconnecting pushbutton;
 - (b) Installed behind a cover or guard; and
 - (c) Identified with an identification plate that is substantially black in color.
- (6) The disconnecting means satisfying subsection (3) of this section must be labeled with an identification plate, with letters at least 1 inch high, as the emergency disconnecting means. The disconnecting means or operator must be:
 - (a) Substantially red in color; and
 - (b) For attended facilities - Must be readily accessible and must be located outdoors and within sight of the pump or dispensing equipment it controls; or
 - (c) For unattended facilities - Must be readily accessible and must be located within sight, but at least 20 feet from the pump or dispensing equipment it controls.

WAC 296-46B-517 Special occupancies — Health care facilities.

001 Health care facilities.

In health care facilities, the following methods must be used to determine adequate capacity and ratings of equipment providing electrical power for the essential electrical systems defined in Article 517 NEC:

- (1) Systems in new facilities:
 - (a) Essential electrical system: The essential electrical system must consist of three branches known as:

- (i) Life safety branch: The feeder conductors and equipment used to supply electrical power to the life safety branch must be determined by summation of the connected loads as determined by Article 220 NEC and may not be subjected to any reduction due to the diversity of the loads. Feeder and equipment will be subject to a one hundred twenty-five percent multiplier for continuous loads in accordance with Article 220 NEC.
- (ii) Critical branch: The feeder conductors and equipment must be calculated in accordance with Article 220 NEC, including a level of diversity as determined by such article.
- (iii) Equipment branch: The feeder conductors and equipment used to supply electrical power to the equipment branch of the essential electrical system must be calculated in accordance with Article 220 NEC, including a level of diversity as determined by such article.

(b) Generator sizing: The rating of the generator(s) supplying electrical power to the essential system of a health care facility must meet or exceed the summation of the loads determined in (a) of this subsection with no additional demand factors applied. Momentary X-ray loads may be ignored if the generator is rated at least three hundred percent of the largest momentary X-ray load connected.

(2) Existing essential systems in facilities to which additional load is to be added:

- (a) Existing loads: The existing loads of the separate branches of the essential electrical system may be determined by WAC [296-46B-900](#)(3)(j).
- (b) Added loads: Added loads to the separate branches of the essential electrical system must be determined by subsection (1) of this section.
- (c) Generator sizing: The rating of the generator(s) supplying electrical power to the essential electrical system must meet or exceed the summation of the loads determined by (a) and (b) of this subsection with no additional demand factors applied.

013 Wiring methods.

(3) The last sentence of NEC 517.13(A) is modified to read: The metal raceway system, or metallic cable armor, or sheath assembly shall itself qualify as an equipment grounding conductor in accordance with 250.118 with the exception of 250.118(10)(a).

017 Ground-fault protection.

(4) The applicability of NEC 700.31 ground-fault protection of equipment, specified by NEC 517.26 for the life safety branch, will also apply to the NEC 517 essential electrical system's critical branch(es) and equipment branch(es).

WAC 296-46B-547 Special occupancies — Agricultural buildings.

001 Scope.

NEC 547 requirements apply only when the agricultural building is greater than 1,000 square feet and is used as part of a business or commercial farming activity.

WAC 296-46B-550 Special occupancies — Mobile homes, manufactured homes, and mobile home parks.

001 Mobile/manufactured homes - inspection.

(1) All alterations to the mobile/manufactured home electrical system must be permitted and inspected.

- (a) Any circuit or feeder that is fed from the pedestal or panel from an outbuilding feeding the mobile/manufactured home requires a permit from the electrical section.
- (b) Any circuit or feeder that originates from the mobile/manufactured home's (i.e. red Factory Assembled Structures label) panel and feeds an addition or equipment that is attached (e.g. garage, heat pump or air conditioning unit) requires an FAS alteration permit.
- (c) Any circuit or feeder that originates in the mobile/manufactured home panel and feeds an unattached structure or equipment (e.g. detached garage, hot tub, pool, well, septic system, yard lighting or generation equipment, etc.) requires two inspections. An FAS permit is required for the circuit or feeder from the panel and must terminate in a J-box located under the home's exterior wall near the rim joist.

A second permit is required from the electrical section for electrical work from the J-box to the equipment or structure.

032 Mobile/manufactured homes - service.

- (2) If an electrical service is installed on the mobile/manufactured home:
 - (a) It must be installed only by the manufacturer, at the manufacturing plant. The manufacturer must complete the service except for service connections, meter, and grounding electrode conductor; and
 - (b) The owner or an electrical contractor must complete the service at the site.

033 Mobile/manufactured homes - feeder.

- (3) When the mobile or manufactured home is supplied with power using a permanent wiring method, the equipment grounding conductor will be permitted to be bare. Bare conductors used underground must be copper. For the purposes of this section, portable cord is not considered a permanent wiring method.

WAC 296-46B-553 Special occupancies — Floating buildings.

004 Floating buildings and similar facilities – Services and feeders.

- (1) Where electrical power is provided, floating buildings and similar facilities in addition to complying with the appropriate sections of Article 553 NEC must have a readily accessible service rated disconnect located on the shoreline within sight of the shoreline connection of the dock, wharf or similar structure to which the floating building or similar facility is moored.
- (2) Where shore power is provided, each floating building or similar facility must have a disconnecting means located within sight of each floating building or similar facility. The disconnecting means must be installed adjacent to but not in or on the floating building or similar facility.
- (3) The second sentence of NEC 553.4 is amended to read: The overcurrent protective devices that supply the floating building shall have ground-fault protection not exceeding 30 mA. Until July 1, 2018, the ground-fault protection level specified in this subsection is amended to allow a maximum of: 100 mA for overcurrent devices supplying feeder conductors; and 30 mA for overcurrent devices supplying branch circuit conductors and outlets.

The third sentence of NEC 553.4 is not adopted.

007 Floating buildings and similar installations - Wiring methods.

- (4) Extra-hard usage portable power cables rated not less than 75°C, 600 volts, listed for wet locations and sunlight resistance and having an outer jacket rated for the environment may be used as a permanent wiring method when joining the structures indicated above and for any concealed or protected wiring on a sectionalized floating dock leading to a floating building or similar facility. The cable needs to be resistant only to environments it is normally exposed to on an ongoing basis.
- (5) Conductors operating in excess of 600 volts, nominal may not be installed on floating portions of a floating building or similar facility.

WAC 296-46B-555 Special occupancies — Marinas, boatyards, and commercial and noncommercial docking facilities.

- (1) Until July 1, 2018, the ground-fault protection level specified in 2017 NEC 555.3 is amended to allow a maximum of: 100 mA for overcurrent devices supplying feeder conductors; and 30 mA for overcurrent devices supplying branch circuit conductors and outlets.
- (2) For the purposes of NEC 555.5, transformer terminations must be located a minimum of 12 inches above the deck of a dock (datum plane requirements do not apply for this section).
- (3) For the purposes of NEC 555.7, adjacent means within sight.

- (4) For the purposes of NEC 555.9, all electrical connections must be installed a minimum of 12 inches above the deck of a pier unless the connections are approved for wet locations (datum plane requirements do not apply for this section).
- (5) For the purposes of NEC 555.10, all enclosures must be corrosion resistant. All gasketed enclosures must be arranged with a weep hole to discharge condensation.
- (6) For the purposes of NEC 555.11, gasketed enclosures are only required for wet locations.
- (7) For the purposes of NEC 555.13, the following wiring methods are allowed:
 - (a) All wiring installed in a damp or wet location must be suitable for wet locations.
 - (b) Extra-hard usage portable power cables rated not less than 75°C, 600 volts, listed for wet locations and sunlight resistance and having an outer jacket rated for the environment are permitted. Portable power cables are permitted as a permanent wiring method under or within docks and piers or where provided with physical protection. The requirements of NEC 555.13 (B)(4)(b) do not apply.
 - (c) Overhead wiring must be installed at the perimeter of areas where boats are moored, stored, moved, or serviced to avoid possible contact with masts and other parts of boats.
 - (d) For the purposes of NEC 555.13 (B)(5), the wiring methods of Chapter 3 NEC will be permitted.
- (8) For the purposes of NEC 555.19, receptacles must be mounted not less than 12 inches above the deck surface of the pier or dock (datum plane requirements do not apply for this section). Shore power receptacles that provide shore power for boats must be rated not less than 20 amperes and must be single outlet type and must be of the locking and grounding type or pin and sleeve type.

WAC 296-46B-590 Special occupancies — Temporary installations.

001 Temporary installations.

- (1) For the purposes of this section, any circuit used for construction purposes is considered to be temporary.

003 Temporary installations – time constraints

- (2) Temporary construction service equipment may only be used for construction purposes and must be disconnected when the permanent service is connected unless the department grants an extension of time.

004 Temporary installations - splices.

- (3) A splice or junction box is required for all wiring splice or junction connections in a temporary installation.

WAC 296-46B-600 Special equipment — Electric signs and outline lighting.

001 Electrical signs - General.

- (1) All electrical signs and outline lighting, regardless of voltage, must be listed to the applicable ANSI UL Standard. Installations will be inspected for compliance with installation instructions and the NEC.
- (2) Luminaires in outdoor awnings must be suitable for wet locations and be connected by a wiring method suitable for wet locations.
- (3) Fluorescent luminaires must be located at least 6 inches from the awning fabric. Incandescent lamps or luminaires must be located at least 18 inches from the awning fabric. A disconnecting means must be installed per Article 600 NEC.
- (4) Listed awning signs must be installed in compliance with the manufacturer's instructions and the NEC.
- (5) Retrofitting signs. When listed signs or listed outline lighting are retrofitted to an LED light source, a licensed (01) general electrical contractor or (04) sign contractor using properly certified individuals or properly supervised trainees may make the retrofit in place so long as all the retrofit components and retrofit kit are listed and installation instructions applicable to the sign for making the retrofit are available for the inspector's use at the time of the inspection and physical access is provided to allow the inspector access to all components of the retrofit kit.

004 Markings.

(6) In addition to the markings required by the NEC, retrofit signs and outline lighting shall be marked with a label, made of a background color contrasting to the listed product, in a location visible during servicing near the listed retrofit subassembly that states, "This equipment contains a retrofit subassembly that may present a risk of electrical hazard. Replace parts only with same type and rating." The label's font must be Arial size 16 bold. This label may be an identification plate as described in WAC 296-46B-100 or an adhesive label approved by the electrical inspector. This label is in addition to any labeling required by the manufacturer's instructions or the UL Standard used to manufacture the retrofit kit.

007 Grounding and bonding.

(7) Remote metal parts of a section sign or outline lighting system only supplied by a remote Class 2 power supply that is listed or is a recognized component in a listed section sign or outline lighting is not required to be bonded to an equipment grounding conductor.

010 Portable or mobile outdoor electrical signs.

(8) A GFCI receptacle outlet that is weatherproof with the supply cord connected must be installed within 6 feet of each portable or mobile electrical sign.
(9) Extension cords are not permitted to supply portable outdoor signs.
(10) All portable outdoor electrical signs must be listed by a qualified electrical testing laboratory accredited by the department.

030 Neon tubing.

(11) NEC 600, Part II, Field-Installed Skeleton Tubing, will apply to the installation of all neon tubing and neon circuit conductors.
(12) Field-installed skeleton tubing is not required to be listed. Installations will be inspected for compliance with installation instructions and the NEC.

WAC 296-46B-680 Special equipment — Swimming pools, fountains, and similar installations.

001 General.

(1) Package spa or hot tubs. Electrical heating, pumping, filtering, and/or control equipment installed within 5 feet of a spa or hot tub must be listed or field evaluated as a package with the spa or hot tub.
(2) A factory assembled skid pack of electrical heating, pumping, filtering, and/or control equipment must be installed more than 5 feet from a spa or hot tub and must be listed as a package unit.
(3) The maintenance disconnect and field installed, listed electrical equipment for a hot tub, spa, or swim spa must be located at least five feet from the hot tub, spa or swim spa. Field installed listed equipment must meet the following additional requirements:
 (a) The heater is listed as a "spa heater or swimming pool heater";
 (b) The pump is listed as a "spa pump" or "swimming pool/spa pump" (the pump may be combined with a filter assembly); and
 (c) Other listed equipment such as panelboards, conduit, and wire are suitable for the environment and comply with the applicable codes.
(4) Field installed, listed electrical equipment for a swimming pool must be located at least 5 feet from the swimming pool. Field installed listed equipment must meet the following additional requirements:
 (a) The heater must be listed as a "swimming pool heater or a spa heater";
 (b) The pump must be listed as a "swimming pool pump" or "spa pump" or "swimming pool/spa pump"; and
 (c) Other equipment such as panelboards, conduit, and wire must be suitable for the environment and comply with the applicable codes.
 The 5 foot separation may be reduced by the installation of a permanent barrier, such as a solid wall, fixed glass windows or doors, etc. The 5 foot separation will be determined by the shortest path or route that a cord can travel from the spa, hot tub, swim spa, or swimming pool to an object.
(5) The field assembly or installation of "recognized components" will not be permitted.

- (6) Hydromassage bathtubs must be listed as a unit and bear a listing mark which reads "hydromassage bathtub."
- (7) Manufacturers' instructions must be followed as part of the listing requirements.
- (8) Electrical components which have failed and require replacement must be replaced with identical products unless the replacement part is no longer available; in which case, a like-in-kind product may be substituted provided the mechanical and grounding integrity of the equipment is maintained.
- (9) Cut-away-type display models may not be sold for other than display purposes and are not expected to bear a listing mark.

040 Spas and hot tubs.

- (10) NEC 680.42(C) will apply for interior and exterior wiring to outdoor installations of spas and hot tubs.

070 Hydromassage bathtubs.

- (11) For hydromassage bathtubs, the ground fault circuit interrupter device must be identified as to use and not located in a building or tub cavity, crawlspace, or attic.
- (12) For hydromassage bathtubs, all electrical equipment installed to support the bathtub (e.g. disconnecting means, motor, etc.) must be accessible at the same grade level as the tub or from a landing on the exterior of the building without the use of a ladder or other access device.

WAC 296-46B-690 Solar Photovoltaic Systems.

002 Definitions.

- (1) Building integrated: means photovoltaic cells. Modules, panels, or arrays that are integrated into the outer surface or structure of a building and serve as the outer protective surface of that building, such as the roof, skylights, windows, or facades.

004 Installation.

- (2) Support structure or foundation. For the purposes of this section those portions of the structural support or foundation that are exclusively mechanical and are not a part of a bonding or grounding path will not be considered part of the photovoltaic system as defined by this section. Such structural support or foundation may be done by the owner, registered general contractor, or licensed electrical contractor without electrical permit or inspection.
- (3) A photovoltaic system design review must be available at the time of the first inspection.
- (4) The entity placing a building integrated cell, module, panel, or array is not subject to the requirements for electrical inspection, licensing, or certification so long as the work is limited to the placement and securing of the device and an electrical work permit has been previously obtained for the electrical work related to the equipment by an entity authorized to do that electrical work.
- (5) All electrical work, including wiring installation, terminations, etc. necessary to complete the electrical installations must be completed by the entity authorized to do the electrical work (i.e. owner or appropriate electrical contractor).

007 Maximum voltage.

- (6) The open-circuit voltage temperature coefficients supplied in the instructions of listed photovoltaic modules will be used to determine the maximum direct current photovoltaic system voltage. Otherwise the voltage will be calculated using Table 690.7 of the NEC. For the purposes of this calculation, a temperature correction factor of 1.25 will be used unless another factor can be justified and is approved by the authority having jurisdiction.

053 Direct-current photovoltaic power source.

- (7) All photovoltaic equipment and disconnecting means must be permanently identified as to their purpose, maximum voltages, and type of current within the system with an identification plate. All photovoltaic circuits must be identified at each overcurrent protection device(s) and panel directory(ies).

WAC 296-46B-694 Wind electric systems.

A wind driven generator system design review must be available at the time of the first inspection.

WAC 296-46B-700 Emergency systems.

001 Emergency systems - General.

(1) In all health or personal care facilities defined in this chapter, educational facilities, institutional facilities, hotels, motels, and places of assembly for one hundred or more persons, all exit and emergency lights must be installed in accordance with Article 700 NEC and located as required in standards adopted by the state building code council under chapter [19.27](#) RCW.

007 Signs.

(2) The sign(s) required in NEC 700.7 must be placed at the service disconnecting means and the meter base if the service disconnecting means and meter base are not located within sight and within 5 feet of each other.

009 Emergency systems - Equipment identification.

(3) All exit and emergency lights, whether or not required by the NEC, must be installed in accordance with Article 700 NEC.

(4) All boxes and enclosures, for Article 700 NEC systems, larger than 6 inches by 6 inches, including transfer switches, generators, and power panels for emergency systems and circuits must be permanently identified with an identification plate that is substantially orange in color, except in existing health care facilities the existing nameplate identification color scheme can be retained for transfer switches, generators, and power panels for existing emergency systems that are not being replaced or modified. All other device and junction boxes for emergency systems and circuits must be substantially orange in color, both inside and outside.

032 Coordination.

(5) The requirements for selective coordination described in NEC 700.32 are not required where the emergency system was installed prior to June 1, 2006. For new emergency systems that are supplied from an existing emergency system installed prior to June 1, 2006, the new portion of the emergency system must comply with NEC 700.32. The ground fault sensing function of overcurrent protective devices will only be required to selectively coordinate with the ground fault sensing functions of other overcurrent protective devices.

WAC 296-46B-701 Legally required standby systems.

007 Signs.

(1) The sign(s) required in NEC 701.7 must be placed at the service disconnecting means and the meter base if the service disconnecting means and meter base are not located within sight and within 5 feet of each other.

027 Coordination.

(2) The requirements for selective coordination described in NEC 701.27 are not required where the legally required standby system was installed prior to June 1, 2006. For new legally required standby systems that are supplied from an existing legally required standby system installed prior to June 1, 2006, the new portion of the legally required standby system must comply with NEC 701.27. The ground fault sensing function of overcurrent protective devices will only be required to selectively coordinate with the ground fault sensing functions of other overcurrent protective devices.

WAC 296-46B-702 Optional standby systems.

007 Signs.

The sign(s) required in NEC 702.7 must be placed at the service disconnecting means and the meter base if the service disconnecting means and meter base are not located within sight and within 5 feet of each other.

WAC 296-46B-705 Interconnected electric power production sources.

(1) For utility interactive systems, any person making interconnections between a power production source and the utility distribution network must consult the serving utility and is required to meet all additional utility standards.

031 Location of overcurrent protection.

(2) In addition to the requirements of NEC 705.31, electric power production source conductors connected to the supply side of the service disconnecting means must be installed using wiring methods specified for service conductors in WAC 296-46B-230(7).

WAC 296-46B 760 Fire alarm systems.

Device and junction boxes for fire alarm systems other than the surface raceway type, must be substantially red in color, both inside and outside. Power-limited fire protective signaling circuit conductors must be durably and plainly marked in or on junction boxes or other enclosures to indicate that it is a power-limited fire protective signaling circuit.

WAC 296-46B 800 Communications systems — Communications circuits.

General.

Chapters 1 through 7, NEC, supplement and modify the requirements of Chapters 8, NEC. If there are specific requirements or exceptions described in Chapter 8, NEC, that are different from those in Chapters 1 through 7, NEC, Chapter 8 will prevail.

001 Installation.

- (1) All telecommunications installations on an end-user's property, beyond the end-user's telecommunications network demarcation point, made by a telecommunications service provider, both inside and outside of a building or structure, must conform to all licensing, certification, installation, permitting, and inspection requirements described in chapter [19.28](#) RCW and this chapter.
- (2) Telecommunications service providers including its subcontractors and agents must install and maintain points of demarcation in conformance with Code of Federal Regulations (CFR), Title 47, Chapter 1, Part 68, Subpart B, Sec. 68.105 and may not place a point of demarcation further than 12 inches within an end-user's occupied space.
- (3) The telecommunications service provider must identify the telecommunications network demarcation point(s) with an identification plate or label having:
 - (a) The provider's name;
 - (b) Customer/end user's name; and
 - (c) If a CWSTP is used, the option type used.
- (4) The CFR prescribes that telecommunications service providers must choose either a MPOE (Minimum Point of Entry) or CWSTP (Cable Wire Service Termination Policy) which regulates where demarcations are placed within a multi-tenant environment.
- (5) A Telecommunications service provider, including its subcontractors and agents provisioning service for a second provider who is not the end-user of the service, must place the point of demarcation no further than 12 inches from the nearest POP (Point of Presence), of the serving provider, to the eventual end-user.

(6) Telecommunications service providers must designate each building that they provide services to with labeling at the terminating point(s) of their facilities indicating:

- Whether the building is under a MPOE policy; or
- Which option of a CWSTP is in effect.

(7) The CWSTP options for demarcation placement are as follows:

- All telecommunications service provider facilities will terminate at one location, mutually agreed upon by the provider and the building owner or designee, upon entry into the building, normally at the lowest common serving point. All demarcations will be placed no more than 12 inches from this point. The building owner and/or tenants will provide, manage and maintain building wire and cable placed beyond this demarcation point location.
- The telecommunications service provider's facilities will terminate at common locations, mutually agreed upon by the provider and the building owner or designee, throughout the building (terminal rooms, utility closets, etc.). The telecommunications service provider will provide, manage and maintain the building cable and registration jacks that denote the demarcation points. The demarcation points will be placed at these locations and will be accessible to end users at these locations. Option (ii) is not an option for single tenant buildings.
- The telecommunications service provider will terminate facilities and place demarcations at locations, mutually agreed upon by the provider and the building owner or designee, within the individually occupied units, within 12 inches or a similarly reasonable distance of cable/wire entry. The provider will provide, manage and maintain the building cable, network terminating wire and registration jacks that denote the demarcation point. Option (iii) is not an option for single tenant buildings.
- All telecommunications service provider facilities and demarcations will terminate at one location on the property, mutually agreed upon by the provider and the building owner or designee. The building owner and/or tenants will provide, manage and maintain building wire and cable placed beyond the demarcation point location.

(8) The telecommunications installer must confer with the telecommunications provider when determining the point of demarcation.

002 Definitions.

(9) "CWSTP (Cable, Wire and Service Termination Policy)" is the policy of the Federal Communications Commission (FCC) and the Washington Utilities and Transportation Commission (WUTC) prescribed by tariff that governs negotiations between building owners and telecommunications service providers regarding the configuration of POP(s) and demarcation point(s) in multi-tenant buildings when a MPOE policy is not elected by the telecommunications service provider.

(10) "MPOE (Minimum Point of Entry)" is a building wiring policy of the FCC and WUTC for multitenant environment locations that can be elected by telecommunications service providers. It prescribes that the telecommunications service provider will provide a single POP for access to its network and is located either at the closest practicable point to where a telecommunications service provider's facilities (fiber, coax, or copper) crosses a property line or at the closest practicable point to where the wiring enters a multiunit building or buildings. All demarcations provided for customers and end-users by the provider will be placed within 12 inches of that POP.

(11) "POP (Point-of-Presence)", also called a "POT (Point-of-Termination)", is a designated point at or near a customer premise at which a telecommunications service provider's facilities for the provision of access service ends. This can be a fiber, coax, or copper connection point. Depending on the telecommunications service provider's CWSTP with the individual building owner demarcations may be established at the POP or at other designated locations. When the customer of a telecommunications service provider is another carrier, the demarcation will be at the closest POP to the end-user. A telecommunications service provider may have multiple POPs within a multiple tenant environment.

Part B – Electrical Plan Review.

WAC 296-46B-900 Electrical plan review.

Definition of occupancies.

(1) Occupancies are defined as follows:

- (a) Educational facility refers to a building or portion of a building used primarily for educational purposes by six or more persons at one time for twelve hours per week or four hours in any one day. Educational occupancy includes: Schools (preschool through grade twelve), colleges, academies, universities, and trade schools.
- (b) Institutional facility refers to a building or portion of a building used primarily for detention or correctional occupancies where some degree of restraint or security is required for a time period of twenty-four or more hours. Such occupancies include, but are not restricted to: Penal institutions, reformatories, jails, detention centers, correctional centers, and residential-restrained care.
- (c) Health or personal care facility. Health or personal care facility refers to buildings or parts of buildings that contain, but are not limited to, facilities that are required to be licensed by the department of social and health services or the department of health (e.g., hospitals, nursing homes, private alcoholism hospitals, private psychiatric hospitals, boarding homes, alcoholism treatment facilities, maternity homes, birth centers or childbirth centers, residential treatment facilities for psychiatrically impaired children and youths, and renal hemodialysis clinics) and medical, dental, or chiropractic offices or clinics, outpatient or ambulatory surgical clinics, and such other health care occupancies where patients who may be unable to provide for their own needs and safety without the assistance of another person are treated.
 - (i) "Hospital" means any institution, place, building, or agency providing accommodations, facilities, and services over a continuous period of twenty-four hours or more, for observation, diagnosis, or care of two or more individuals not related to the operator who are suffering from illness, injury, deformity, abnormality, or from any other condition for which obstetrical, medical, or surgical services would be appropriate for care or diagnosis.
 - (ii) "Nursing home," "nursing home unit" or "long-term care unit" means a group of beds for the accommodation of patients who, because of chronic illness or physical infirmities, require skilled nursing care and related medical services but are not acutely ill and not in need of the highly technical or specialized services ordinarily a part of hospital care.
 - (iii) "Boarding home" means any home or other institution, however named, which is advertised, announced, or maintained for the express or implied purpose of providing board and domiciliary care to seven or more aged persons not related by blood or marriage to the operator. It must not include any home, institution, or section thereof which is otherwise licensed and regulated under the provisions of state law providing specifically for the licensing and regulation of such home, institution, or section thereof.
 - (iv) "Enhanced service facility" (ESF) means a facility, or a portion of a facility, that provides treatment and services to persons for whom acute inpatient treatment is not medically necessary and who have been determined by the department to be inappropriate for placement in other licensed facilities due to the complex needs that result in behavioral and security issues. For the purposes of this chapter, an enhanced services facility is not an evaluation and treatment facility certified under chapter 71.05 RCW.
 - (v) "Private alcoholism hospital" means an institution, facility, building, or equivalent designed, organized, maintained, or operated to provide diagnosis, treatment, and care of individuals demonstrating signs or symptoms of alcoholism, including the complications of associated substance use and other medical diseases that can be appropriately treated and cared for in the facility and providing accommodations, medical services, or other necessary services over a continuous period of twenty-four hours or more for two or more individuals unrelated to the operator, provided that this chapter will not apply to any facility, agency, or other entity which is owned and operated by a public or governmental body.
 - (vi) "Private psychiatric hospital" means a privately owned and operated establishment or institution which: Provides accommodations and services over a continuous period of twenty-four hours or more, and is expressly and exclusively for observing, diagnosing, or caring for two or more individuals with signs or symptoms of mental illness who are not related to the licensee.
 - (vii) "Maternity home" means any home, place, hospital, or institution in which facilities are maintained for the care of four or more women, not related by blood or marriage to the

operator, during pregnancy or during or within ten days after delivery: Provided, however, that this definition will not apply to any hospital approved by the American College of Surgeons, American Osteopathic Association, or its successor.

- (viii) "Birth center" or "childbirth center" means a type of maternity home which is a house, building, or equivalent organized to provide facilities and staff to support a birth service provided that the birth service is limited to low-risk maternal clients during the intrapartum period.
- (ix) "Ambulatory surgical facility" means a facility, not a part of a hospital, providing surgical treatment to patients not requiring inpatient care in a hospital.
- (x) "Hospice care center" means any building, facility, place, or equivalent, organized, maintained, or operated specifically to provide beds, accommodations, facilities, or services over a continuous period of twenty-four hours or more for palliative care of two or more individuals, not related to the operator, who are diagnosed as being in the latter stages of an advanced disease which is expected to lead to death.
- (xi) "Renal hemodialysis clinic" means a facility in a building or part of a building which is approved to furnish the full spectrum of diagnostic, therapeutic, or rehabilitative services required for the care of renal dialysis patients (including inpatient dialysis furnished directly or under arrangement). (NEC: Ambulatory Health Care Occupancy.)
- (xii) "Medical, dental, and chiropractic clinic" means any clinic or physicians' office where patients are not regularly kept as bed patients for twenty-four hours or more. Electrical plan review is not required.
- (xiii) "Residential treatment facility" means a facility licensed and operated 24 hours per day to provide health care to persons receiving services for a mental disorder or substance abuse.
- (xiv) "Group care facility" means a facility other than a foster-family home maintained or operated for the care of a group of children on a twenty-four-hour basis.

Plan review for educational, institutional, or health care facilities/buildings.

- (2) Plan review is a part of the electrical inspection process; its primary purpose is to determine:
 - (a) That service/feeder conductors are calculated and sized according to the proper NEC or WAC article or section;
 - (b) The classification of hazardous locations; and
 - (c) The proper design of emergency and standby systems.
- (3) Electrical plan review.
 - (a) Electrical plan review is not required for:
 - (i) Low voltage systems;
 - (ii) Lighting specific projects that result in an electrical load reduction on each feeder involved in the project;
 - (iii) Heating and cooling specific retrofit projects that result in an electrical load reduction on each existing feeder involved in the project, provided there is not a corresponding increase in the available fault current in any feeder.
 - (iv) Stand-alone utility fed services that do not exceed 250 volts, 400 amperes where the project's distribution system does not include:
 - (A) Emergency systems other than listed unit equipment per NEC 700.12(F);
 - (B) An essential electrical system defined in NEC 517.2; or
 - (C) A required fire pump system.
 - (v) Modifications to existing electrical installations where all of the following conditions are met:
 - (A) Service or distribution equipment involved is rated not more than 400 amperes and does not exceed 250 volts or for lighting circuits not exceeding 277 volts to ground;
 - (B) Does not involve emergency systems other than listed unit equipment per NEC 700.12(F);
 - (C) Does not involve branch circuits or feeders of an essential electrical system as defined in NEC 517.2; and
 - (D) Service or feeder load calculations are increased by 5% or less.
 - (vi) Electric power production source(s) such as solar photovoltaic, fuel cell, or wind electric system(s) with a total rating of 9600 watts or less.
 - (vii) For installations in (a)(ii), (iii), and (v) of this subsection to be considered, the following must be available to the electrical inspector before the work is initiated:
 - (A) A clear and adequate description of the project's scope;
 - (B) A load calculation(s);
 - (C) What the load changes are, providing both before and after panel schedules as needed; and

- (D) Provide information showing that the service and feeder(s) supplying the panel(s) where the work is taking place has adequate capacity for any increased load and has code compliant overcurrent protection for that supply.
- (b) Electrical plan review is required for all other new or altered electrical projects in educational, institutional, or health care occupancies defined in this chapter.
- (c) If a review is required, the electrical plan must be submitted for review and approval before the electrical work is begun.
- (d) Electrical plans.
 - (i) The plan must be submitted for plan review prior to beginning any electrical inspection. If a plan is rejected during the plan review process, no electrical inspection(s) may proceed until the plan is resubmitted and a conditional acceptance is granted.
 - (ii) The submitted plan will receive a preliminary review within seven business days after receipt by the department or city authorized to do electrical inspections.
 - (iii) If the submitted plan:
 - (A) Is rejected at the preliminary review, no inspection(s) will be made on the project.
 - (B) Receives conditional acceptance, the permit holder may request a preliminary inspection(s) in writing to the department or city authorized to do electrical inspections. The request must note that the preliminary inspection(s) is conditional and subject to any alterations required from the final plan review process.
 - (iv) Once the submitted plan has preliminary plan review approval, a copy of the submitted plan must be available on the job site for use by the electrical inspector.
 - (v) The final approved plan must be available on the job site, for use by the electrical inspector, after it is approved, but no later than prior to the final electrical inspection.
 - (vi) If the final approved plan requires changes from the conditionally accepted plan, alterations to the project may be required to make the project comply with the approved plan.
 - (vii) If the installer deviates from the service/feeder design shown on the final approved plan, a supplemental plan must be submitted for review before inspection can proceed. Load reductions or moving branch circuit locations within a panelboard do not require resubmission.
- (e) All electrical plans for educational facilities, hospitals, and nursing homes must be prepared by, or under the direction of, a consulting engineer registered under chapter [18.43](#) RCW, and chapters [246-320](#), [180-29](#), and [388-97](#) WAC and stamped with the engineer's mark and signature.
- (f) Refer plans for review to the Electrical Section, Department of Labor and Industries, P.O. Box 44460, Olympia, Washington 98504-4460 or the city authorized to do electrical inspections.
- (g) Plans for projects within cities that perform electrical inspections must be submitted to that city for review.
- (h) Plans to be reviewed must be legible, identify the name and classification of the facility, clearly indicate the scope and nature of the installation and the person or firm responsible for the electrical plans. The plans must clearly show the electrical installation or alteration in floor plan view, include all switchboard and panelboard schedules and when a service or feeder is to be installed or altered, must include a riser diagram, load calculation, fault current calculation, and interrupting rating of equipment. Where existing electrical systems are to supply additional loads, the plans must include documentation that proves adequate capacity and ratings. The plans must be submitted with a plan review submittal form available from the department or city authorized to do electrical inspections. Fees must be calculated based on the date the plans are received by the department or city authorized to do electrical inspections.
 - (i) The department may perform the plan review for new or altered electrical installations of other types of construction when the owner or electrical contractor makes a voluntary request for review. A city authorized to do electrical inspections may require a plan review of any electrical system.
 - (j) For existing structures where additions or alterations to feeders and services are proposed, NEC 220.87(1) may be used. If NEC 220.87(1) is used, the following is required:
 - (i) The date of the measurements.
 - (ii) A statement attesting to the validity of the demand data, signed by a professional electrical engineer or the electrical administrator of the electrical contractor performing the work.
 - (iii) A diagram of the electrical system identifying the point(s) of measurement.
 - (iv) Building demand measured continuously on the highest-loaded phase of the feeder or service over a thirty-day period, with the demand peak clearly identified. Demand peak is defined as the maximum average demand over a fifteen-minute interval.

Notes to Tables 900-1 and 900-2.

1. A city authorized to do electrical inspections may require plan review on facility types not reviewed by the department.

Table 900-1 Health or Personal Care Facilities

Health or Personal Care Facility Type	Plan Review Required
Hospital	Yes
Nursing home unit or long-term care unit	Yes
Boarding home	Yes
Assisted living facility	Yes
Private alcoholism hospital	Yes
Private psychiatric hospital	Yes
Maternity home	Yes
Ambulatory surgery facility	Yes
Renal hemodialysis clinic	Yes
Residential treatment facility	Yes
Enhanced service facility	Yes
Adult residential rehabilitation center	Yes

Table 900-2 Educational and Institutional Facilities, Places of Assembly, or Other Facilities

Educational, Institutional, or Other Facility Types	Plan Review Required
Educational	Yes
Institutional	Yes

Part C – Permits and fees.

WAC 296-46B-901 General — Electrical work permits and fees.

General.

- (1) When an electrical work permit is required by chapter [19.28](#) RCW or this chapter, inspections may not be made, equipment must not be energized, or services connected unless:
 - (a) A valid electrical work permit is obtained and posted per subsection (5) of this section;
 - (b) The classification or type of facility to be inspected and the exact scope and location of the electrical work to be performed are clearly shown on the electrical work permit;
 - (c) The address where the inspection is to be made is clearly identifiable from the street, road or highway that serves the premises; and
 - (d) Driving directions are provided for the inspectors' use.
- (2) Except as allowed for annual permits and two-family dwellings, an electrical work permit is valid for only one specific job site address.

Permit - Responsibility for.

- (3) Each person, firm, partnership, corporation, or other entity must furnish a valid electrical work permit for the installation, alteration, or other electrical work performed or to be performed by that entity.
When the original purchaser is replaced, another entity may request, in writing, written approval from the chief electrical inspector to take responsibility for the work of the original installing entity under the original permit. If permission is not granted, the entity must obtain a new permit for the remaining work.
Two or more entities may never work under the same permit.
Each electrical work permit application must be signed by the electrical contractor's administrator (or designee) or the person, or authorized representative of the firm, partnership, corporation, or other entity that is performing the electrical installation or alteration. Permits purchased electronically do not require a handwritten signature. An entity designated to sign electrical permits must provide written authorization of the purchaser's designation when requested by the department or city that is authorized to do electrical inspections.
- (4) Permits to be obtained by customers. Whenever a serving electrical utility performs work for a customer under one of the exemptions in [WAC 296-46B-925](#) and the work is subject to inspection, the customer is responsible for obtaining all required permits.
- (5) Except as allowed for Class B permits, where an electrical work permit is required, the work permit must be obtained and posted at the job site or the electrical work permit number must be conspicuously posted and identified as the electrical work permit number on or adjacent to the electrical service or feeder panel supplying power to the work prior to beginning any electrical work and at all times until the electrical inspection process is completed.
Exceptions:
 - (a) For an owner, an electrical work permit for emergency like-in-kind repairs to an existing electrical system(s) must be obtained no later than the next business day after the work is begun.
 - (b) For an electrical contractor, in a city's jurisdiction where the city is authorized to do electrical inspections and does not have a provisional permit system, an electrical work permit for emergency like-in-kind repairs to an existing electrical system(s) must be obtained and posted per the city's requirements at the job site no later than the next business day after the work is begun.
- (6) Fees must be paid in accordance with the inspection fee schedule in Part C of this chapter. The amount of the fee due is calculated based on the fee effective at the date payment is made. If the project is required to have an electrical plan review, the plan review fees will be based on the fees effective at the date the plans are received by the department for review. In a city where the department is doing inspections as the city's contractor, a supplemental fee may apply.

Permit - Requirements for.

- (7) As required by chapter [19.28](#) RCW or this chapter, an electrical work permit is required for the installation, alteration, or maintenance of all electrical systems or equipment except for:
 - (a) Travel trailers;
 - (b) Class A basic electrical work which includes:
 - (i) The like-in-kind replacement of lamps; a single set of fuses; a single battery smaller than 150 amp hour; contactors, relays, timers, starters, circuit boards, or similar control components; one household appliance; circuit breakers; single-family residential luminaires; a maximum of

five snap switches, dimmers, receptacle outlets, thermostats, heating elements, luminaire ballasts or drivers/power supplies for single LED luminaires with an exact same ballast or driver/power supply; component(s) of electric signs, outline lighting, or skeleton neon tubing when replaced on-site by an appropriate electrical contractor and when the sign, outline lighting or skeleton neon tubing electrical system is not modified; one ten horsepower or smaller motor.

For the purposes of this section, "circuit breaker" means a circuit breaker that is used to provide overcurrent protection only for a branch circuit, as defined in NEC 100.

- (ii) Induction detection loops described in [WAC 296-46B-300](#)(2) and used to control gate access devices;
- (iii) Heat cable repair; and
- (iv) Embedding premanufactured heat mats in tile grout where the mat is listed by an approved testing laboratory and comes from the manufacturer with preconnected lead-in conductors. All listing marks and lead-in conductor labels must be left intact and visible for evaluation and inspection by the installing electrician and the electrical inspector.
- (v) The disconnection of electrical circuits from their overcurrent protection device for the specific purpose of removing the electrical wiring or equipment for disposal.

Unless specifically noted, the exemptions listed do not include: The replacement of an equipment unit, assembly, or enclosure that contains an exempted component or combination of components (e.g., an electrical furnace/heat pump, industrial milling machine, etc.) or any appliance/equipment described in this section for Class B permits.

In the department's jurisdiction, a provisional electrical work permit label may be posted in lieu of an electrical work permit. If a provisional electrical work permit label is used, an electrical work permit must be obtained within two working days after posting the provisional electrical work permit label. See [WAC 296-46B-907](#)(2) for provisional label requirements.

- (c) The following types of systems and circuits are considered exempt from the requirements for licensing and permitting described in chapter [19.28](#) RCW. The electrical failure of these systems does not inherently or functionally compromise safety to life or property.
 - (i) Low-voltage thermocouple derived circuits
 - (ii) Low-voltage circuits for built-in residential vacuum systems;
 - (iii) Low-voltage circuits for underground landscape sprinkler systems;
 - (iv) Low-voltage circuits for underground landscape lighting; and
 - (v) Low-voltage circuits for residential garage doors.

For these types of systems and circuits to be considered exempt, the following conditions must be met:

- (A) The power supplying the installation must be derived from a listed Class 2 power supply;
- (B) The installation and termination of line voltage equipment and conductors supplying these systems is performed by appropriately licensed and certified electrical contractors and electricians;
- (C) The conductors of these systems do not pass through fire-rated walls, fire-rated ceilings or fire-rated floors in other than residential units; and
- (D) Conductors or luminaires are not installed in installations covered by the scope of Article 680 NEC (swimming pools, fountains, and similar installations).

- (8) An electrical work permit is required for all installations of telecommunications systems on the customer side of the network demarcation point for projects greater than ten telecommunications outlets. All backbone installations regardless of size and all telecommunications cable or equipment installations involving penetrations of fire barriers or passing through hazardous locations require permits and inspections. For the purposes of determining the inspection threshold for telecommunications projects greater than ten outlets, the following will apply:

- (a) An outlet is the combination of jacks and mounting hardware for those jacks, along with the associated cable and telecommunications closet terminations, that serve one workstation. In counting outlets to determine the inspection threshold, one outlet must not be associated with more than six standard four-pair cables or more than one twenty-five-pair cable. Therefore, installations of greater than sixty standard four-pair cables or ten standard twenty-five-pair cables require permits and inspections. (It is not the intent of the statute to allow large masses of cables to be run to workstations or spaces serving telecommunications equipment without inspection. Proper cable support and proper loading of building structural elements are safety concerns. When considering total associated cables, the telecommunications availability at one workstation may count as more than one outlet.)

- (b) The installation of greater than ten outlets and the associated cables along any horizontal pathway from a telecommunications closet to work areas during any continuous ninety-day period requires a permit and inspection.
- (c) All telecommunications installations within the residential dwelling units of single-family, duplex, and multifamily dwellings do not require permits or inspections. In residential multifamily dwellings, permits and inspections are required for all backbone installations, all fire barrier penetrations, and installations of greater than ten outlets in common areas.
- (d) No permits or inspections are required for installation or replacement of cord and plug connected telecommunications equipment or for patch cord and jumper cross-connected equipment.
- (e) Definitions of telecommunications technical terms will come from chapter [19.28](#) RCW, this chapter, TIA/EIA standards, and NEC.

Inspection and approval.

(9) Requests for inspections.

- (a) Requests for inspections must be made no later than three working days after an entity completes its electrical/telecommunications installation or one working day after any part of the installation has been energized, whichever occurs first.
- (b) Requests for after hours, weekend inspections, or temporary installations that will be energized for less than 48 hours must be made by contacting the local electrical inspection supervisor at least three working days prior to the requested date of inspection. The portal-to-portal inspection fees required for after hours or weekend inspections are in addition to the cost of the original electrical work permit.
- (c) Inspections for annual electrical maintenance permits and annual telecommunications permits may be done on a regular schedule arranged by the permit holder with the department.

(10) Inspections will not be made until all permit fees are paid in full.

Permit - Duration/refunds.

(11) Electrical work permits will expire one year after the date of purchase unless permission is granted by the chief electrical inspector or when the permit is closed or completed by the inspector. Refunds are not available for:

- (a) Expired electrical work permits;
- (b) Electrical work permit fee items, within the department's jurisdiction, where the electrical installation has begun or an inspection requested for that work; or
- (c) The first \$25.00 of each permit purchase – application fee.

All refund requests must be made using the Request for Refund application form.

Permit - Annual telecommunications.

(12) The chief electrical inspector or city that is authorized to do electrical inspections can allow annual permits for the inspection of telecommunications installations to be purchased by a building owner or licensed electrical/telecommunications contractor. The owner's full-time telecommunications maintenance staff, or a licensed electrical/telecommunications contractor(s) can perform the work done under this annual permit. The permit holder is responsible for correcting all installation deficiencies. The permit holder must make available, to the electrical inspector, all records of all the telecommunications work performed and the valid electrical or telecommunications contractor's license numbers for all contractors working under the permit. Upon request, the chief electrical inspector may allow the annual permit to be used for multiple worksites or addresses.

Permit - Annual electrical.

(13) The chief electrical inspector or city that is authorized to do electrical inspections can allow annual permits for the inspection of electrical installations to be purchased by a building owner or licensed electrical contractor. This type of permit is available for commercial/industrial locations employing a full-time electrical maintenance staff or having a yearly maintenance contract with a licensed electrical contractor. Upon request, the chief electrical inspector may allow the annual permit to be used for multiple worksites or addresses.

The permit holder is responsible for correcting all installation deficiencies. The permit holder must make available, to the electrical inspector, all records of all electrical work performed.

This type of electrical permit may be used for retrofit, replacement, maintenance, repair, upgrade, and alterations to electrical systems at a plant or building location. This type of permit does not include new or increased service or new square footage.

Permit - Temporary construction project installations.

(14) For temporary electrical installations, the department will consider a permit applicant to be the owner per RCW [19.28.261](#) under the conditions below:

Any person firm, partnership, corporation, or other entity registered as a general contractor under chapter 18.27 RCW will be permitted to install a single electrical service per address for the purposes of temporary power during the construction phase of a project, when all of the following conditions are met:

- (a) The installation is limited to the mounting and bracing of a preassembled pole or pedestal mounted service, the installation of a ground rod or ground plate, and the connection of the grounding electrode conductor to the ground rod or plate;
- (b) The total service size does not exceed 200 amperes, 250 volts nominal;
- (c) The service supplies no feeders;
- (d) Branch circuits not exceeding 50 amperes each are permitted, provided such branch circuits supply only receptacles that are either part of the service equipment or are mounted on the same pole;
- (e) The general contractor owns the electrical equipment;
- (f) The general contractor has been hired by the property owner as the general contractor for the project;
- (g) The general contractor must purchase an electrical work permit for the temporary service, request inspection, and obtain approval prior to energizing the service.

Posting of corrections.

(15) Electrical installations found to be not in compliance with approved standards must be corrected within fifteen calendar days of notification by the department as required in RCW [19.28.101](#)(3). The notifications will be posted electronically on the electrical permit inspection results. A printed copy of the correction notification will be posted by the inspector at the job site for permits not purchased electronically.

WAC 296-46B-902 Equipment standards approval — City ordinances.

(1) Any city that does electrical or telecommunications inspections must declare their intent to do inspections by ordinance. See RCW [19.28.010](#)(3) for city inspection and inspector requirements. The department may enforce city electrical or telecommunications ordinances where those governmental agencies do not make inspections under an established program.

Evaluation engineers, testing laboratories, and equipment standards.

(2) As authorized in [RCW 19.28.010](#)(1), the department is the sole authority for determining testing laboratory accreditation. See WAC [296-46B-997](#) and [999](#) for information regarding evaluation engineers, testing laboratories, and equipment standards.

WAC 296-46B-903 Equipment standards.

General.

- (1) The standard(s) used, as the basis of electrical product certification, field evaluation, or department approval must be determined by the department to provide an adequate level of safety or define an adequate level of safety performance. Except for the reference of construction requirements to ensure the product can be installed in accordance with the National Electrical Code, field evaluations, by an approved laboratory, must not use the National Electrical Code as standard for product evaluation.
- (2) Generally, standards will be:
 - (a) Developed by a standards developing organization under a method providing for input and consideration of views of industry groups, experts, users, consumers, governmental authorities, and others having broad experience in the electrical products safety field. A standard is used to control the quality and safety of a product;
 - (b) Compatible with and be maintained current with periodic revisions of applicable national codes and installation standards; and
 - (c) Approved by the department. The department will evaluate the proposed standard to determine that it provides an adequate level of safety.
- (3) All ANSI safety designated electrical product standards may be deemed acceptable for their intended use without further qualification.
- (4) If the product safety standard is not ANSI, the standard must be reviewed and approved by the department as an appropriate electrical product safety standard as a part of the field evaluation or department inspection process.

Industrial control panel and industrial utilization equipment inspection.

- (5) Specific definitions for this section:
 - (a) "Engineering evaluation" means a review in accordance with subsection (6)(c) of this section.
 - (b) "Food processing plants" include buildings or facilities used in a manufacturing process, but do not include:
 - (i) Municipal or other government facilities;
 - (ii) Educational facilities or portions thereof;
 - (iii) Institutional facilities or portions thereof;
 - (iv) Restaurants;
 - (v) Farming, ranching, or dairy farming operations;
 - (vi) Residential uses; or
 - (vii) Other installations not used for direct manufacturing purposes.
 - (c) In RCW [19.28.010](#), "industrial control panel" means a factory or user wired assembly of industrial control equipment such as motor controllers, switches, relays, power supplies, computers, cathode ray tubes, transducers, and auxiliary devices used in the manufacturing process to control industrial utilization equipment. The panel may include disconnecting means and motor branch circuit protective devices. Industrial control panels include only those used in a manufacturing process in a food processing or industrial plant.
 - (d) "Industrial plants" include buildings or facilities used in a manufacturing process or a manufacturing training facility (e.g., educational shop area in an educational or institutional facility), but do not include:
 - (i) Municipal or other government facilities;
 - (ii) Other educational facilities or portions thereof;
 - (iii) Other institutional facilities or portions thereof;
 - (iv) Restaurants;
 - (v) Farming, ranching, or dairy farming operations;
 - (vi) Residential uses; or
 - (vii) Other installations not used for direct manufacturing purposes.
 - (e) "Industrial utilization equipment" means equipment directly used in a manufacturing process in a food processing or industrial plant, in particular the processing, treatment, moving, or packaging of a material. Industrial utilization equipment does not include: Cold storage, warehousing, or similar storage equipment.
 - (f) "Manufacturing process" means to make or process a raw material or part into a finished product for sale using industrial utilization equipment. A manufacturing process does not include the storage of a product for future distribution (e.g., cold storage, warehousing, and similar storage activity).
 - (g) "Normal department inspection" is a part of the department electrical inspection process included with the general wiring inspection of a building, structure, or other electrical installation. Normal department inspection will only be made for equipment solely using listed or field evaluated components and wired

to the requirements of the NEC. Fees for the normal department inspections required under this chapter are included in the electrical work permit fee calculated for the installation and are not a separate inspection fee. However, inspection time associated with such equipment is subject to the progress inspection rates in Part (C) of this chapter.

(h) For the purposes of this section, "panel" means a single box or enclosure containing the components comprising an industrial control panel. A panel does not include any wiring methods connecting multiple panels or connecting a panel(s) and other electrical equipment.

(6) Industrial control panels and industrial utilization equipment will be determined to meet the minimum electrical safety standards for installations by:

- (a) Listing or field evaluation of the entire panel or equipment;
- (b) Normal department inspection for compliance with codes and rules adopted under this chapter; or
- (c) An engineering evaluation review where an engineer, accredited by the department, shows the equipment to be in compliance with an appropriate industrial equipment standard(s).

(i) See WAC [296-46B-997](#) for the requirements to become an accredited engineer.

(ii) The engineer may review equipment upon request by the equipment owner or the equipment manufacturer.

(iii) The equipment may be reviewed for compliance with the standard(s) before the equipment is located in Washington.

(iv) Appropriate standards are:

- (A) NEMA;
- (B) ANSI;
- (C) NFPA 79;
- (D) UL 508A;
- (E) International Electrotechnical Commission 60204; or
- (F) Their equivalent.

(v) In cases where equipment has been previously reviewed and approved by an accredited engineer or the department and found to meet an appropriate standard(s), the equipment information will be placed on a "reviewed and approved industrial utilization equipment list" established and maintained by the reviewing engineer. The list may be used by a reviewing engineer to aid in evaluating other like equipment. Because standards change over time, equipment will be removed from the list three years after the last successful review. The list will contain the following information:

- (A) Equipment manufacturer name;
- (B) Model and serial numbers;
- (C) Voltage, full load current; phasing; and asymmetrical fault current rating of the equipment;
- (D) Accessory items approved for use with the equipment;
- (E) Standard(s) to which the equipment was built;
- (F) Application of use for the equipment;
- (G) Original reviewing engineer's name; and
- (H) Date of the original review approval.

(vi) If the engineer uses the "reviewed and approved industrial utilization equipment list", the engineer will visually determine that the equipment being reviewed is the exact same model as equipment on the list.

(vii) Before the engineer's approval label can be applied, the engineer must visually inspect the equipment on site to determine that the equipment is in factory original good condition, has not been modified electrically, and the equipment use is appropriate to the standard(s).

(viii) When the review is completed and the equipment is eligible for approval, the engineer must personally affix a permanent label to the equipment showing:

- (A) Engineer's name;
- (B) Date of approval;
- (C) Equipment serial number;
- (D) Equipment voltage, full load current, phasing, and fault interrupting rating; and
- (E) The following statement: "This equipment meets appropriate standards for industrial utilization equipment."

(7) The department may authorize, on a case-by-case basis, use of the industrial control panel or equipment, for a period not to exceed six months or as approved by the chief electrical inspector after use is begun, before its final inspection, listing, field evaluation, or engineering evaluation is complete.

WAC 296-46B-906 Inspection fees.

To calculate inspection fees, the amperage is based on the conductor ampacity or the overcurrent device rating. The total fee must not be less than the number of progress inspection (one-half hour) units times the progress inspection fee rate from subsection (8) of this section, PROGRESS INSPECTIONS.

The amount of the fee due is calculated based on the fee effective at the date of a department assessed fee (e.g., plan review or fee due) or when the electrical permit is purchased.

(1) Residential.

(a) Single- and two-family residential (New Construction).

Notes:

(1) Square footage is the area included within the surrounding exterior walls of a building exclusive of any interior courts. (This includes any floor area in an attached garage, basement, or unfinished living space.)

(2) "Inspected with the service" means that a separate service inspection fee is included on the same electrical work permit.

(3) "Inspected at the same time" means all wiring is to be ready for inspection during the initial inspection trip.

(4) An "outbuilding" is a structure that serves a direct accessory function to the residence, such as a pump house or storage building. Outbuilding does not include buildings used for commercial type occupancies or additional dwelling occupancies.

(i) First 1300 sq. ft.	\$94.20
Each additional 500 sq. ft. or portion of	\$30.10
(ii) Each outbuilding or detached garage - inspected at the same time as a dwelling unit on the property	\$39.20
(iii) Each outbuilding or detached garage - inspected separately	\$62.00
(iv) Each swimming pool - inspected with the service	\$62.00
(v) Each swimming pool - inspected separately	\$94.20
(vi) Each hot tub, spa, or sauna - inspected with the service	\$39.20
(vii) Each hot tub, spa, or sauna - inspected separately	\$62.00
(viii) Each septic pumping system - inspected with the service	\$39.20
(ix) Each septic pumping system - inspected separately	\$62.00

(b) Multifamily residential and miscellaneous residential structures, services and feeders (New Construction).

Each service and/or feeder		
Ampacity	Service/Feeder	Additional Feeder
0 to 200	\$101.60	\$30.10
201 to 400	\$126.30	\$62.00
401 to 600	\$173.50	\$86.30
601 to 800	\$222.70	\$118.60
801 and over	\$317.60	\$238.20

(c) Single or multifamily altered services or feeders including circuits.

(i) Each altered service and/or altered feeder

Ampacity	Service/Feeder
0 to 200	\$86.30
201 to 600	\$126.30
601 and over	\$190.40

(ii) Maintenance or repair of a meter or mast (no alterations to the service or feeder) \$46.70

(d) Single or multifamily residential circuits only (no service inspection).

Note:

Altered or added circuit fees are calculated per panelboard. Total cost of the alterations in an individual panel should not exceed the cost of a complete altered service or feeder of the same rating, as shown in subsection (1) RESIDENTIAL (c) (table) of this section.

(i) 1 to 4 circuits (see note above)	\$62.00
(ii) Each additional circuit (see note above)	\$6.60

(e) Mobile homes, modular homes, mobile home parks, and RV parks.

(i) Mobile home or modular home service or feeder only	\$62.00
(ii) Mobile home service and feeder	\$101.60

(f) Mobile home park sites and RV park sites.

Note:

For master service installations, see subsection (2) COMMERCIAL/INDUSTRIAL of this section.

(i) First site service or site feeder	\$62.00
(ii) Each additional site service; or additional site feeder inspected at the same time as the first service or feeder	\$39.20

(2) Commercial/industrial.

(a) New service/feeder, and additional new feeders inspected at the same time (includes circuits).

Note:

For large COMMERCIAL/INDUSTRIAL projects that include multiple feeders, "inspected at the same time" can be interpreted to include additional inspection trips for a single project. The additional inspections must be for electrical work specified on the permit at the time of purchase. The permit fee for such projects must be calculated using this section. However, the total fee must not be less than the number of progress inspection (one-half hour) units times the progress inspection fee rate from subsection (8) PROGRESS INSPECTIONS of this section.

Ampacity	Service/Feeder	Additional Feeder
0 to 100	\$101.60	\$62.00
101 to 200	\$123.70	\$79.00
201 to 400	\$238.20	\$94.20
401 to 600	\$277.60	\$110.80
601 to 800	\$359.10	\$151.00
801 to 1000	\$438.40	\$182.70
1001 and over	\$478.30	\$255.00

(b) Altered services/feeder (no circuits).

(i) Service/Feeder

Ampacity	Service/Feeder
0 to 200	\$101.60
201 to 600	\$238.20
601 to 1000	\$359.10
1001 and over	\$398.90

(ii) Maintenance or repair of a meter or mast (no alterations to the service or feeder) \$86.30

(c) Circuits only.

Note:

Altered/added circuit fees are calculated per panelboard. Total cost of the alterations in a panel (or panels) should not exceed the cost of a new feeder (or feeders) of the same rating, as shown in subsection (2) COMMERCIAL/INDUSTRIAL (2)(a)(table) above.

(i) First 5 circuits per branch circuit panel \$79.00

(ii) Each additional circuit per branch circuit panel \$6.60

(d) Over 600 volts surcharge per permit. \$79.00

(3) Temporary service(s).

Note:

(1) See WAC [296-46B-590](#) for information about temporary installations.

(2) Temporary stage or concert inspections requested outside of normal business hours will be subject to the portal-to-portal hourly fees in subsection (11) OTHER INSPECTIONS. The fee for such after hours inspections will be the greater of the fee from this subsection or the portal-to-portal fee.

Temporary services, temporary stage or concert productions.

Ampacity	Service/Feeder	Additional Feeder
0 to 60	\$54.30	\$27.80
61 to 100	\$62.00	\$30.10
101 to 200	\$79.00	\$39.20
201 to 400	\$94.20	\$46.80
401 to 600	\$126.30	\$62.00
601 and over	\$143.30	\$71.30

(4) Irrigation machines, pumps, and equipment.

Irrigation machines.

- (a) Each tower - When inspected at the same time as a service and feeder from (2) COMMERCIAL/INDUSTRIAL \$6.60
- (b) Towers - When not inspected at the same time as a service and feeders - 1 to 6 towers \$94.20
- (c) Each additional tower \$6.60

(5) Miscellaneous - Commercial/industrial and residential.

- (a) **A Class 2 low-voltage thermostat** and its associated cable controlling a single piece of utilization equipment or a single furnace and air conditioner combination.
 - (i) First thermostat \$46.80
 - (ii) Each additional thermostat inspected at the same time as the first \$14.50
- (b) **Class 2 or 3 low-voltage systems and telecommunications systems.** Includes all telecommunications installations, fire alarm, nurse call, energy management control systems, industrial and automation control systems, lighting control systems, and similar Class 2 or 3 low-energy circuits and equipment not included in WAC [296-46B-908](#) for Class B work.
 - (i) First 2500 sq. ft. or less \$54.30
 - (ii) Each additional 2500 sq. ft. or portion thereof \$14.50
- (c) **Signs and outline lighting.**
 - (i) First sign (no service included) \$46.80
 - (ii) Each additional sign inspected at the same time on the same building or structure \$22.10

(d) Berth at a marina or dock.

Note:

Five berths or more will be permitted to have the inspection fees based on appropriate service and feeder fees from section (2) COMMERCIAL/INDUSTRIAL above.

(i) Berth at a marina or dock	\$62.00
(ii) Each additional berth inspected at the same time	\$39.20

(e) Yard pole, pedestal, or other meter loops only.

(i) Yard pole, pedestal, or other meter loops only	\$62.00
(ii) Meters installed remote from the service equipment and inspected at the same time as a service, temporary service or other installations	\$14.50

(f) Inspection appointment requested for outside of normal working hours.

Regular fee plus surcharge of: \$118.60

(g) Generators.

Note:

Permanently installed generators: Refer to the appropriate residential or commercial new/alterred service or feeder section.

Portable generators: Permanently installed transfer equipment for portable generators	\$86.30
---	---------

(h) Electrical - annual permit fee.

Note:

See WAC [296-46B-901](#)(13).

For commercial/industrial location employing full-time electrical maintenance staff or having a yearly maintenance contract with a licensed electrical contractor. Note, all yearly maintenance contracts must detail the number of contractor electricians necessary to complete the work required under the contract. This number will be used as a basis for calculating the appropriate fee. Each inspection is based on a 2-hour maximum.

	Inspections	Fee
1 to 3 plant electricians	12	\$2,284.20
4 to 6 plant electricians	24	\$4,571.00
7 to 12 plant electricians	36	\$6,856.20
13 to 25 plant electricians	52	\$9,143.00
More than 25 plant electricians	52	\$11,429.80

(i) Telecommunications - annual permit fee.

Notes:

(1) See WAC [296-46B-901](#)(12).

(2) Annual inspection time required may be estimated by the purchaser at the rate for "OTHER INSPECTIONS" in this section, charged portal-to-portal per hour.

For commercial/industrial location employing full-time telecommunications maintenance staff or having a yearly maintenance contract with a licensed electrical/telecommunications contractor.

2-hour minimum	\$188.80
Each additional hour, or portion thereof, of portal-to-portal inspection time	\$94.20

(j) Permit requiring ditch cover inspection only.

Each 1/2 hour, or portion thereof	\$46.80
-----------------------------------	---------

(k) Cover inspection for elevator/conveyance installation.

This item is only available to a licensed/registered elevator contractor.

(6) Carnival inspections.

(a) First carnival field inspection each calendar year.

(i) Each ride and generator truck	\$22.10
(ii) Each remote distribution equipment, concession, or gaming show	\$6.60
(iii) If the calculated fee for first carnival field inspection above is less than \$100.50, the minimum inspection fee will be:	\$118.60

(b) Subsequent carnival inspections.

(i) First ten rides, concessions, generators, remote distribution equipment, or gaming show	\$118.60
(ii) Each additional ride, concession, generator, remote distribution equipment, or gaming show	\$6.60

(c) Concession(s) or ride(s) not part of a carnival.

(i) First field inspection each year of a single concession or ride, not part of a carnival	\$94.20
(ii) Subsequent inspection of a single concession or ride, not part of a carnival	\$62.00

(7) Trip fees.

(a) Requests by property owners to inspect existing installations. (This fee includes a maximum of one hour of inspection time. All inspection time exceeding one hour will be charged at the rate for progressive inspections.)	\$94.20
(b) Submitter notifies the department that work is ready for inspection when it is not ready.	\$46.80
(c) Additional inspection required because submitter has provided the wrong address or incomplete, improper or illegible directions for the site of the inspection.	\$46.80
(d) More than one additional inspection required to inspect corrections; or for repeated neglect, carelessness, or improperly installed electrical work.	\$46.80
(e) Each trip necessary to remove a noncompliance notice.	\$46.80
(f) Corrections that have not been made in the prescribed time, unless an exception has been requested and granted.	\$46.80
(g) Installations that are covered or concealed before inspection.	\$46.80

(8) Progress inspections.

Note:

The fees calculated in subsections (1) through (6) of this section will apply to all electrical work. This section will be applied to a permit where the permit holder has requested additional inspections beyond the number supported by the permit fee calculated at the rate in subsections (1) through (6) of this section.

Partial or progress inspections, each 1/2 hour.

\$46.80

(9) Plan review.

(a) Plan review fee is 35% of the electrical work permit fee as determined by WAC 296-46B-906	35%
(b) Plan review submission fee.	\$79.00
(c) Supplemental submissions of plans per hour or fraction of an hour of review time.	\$94.20
(d) Plan review handling fee.	\$22.10

(10) Out-of-state inspections.

(a) Permit fees will be charged according to the fees listed in this section.
(b) Travel expenses:

All travel expenses and per diem for out-of-state inspections are billed following completion of each inspection(s). These expenses can include, but are not limited to: Inspector's travel time, travel cost and per diem at the state rate. Travel time is hourly based on the rate in subsection (11) of this section.

(11) Other inspections.

Inspections not covered by above inspection fees must be charged portal-to-portal per hour: \$94.20

(12) Variance request processing fee.

Variance request processing fee. This fee is nonrefundable once the transaction has been validated. \$94.20

(13) Class B basic electrical work labels.

(a) Block of twenty Class B basic electrical work labels (not refundable).	\$258.70
(b) Reinspection of Class B basic electrical work to assure that corrections have been made (per 1/2 hour timed from leaving the previous inspection until the reinspection is completed). See WAC 296-46B-908(5) .	\$46.80
(c) Reinspection of Class B basic electrical work because of a failed inspection of another Class B label (per 1/2 hour from previous inspection until the reinspection is completed). See WAC 296-46B-908(5) .	\$46.80

(15) Provisional electrical work permit labels.

Block of twenty provisional electrical work permit labels. \$258.70

Part D – Provisional permits.

WAC 296-46B-907 Provisional permits.

Provisional electrical work permit - Use/duration/refunds.

- (1) Only licensed electrical or telecommunications contractors can use provisional electrical work permits.
- (2) If a provisional electrical work permit label is used, the following requirements must be met:
 - (a) Prior to beginning the work, the certified electrician or telecommunications worker performing the installation must affix the provisional electrical work permit label to the building, structure, or on the cover of the panelboard, overcurrent device, or telecommunications equipment supplying the circuit or equipment.
 - (b) The job site and contractor portion of the label must be completely filled out.
 - (c) The label must be filled in using sunlight and weather resistant ink.
 - (d) The contractor must return the contractor's portion of the label to the department of labor and industries, electrical section office having jurisdiction for the inspection, within two working days after the job site portion of the label is affixed. Either receipt by department of labor and industries or postmark to a valid department of labor and industries electrical address is acceptable for meeting this requirement.
- (3) Refunds are not available for provisional electrical work permit labels.
- (4) Provisional electrical work permit labels will be sold in blocks of twenty.
- (5) Any contractor purchasing a provisional electrical work permit label may be audited for compliance with the provisions for purchasing, inspection, reporting of installations, and any other requirement of usage.
- (6) An electrical work permit must be obtained within two working days after posting the provisional work permit label.
See WAC [296-46B-901\(7\)\(b\)](#).

Part E – Class B permits.

WAC 296-46B-908 – Class B permits.

Class B electrical work permit - Use.

- (1) The Class B basic electrical random inspection process (Class B process) may only be used by:
 - (a) Licensed electrical/telecommunication contractors; or
 - (b) Health care, commercial, or industrial facilities using an employee(s) who is an appropriately certified electrician(s) after requesting, in writing, and receiving written permission from the chief electrical inspector.

Each entity doing work must use a separate label.
- (2) The Class B random inspection process is only available if the label is validated and the label or label number is posted before beginning the work.
 - (a) For Class B labels obtained after February 28, 2013:
 - (i) Prior to, or immediately upon posting the Class B label/number, the purchaser must use the department's online Class B system to enter the job site information for an unused Class B label obtained by the purchaser. If the posting occurs on a weekend or a federal/state holiday, the purchaser must use the online system to enter the information no later than the first business day after posting the label/number;
 - (ii) The person identified as the installer on the Class B label must post the Class B label or label number, in a conspicuous permanent manner, at the:
 - (A) Main service/feeder location supplying the structure or system; or
 - (B) Purchaser's equipment, or on the equipment conductors if the equipment is not in place.
 - (iii) The Class B label is valid immediately upon the purchaser completing the job site information in the department's online Class B system, and posting of the Class B label or label number per (a)(ii) of this subsection.
 - (b) For Class B labels obtained before March 1, 2013:
 - (i) The purchaser must fully enter the job site information on the job site and contractor portions of the Class B label.
 - (ii) The person identified as the installer on the Class B label must post the completed job site copy, in a conspicuous permanent manner, at the:
 - (A) Main service/feeder location supplying the structure or system;
 - (B) Purchaser's equipment, or on the conductors if the equipment is not available.
 - (iii) The purchaser must return the contractor copy to the Department of Labor and Industries, Electrical Section, Chief Electrical Inspector, P.O. Box 44460, Olympia, WA 98504-4460 within fifteen working days after the job site portion of the Class B installation label is affixed.
 - (iv) The Class B label is valid immediately upon posting on the job site.
- (3) Class B labels will be sold in blocks and are nonrefundable and nontransferable.
- (4) Class B label installations will be inspected on a random basis as determined by the department.
- (5) A progress inspection fee is required for any inspection required when a correction(s) is issued as a result of the inspection of a Class B label.
- (6) Any entity using the Class B process may be audited for compliance with the provisions for purchasing, inspection, reporting of installations, and any other requirement of usage.
- (7) A separate label is required for each line item listed below in subsection (10) of this section. For example, if the work includes an item under subsection (10)(a) and (b)(i) of this section, two labels are required.
- (8) An entity using a Class B basic inspection label is restricted to using no more than two labels per week per job site.
- (9) All Class B work must be completed within fifteen days after the label is validated. If the work is not completed, another Class B may be posted.
Except that, in a one- or two-family residential structure, a label is valid for ninety days after the label is validated, so long as all work described on the label is performed by the purchaser.
- (10) Class B work includes the following:
 - (a) Extension of not more than one branch electrical circuit limited to 120 volts and 20 amps each where:
 - (i) No cover inspection is necessary. For the purposes of this section, cover inspection does not include work covered by any surface that may be removed for inspection without damaging the surface; and
 - (ii) The extension does not supply more than two outlets as defined by the NEC.
 - (b) Single like-in-kind replacement of:
 - (i) A motor larger than 10 horsepower; or

- (ii) The internal wiring of a furnace, air conditioner, refrigeration unit or household appliance; or
- (iii) An electric/gas/oil furnace not exceeding 240 volts and 100 amps and associated Class 2 low voltage wiring when the furnace is connected to an existing branch circuit. For the purposes of this section, a boiler is not a furnace; or
- (iv) An individually controlled electric room heater (e.g., baseboard, wall, fan forced air, etc.), air conditioning unit, heat pump unit, or refrigeration unit not exceeding 240 volts, 40 minimum circuit amps and associated Class 2 low voltage wiring when the unit is connected to an existing branch circuit; or
- (v) Circuit modification required to install not more than five residential load control devices in a residence where installed as part of an energy conservation program sponsored by an electrical utility and where the circuit does not exceed 240 volts and 40 amps; or
- (vi) A single, line-voltage flexible supply whip associated with (b)(i), (iii), or (iv) of this subsection, not over 6 feet in length, provided there are no modifications to the branch circuit/feeder load being supplied by the whip. May be done on the same Class B label with the replacement unit if done at the same time.

(c) The following low voltage systems:

- (i) Repair and replacement of devices not exceeding 100 volt-amperes in Class 2, Class 3, or power limited low voltage systems in one- and two-family dwellings; or
- (ii) Repair and replacement of devices not exceeding 100 volt-amperes in Class 2, Class 3, or power limited low voltage systems in other buildings, provided the equipment is not for fire alarm or nurse call systems and is not located in an area classified as hazardous by the NEC; or
- (iii) The installation of Class 2 or 3 device(s) or wiring for thermostat, audio, security, burglar alarm, intercom, amplified sound, public address, or access control systems where the installation does not exceed twenty devices or five thousand square feet. This does not include fire alarm, nurse call, lighting control, industrial automation/control or energy management systems; or
- (iv) Telecommunications cabling and equipment requiring inspection in RCW [19.28.470](#) where the installation does not exceed twenty devices or five thousand square feet.

(d) The replacement of not more than ten standard receptacles with GFCI or AFCI receptacles;

(e) The conversion of not more than ten snap switches to dimmers or occupancy sensors for the use of controlling a luminaire(s) conversion;

(f) The like-in-kind replacement of a maximum of twenty: Paddle fans, luminaires not exceeding 277 volts and 20 amperes; snap switches, dimmers, receptacle outlets, line voltage thermostats, heating elements, luminaire ballasts, or drivers/power supplies for single LED luminaires;

(g) The replacement of not more than two luminaires with paddle fans if a listed fan box has been previously installed to support the luminaires;

(h) The replacement of not more than four batteries rated not larger than 150 amp hours each that supply power to a single unit of equipment (e.g., uninterruptable power supply, photovoltaic storage system, control panel, etc.);

(i) The installation or repair of equipment powered by a standalone solar photovoltaic source where the:

- (i) Electrical equipment requires no field assembly except for the attachment and electrical connection of the solar photovoltaic source to the equipment, the installation and attachment to a grounding electrode, and the placement of the equipment on a pad, pole, or other structure;
- (ii) Solar photovoltaic source and the equipment operates at less than 15 volts DC;
- (iii) Solar photovoltaic source is the only source of external power; and
- (iv) Equipment and the solar photovoltaic source are appropriately labeled as a single unit. The label must be by an approved electrical testing laboratory or for equipment used for traffic control labeled according to WAC [296-46B-010](#)(21).

(j) The installation or replacement of a single electric sign on an existing single 120-volt, 20-amp maximum branch circuit.

(11) Class B basic electrical work does not include any work in:

- (a) Areas classified as Class I, Class II, Class III, or Zone locations per NEC 500; or
- (b) Areas regulated by NEC 517 or 680; or
- (c) Any work where electrical plan review is required; or
- (d) Fire alarm, nurse call, lighting control, industrial automation/control or energy management systems.

Part F – Administrative.

WAC 296-46B-909 Electrical/telecommunications contractor's license, administrator certificate and examination, master electrician certificate and examination, electrician certificate and examination, copy, and miscellaneous fees.

Notes: (1) The department will deny renewal of a license, certificate, or permit if an individual owes money as a result of an outstanding final judgment(s) to the department or is in revoked status. The department will deny application of a license, certificate, or permit if an individual is in suspended status or owes money as a result of an outstanding final judgment(s) to the Electrical Program.

(2) Certificates may be prorated for shorter renewal periods in one-year increments. Each year or part of a year will be calculated to be one year.

(3) The amount of the fee due is calculated based on the fee effective at the date payment is made.

(1) General or specialty contractor's license per twenty-four month period. (Nonrefundable after license has been issued.)

(a) Initial application or renewal made in person, by mail, or by fax	\$277.60
(b) Renewal fully completed using the online web process	\$240.10
(c) Reinstatement of a general or specialty contractor's license after a suspension	\$56.20

(2) Master electrician/administrator/electrician/trainee certificate.

(a) Examination application (nonrefundable) Administrator certificate examination application. (Required only for department administered examinations.) (Not required when testing with the department's contractor.)	\$34.70
--	---------

(b) Examination fees (nonrefundable**)**

Note: Normal examination administration is performed by a state authorized contractor. The fees for such examinations are set by contract with the department. For written examinations administered by the department, use the following fee schedule.

(i) Master electrician or administrator first-time examination fee (when administered by the department)	\$83.80
(ii) Master electrician or administrator retest examination fee (when administered by the department)	\$98.20
(iii) Journey level or specialty electrician examination fee (first test or retest when administered by the department)	\$63.10
(iv) Certification examination review fee	\$129.90
(c) Original certificates (nonrefundable after certificate has been issued)	
(i) Electrical administrator original certificate (except 09 telecommunication)	\$125.60
(ii) Telecommunications administrator original certificate (for 09 telecommunications)	\$83.50
(iii) Master electrician exam application (includes original certificate and application processing fee) (\$34.70 is nonrefundable after application is submitted)	\$160.60

(iv) Journey level or specialty electrician application (includes original certificate and application processing fee) (\$34.70 is nonrefundable after application is submitted)	\$90.00
(v) Training certificate	
(A) Initial application made in person, by mail, or by fax	\$44.10
(B) Initial application fully completed online using the online web process	\$37.90
(C) 0% supervision modified training certificate. Includes trainee update of hours (i.e., submission of affidavit of experience) (\$53.40 is nonrefundable after application is submitted)	\$80.30
(D) 75% supervision modified training certificate.	\$53.40
(E) Unsupervised training certificate as allowed by RCW <u>19.28.161</u> (4)(b).	\$26.40
(d) Certificate renewal (nonrefundable)	
(i) Master electrician or administrator certificate	
(A) Renewal made in person, by mail, or by fax	\$158.70
(B) Renewal fully completed using the online web process	\$137.90
(ii) Telecommunications (09) administrator certificate renewal	
(A) Renewal made in person, by mail, or by fax	\$105.70
(B) Renewal fully completed using the online web process	\$91.20
(iii) Late renewal of master electrician or administrator certificate	
(A) Renewal made in person, by mail, or by fax	\$317.50
(B) Renewal fully completed using the online web process	\$275.90
(iv) Late renewal of telecommunications (09) administrator certificate	
(A) Renewal made in person, by mail, or by fax	\$211.60
(B) Renewal fully completed using the online web process	\$182.50
(v) Journey level or specialty electrician certificate renewal	
(A) Renewal made in person, by mail, or by fax	\$83.50
(B) Renewal fully completed using the online web process	\$72.20
(vi) Late renewal of journey level or specialty electrician certificate	
(A) Renewal made in person, by mail, or by fax	\$167.20
(B) Renewal fully completed using the online web process	\$145.50
(vii) Trainee update of hours outside of renewal period (i.e. submission of affidavit of experience outside of the timeline in WAC 296-46B-942(8)(d))	\$53.40
(viii) Trainee certificate renewal	
(A) Renewal made in person, by mail, or by fax	\$53.40
(B) Renewal fully completed using the online web process when the affidavit of experience is submitted per WAC 296-46B-942(8)(d)	\$46.60
(ix) Late trainee certificate renewal	
(A) Renewal made in person, by mail, or by fax	\$74.90
(B) Renewal fully completed using the online web process	\$65.20

(e) Certificate - reinstatement (nonrefundable)		
(i) Reinstatement of a suspended master electrician or administrator's certificate (in addition to normal renewal fee)		\$56.20
(ii) Reinstatement of suspended journey level, or specialty electrician certificate (in addition to normal renewal fee)		\$26.40
(f) Assignment/unassignment of master electrician/administrator designation (nonrefundable)		\$41.60
(3) Certificate/license.		
(a) Replacement for lost or damaged certificate/license. (Nonrefundable.)		\$18.20
(b) Optional display quality General Master Electrician certificate.		\$29.60
(4) Continuing education courses or instructors. (Nonrefundable.)		
(a) If the course or instructor review is performed by the electrical board or the department		
The course or instructor review		\$53.50
(b) If the course or instructor review is contracted out by the electrical board or the department		
(i) Continuing education course or instructor submittal and approval (per course or instructor)		As set in contract
(ii) Applicant's request for review, by the chief electrical inspector, of the contractor's denial		\$130.20
(5) Copy fees. (Nonrefundable.)		
(a) Certified copy of each document (maximum charge per file):		\$59.10
(i) First page:		\$26.40
(ii) Each additional page:		\$2.10
(b) RCW or WAC printed document:		\$5.80
(6) Training school program review fees. Initial training school program review fee. (Nonrefundable.)		
(a) Initial training school program review fee submitted for approval. Valid for three years or until significant changes in program content or course length are implemented (see WAC 296-46B-971 (4)).		\$615.30
(b) Renewal of training school program review fee submitted for renewal. Valid for 3 years or until significant changes in program content or course length are implemented (see WAC 296-46B-971 (4)).		\$307.60

WAC 296-46B-911 Electrical testing laboratory and engineer accreditation fees.

The amount of the fee due is calculated based on the fee effective at the date payment is made.

Electrical testing laboratory

Initial filing fee: (Nonrefundable)	\$585.00
Initial accreditation fee:	
1 product category	\$292.40
Each additional category for the next 19 categories	\$116.90 each
Maximum for 20 categories or more	\$2,515.70
Renewal fee: (Nonrefundable)	50% of initial filing fee
Renewal of existing accreditations	
Each additional category for the next 19 categories	\$116.90 each
Maximum for 20 categories or more	\$2,515.70

Engineer for evaluating industrial utilization equipment

Initial filing fee: (Nonrefundable)	\$585.00
Renewal fee: (Nonrefundable)	50% of initial filing fee

WAC 296-46B-915 Civil penalty schedule.

Notes:

- Each day that a violation occurs on a job site may be a separate offense.
- Once a violation of chapter [19.28](#) RCW or chapter [296-46B](#) WAC becomes a final judgment, any additional violation within three years becomes a "second" or "additional" offense subject to an increased penalty as set forth in the following tables.
- In case of serious noncompliance or a serious violation of the provisions of chapter [19.28](#) RCW or as described in WAC [296-46B-990](#), the department may double the penalty amount, up to ten thousand dollars shown in subsections (1) through (13) of this section.
- A person, firm, partnership, corporation or other entity who violates a provision of chapter [19.28](#) RCW or chapter [296-46B](#) WAC is liable for a civil penalty based upon the following schedule.

(1) Offering to perform, submitting a bid for, advertising, installing or maintaining cables, conductors or equipment:

- (a) That convey or utilize electrical current without having a valid electrical contractor's license; or
- (b) Used for information generation, processing, or transporting of signals optically or electronically in telecommunications systems without having a valid telecommunications contractor's license.

First offense:	\$500
Second offense:	\$1,500
Third offense:	\$3,000
Each offense thereafter:	\$6,000

(2) Employing an individual for the purposes of chapter [19.28](#) RCW who does not possess a valid certificate of competency or training certificate to do electrical work.

First offense:	\$250
Each offense thereafter:	\$500

(3) Performing electrical work without having a valid certificate of competency or electrical training certificate.

- (a) Failing to visibly display a certificate (must possess a valid, active certificate).
 - First offense: \$50
 - Each offense thereafter: \$100

- (b) Performing electrical work while not possessing a valid certificate or working outside the scope of a certificate.
 - First offense: \$250
 - Each offense thereafter: \$500

(4) Employing electricians and electrical trainees for the purposes of chapter [19.28](#) RCW in an improper ratio. Contractors found to have violated this section three times in a three-year period must be the subject of an electrical audit in accordance with WAC [296-46B-975](#).

First offense:	\$250
Each offense thereafter:	\$500

(5) Failing to provide proper supervision to an electrical trainee as required by chapter [19.28](#) RCW. Contractors found to have violated this section three times in a three-year period must be the subject of an electrical audit in accordance with WAC [296-46B-975](#).

First offense:	\$250
Each offense thereafter:	\$500

(6) Working as an electrical trainee without proper supervision as required by chapter 19.28 RCW.	First offense: \$50
	Second offense: \$250
	Each offense thereafter: \$500
(7) Offering, bidding, advertising, or performing electrical or telecommunications installations, alterations or maintenance outside the scope of the firm's specialty electrical or telecommunications contractors license.	First offense: \$500
	Second offense: \$1,500
	Third offense: \$3,000
	Each offense thereafter: \$6,000
(8) Selling or exchanging electrical equipment associated with spas, hot tubs, swimming pools or hydromassage bathtubs which are not listed by an approved laboratory.	First offense: \$500
	Second offense: \$1,000
	Each offense thereafter: \$2,000
Definition:	
The sale or exchange of electrical equipment associated with hot tubs, spas, swimming pools or hydromassage bathtubs includes to: "Sell, offer for sale, advertise, display for sale, dispose of by way of gift, loan, rental, lease, premium, barter or exchange."	
(9) Covering or concealing installations prior to inspection.	First offense: \$250
	Second offense: \$1,000
	Each offense thereafter: \$2,000
(10) Failing to make corrections within fifteen days of notification by the department.	
Exception:	
Where an extension has been requested and granted, this penalty applies to corrections not completed within the extended time period.	
	First offense: \$250
	Second offense: \$1,000
	Each offense thereafter: \$2,000
(11) Failing to get an inspection or obtain an electrical/telecommunications work permit or post a provisional electrical work permit label prior to beginning the electrical/telecommunications installation or alteration.	
Exception:	
In cases of emergency repairs, for owners, to existing electrical/telecommunications systems, this penalty will not be charged if the permit is obtained and posted no later than the business day following beginning work on the emergency repair.	
Standard/provisional permit offenses:	
	First offense: \$250
	Second offense: \$1,000
	Each offense thereafter: \$2,000
Class B offenses:	
Failure to post a Class B label or number for Class B eligible work:	
	First offense: \$100
	Second offense: \$250
	Each offense thereafter: \$1,000

For other Class B offenses:

First offense:	\$100
Second offense:	\$250
Each offense thereafter:	\$1,000

(12) Violating chapter [19.28](#) RCW duties of the electrical/telecommunications administrator or master electrician.

(a) Failing to be a member of the firm or a supervisory employee and must be available during working hours to carry out the duties of an administrator or master electrician.

First offense:	\$1,000
Second offense:	\$1,500
Each offense thereafter:	\$3,000

(b) Failing to ensure that all electrical work complies with the electrical installation laws and rules of the state.

First offense:	\$100
Second offense:	\$250
Third offense:	\$1,000
Each offense thereafter:	\$3,000

(c) Failing to ensure that the proper electrical safety procedures are used.

First offense:	\$500
Second offense:	\$1,500
Each offense thereafter:	\$3,000

(d) Failing to ensure that inspections are obtained and that all electrical labels, permits, and certificates required to perform electrical work are used.

Standard/provisional permit offenses:

First offense:	\$250
Each offense thereafter:	\$500

Class B offenses:

First offense:	\$100
Second offense:	\$250
Each offense thereafter:	\$1,000

(e) Failing to ensure that all electrical licenses, required to perform electrical work are used (i.e., work performed must be in the allowed scope of work for the contractor).

First offense:	\$500
Second offense:	\$1,500
Third offense:	\$3,000
Each offense thereafter:	\$6,000

(f) Failing to see that corrective notices issued by an inspecting authority are complied with within fifteen days.

Exception: Where an extension has been requested and granted, this penalty applies to corrections not completed within the extended time period.

First offense:	\$250
Second offense:	\$1,000
Each offense thereafter:	\$2,000

(g) Failing to notify the department in writing within ten days if the master electrician or administrator terminates the relationship with the electrical contractor.

First offense:	\$500
Second offense:	\$1,000
Each offense thereafter:	\$3,000

(13) Causing or failing to correct a serious violation. A serious violation is a violation of chapter 19.28 RCW or 296-46B WAC that creates a hazard of fire or a danger to life safety.

First offense:	\$1,000
Second offense:	\$3,000
Each offense thereafter:	\$5,000

(14) Violating any of the provisions of chapter [19.28](#) RCW or chapter [296-46B](#) WAC which are not identified in subsections (1) through (12) of this section.

RCW [19.28.161](#) through [19.28.271](#) and the rules developed pursuant to them.

First offense:	\$250
Each offense thereafter:	\$500

All other chapter [19.28](#) RCW provisions and the rules developed pursuant to them.

First offense:	\$250
Second offense:	\$750
Each offense thereafter:	\$2,000

WAC 296-46B-920 Electrical/telecommunications license/certificate types and scope of work.

General Electrical. (01)

(1) A general electrical license and/or certificate encompasses all phases and all types of electrical and telecommunications installations and minor plumbing under RCW [18.106.150](#). For the purposes of RCW 18.106.150, the like-in-kind replacement includes the appliance or any component part of the appliance (e.g., such as, but not limited to, the thermostat in a water heater).

Specialties.

(2) All specialties listed in this subsection may perform the electrical work described within their specific specialty as allowed by the occupancy and location described within the specialty's scope of work. Except for residential (02), the scope of work for these specialties does not include plumbing work regulated under chapter [18.106](#) RCW. See RCW 18.106.150 for plumbing exceptions for the residential (02) specialty. For the purposes of RCW 18.106.150, the like-in-kind replacement includes the appliance or any component part of the appliance (e.g., such as, but not limited to, the thermostat in a water heater). Specialty (limited) electrical licenses and/or certificates are as follows:

(a) **Residential (02):** Limited to the telecommunications, low voltage, and line voltage wiring of one- and two-family dwellings, or multifamily dwellings not exceeding three stories above grade. All wiring is limited to nonmetallic sheathed cable, except for services and/or feeders, exposed installations where physical protection is required, and for wiring buried below grade.

- (i) This specialty also includes the wiring for ancillary structures such as, but not limited to:
Appliances, equipment, swimming pools, septic pumping systems, domestic water systems, limited energy systems (e.g., doorbells, intercoms, fire alarm, burglar alarm, energy control, HVAC/refrigeration, etc.), multifamily complex offices/garages, site lighting when supplied from the residence or ancillary structure, and other structures directly associated with the functionality of the residential units.
- (ii) This specialty does not include wiring occupancies defined in WAC [296-46B-900\(1\)](#), or commercial occupancies such as: Motels, hotels, offices, assisted living facilities, or stores.
- (iii) See RCW 18.106.150 for plumbing exceptions for the residential (02) specialty.

(b) **Pump and irrigation (03):** Limited to the electrical connection of circuits, feeders, controls, low voltage, related telecommunications, and services to supply: Domestic water systems and public water systems include but are not limited to pumps, pressurization, filtration, treatment, or other equipment and controls, and irrigation water pumps, circular irrigating system's pumps and pump houses.

This specialty may also perform the work defined in (c) of this subsection.

Also see RCW [18.106.010\(10\)\(c\)](#).

(c) **Domestic pump (03A):** Limited to the extension of a branch circuit, which is supplied and installed by others, to signaling circuits, motor control circuits, motor control devices, and pumps which do not exceed 7 1/2 horsepower at 250 volts AC single phase input power, regardless of motor controller output or motor voltage/phase, used in residential potable water or residential sewage disposal systems. Domestic water systems and public water systems include but are not limited to pumps, pressurization, filtration, treatment, or other equipment and controls.

Also see RCW 18.106.010(10)(c).

(d) **Signs (04):** Limited to placement and connection of signs and outline lighting, the electrical supply, related telecommunications, controls and associated circuit extensions thereto; and the installation of a maximum 60 ampere, 120/240 volt single phase service to supply power to a remote sign only. This specialty may service, maintain, or repair exterior luminaires that are mounted on a pole or other structure with like-in-kind components.

- (i) Electrical licensing/certification is not required to:
 - (A) Clean the nonelectrical parts of an electric sign;
 - (B) Form or pour a concrete pole base used to support a sign;

(C) Operate machinery used to assist an electrician in mounting an electric sign or sign supporting pole; or

(D) Assemble the structural parts of a billboard.

(ii) Electrical licensing/certification is required to: Install, modify, or maintain a sign, sign supporting pole, sign face, sign ballast, lamp socket, lamp holder, disconnect switch, or any other part of a listed electric sign.

(e) **Limited energy system (06):** Limited to the installation of signaling and power limited circuits and related equipment. This specialty is restricted to low-voltage circuits. This specialty includes the installation of telecommunications, HVAC/refrigeration low-voltage wiring, fire protection signaling systems, intrusion alarms, energy management and control systems, industrial and automation control systems, lighting control systems, commercial and residential amplified sound, public address systems, and such similar low-energy circuits and equipment in all occupancies and locations.

(i) For the purposes of this section, when a line voltage connection is removed and reconnected to a replacement component located inside the control cabinet, the replacement must be like-in-kind or replaced using the equipment manufacturer's authorized replacement component. The line voltage circuit is limited to 120 volts 20 amps maximum and must have a means of disconnect.

(ii) The limited energy systems (06) specialty may repair or replace line voltage connections terminated inside the cabinet to power supplies internal to the low voltage equipment provided there are no modifications to the characteristics of the branch circuit/feeder load being supplied by the circuit.

(iii) The limited energy systems (06) specialty may not replace or modify the line voltage circuit or cabling or alter the means of connection of the line voltage circuit to the power supply or to the control cabinet.

Limited energy electrical contractors may perform all telecommunications work under their specialty (06) electrical license and administrator's certificate.

(f) **HVAC/refrigeration systems:**

(i) See WAC [296-46B-100](#) for specific HVAC/refrigeration definitions.

(ii) For the purposes of this section when a component is replaced, the replacement must be like-in-kind or made using the equipment manufacturer's authorized replacement component.

(iii) The HVAC/refrigeration specialties described in (f)(v) and (vi) of this subsection may:

(A) Install HVAC/refrigeration: Telecommunications, Class 2 low-voltage control circuit wiring/components in all residential occupancies;

(B) Install, repair, replace, and maintain line voltage components within HVAC/refrigeration equipment. Such line voltage components include product illumination luminaires installed within and powered from the HVAC/refrigeration system (e.g., reach-in beverage coolers, frozen food cases, produce cases, etc.) and new or replaced factory authorized accessories such as internally mounted outlets;

(C) Repair, replace, or maintain the internal components of the HVAC/refrigeration equipment disconnecting means or controller so long as the disconnecting means or controller is not located within a motor control center or panelboard;

(D) Install, repair, replace, and maintain short sections of raceway to provide physical protection for low-voltage cables. For the purposes of this section a short section cannot mechanically interconnect two devices, junction boxes, or other equipment or components; and

(E) Repair, replace, or maintain line voltage flexible supply whips not over six feet in length, provided there are no modifications to the characteristics of the branch circuit/feeder load being supplied by the whip. There is no limitation on the whip raceway method (e.g., metallic replaced by nonmetallic).

(iv) The HVAC/refrigeration specialties described in (f)(v) and (vi) of this subsection may not:

(A) Install line voltage controllers or disconnect switches external to HVAC/refrigeration equipment;

(B) Install, repair, replace, or maintain:

- Integrated building control systems, other than HVAC/refrigeration systems;
- Single stand-alone line voltage equipment or components (e.g., heat cable, wall heaters, radiant panel heaters, baseboard heaters, contactors, motor starters, and similar equipment) unless the equipment or component:

- Is exclusively controlled by the HVAC/refrigeration system and requires the additional external connection to a mechanical system(s) (e.g., connection to water piping, gas piping, refrigerant system, ducting for the HVAC/refrigeration system, gas fireplace flume, ventilating systems, etc. (i.e., as in the ducting connection to a bathroom fan)). The external connection of the equipment/component to the mechanical system must be required as an integral component allowing the operation of the HVAC/refrigeration system; or
 - Contains a HVAC/refrigeration mechanical system(s) (e.g., water piping, gas piping, refrigerant system, etc.) within the equipment (e.g., "through-the-wall" air conditioning units, self-contained refrigeration equipment, etc.);
- Luminaires that serve as a building or structure lighting source, even if mechanically connected to a HVAC/refrigeration system (e.g., troffer luminaire used as a return air device, lighting within a walk-in cooler/freezer used for personnel illumination);
- Raceway/conduit systems;
- Line voltage: Service, feeder, or branch circuit conductors. However, if a structure's feeder/branch circuit supplies HVAC/refrigeration equipment containing a supplementary overcurrent protection device(s), this specialty may install the conductors from the supplementary overcurrent device(s) to the supplemental HVAC/refrigeration equipment if the supplementary overcurrent device and the HVAC/refrigeration equipment being supplied are located within sight of each other; or
- Panelboards, switchboards, or motor control centers external to HVAC/refrigeration system.

(v) HVAC/refrigeration (06A):

- (A) This specialty is not limited by voltage, phase, or amperage.
- (B) No unsupervised electrical trainee can install, repair, replace, or maintain any part of a HVAC/refrigeration system that contains any circuit rated over 600 volts whether the circuit is energized or deenergized.
- (C) This specialty may:
 - Install HVAC/refrigeration: Telecommunications, Class 2 low-voltage control circuit wiring/components in other than residential occupancies:
 - That have no more than three stories on/above grade; or
 - Regardless of the number of stories above grade if the installation:
 - Does not pass between stories;
 - Is made in a previously occupied and wired space; and
 - Is restricted to the HVAC/refrigeration system;
 - Repair, replace, and maintain HVAC/refrigeration: Telecommunications, Class 2 low-voltage control circuit wiring/components in all occupancies regardless of the number of stories on/above grade.
 - Install a bonding conductor for metal gas piping to an existing accessible grounding electrode conductor or grounding electrode only when terminations can be made external to electrical panelboards, switchboards, or other distribution equipment.
- (D) This specialty may not install, repair, replace, or maintain: Any electrical wiring governed under article(s) 500, 501, 502, 503, 504, 505, 510, 511, 513, 514, 515, or 516 NEC (i.e., classified locations) located outside the HVAC/refrigeration equipment.

(vi) HVAC/refrigeration restricted (06B):

- (A) This specialty may not perform any electrical work where the primary electrical power connection to the HVAC/refrigeration system exceeds: 250 volts, single phase, or 120 amps.

(B) This specialty may install, repair, replace, or maintain HVAC/refrigeration:
Telecommunications, Class 2 low-voltage control circuit wiring/components in other than residential occupancies that have no more than three stories on/above grade.

(C) This specialty may not install, repair, replace, or maintain:

- The allowed telecommunications/low-voltage HVAC/refrigeration wiring in a conduit/raceway system; or
- Any electrical work governed under article(s) 500, 501, 502, 503, 504, 505, 510, 511, 513, 514, 515, or 516 NEC (i.e., classified locations).

(g) **Nonresidential maintenance (07):** Limited to maintenance, repair and replacement of like-in-kind existing electrical equipment and conductors. This specialty does not include maintenance activities in residential dwellings defined in (a) of this subsection for the purposes of accumulating training experience toward qualification for the residential (02) specialty electrician examination.

(i) This specialty includes the installation and connections of temporary conductors and equipment for the purpose of load testing, not to exceed 600 Volts.

(ii) This specialty may perform the work defined in (h), (i), (j), (k), and (l) of this subsection.

(h) **Nonresidential lighting maintenance and lighting retrofit (07A):** Limited to working within the housing of existing nonresidential luminaires for work related to repair, service, maintenance of luminaires and installation of energy efficiency lighting retrofit upgrades. This specialty includes replacement of lamps, ballasts, sockets and the installation of listed lighting retrofit reflectors and kits. All work is limited to the luminaire body, except remote located ballasts may be replaced or retrofitted with approved products. This specialty does not include installing new luminaires or branch circuits; moving or relocating existing luminaires; or altering existing branch circuits.

(i) **Residential maintenance (07B):** This specialty is limited to residential dwellings as defined in WAC 296-46B-920 (2)(a), multistory dwelling structures with no commercial facilities, and the interior of dwelling units in multistory structures with commercial facilities. This specialty may maintain, repair, or replace (like-in-kind) existing electrical utilization equipment, and all permit exempted work as defined in WAC 296-46B-901.

This specialty is limited to equipment and circuits to a maximum of 250 volts, 60 amperes, and single phase maximum.

This specialty may disconnect and reconnect low-voltage control and line voltage supply whips not over six feet in length provided there are no modifications to the characteristics of the branch circuit or whip.

For the purpose of this specialty, "electrical equipment" does not include electrical conductors, raceway or conduit systems external to the equipment or whip. This specialty cannot perform any plumbing work regulated under chapter [18.106](#) RCW.

(j) **Restricted nonresidential maintenance (07C):** This specialty may maintain, repair, or replace (like-in-kind) existing electrical utilization equipment, and all permit exempted work as defined in WAC [296-46B-901](#) except for the replacement or repair of circuit breakers.

This specialty is limited to equipment and circuits to a maximum of 277 volts and 20 amperes for lighting branch circuits only and/or maximum 250 volts and 60 amperes for other circuits. The replacement of luminaires is limited to in-place replacement required by failure of the luminaire to operate. Luminaires installed in suspended lay-in tile ceilings may be relocated providing: The original field installed luminaire supply whip is not extended or relocated to a new supply point; or if a manufactured wiring assembly supplies luminaire power, a luminaire may be relocated no more than eight feet providing the manufactured wiring assembly circuiting is not changed.

This specialty may disconnect and reconnect low-voltage control and line voltage supply whips not over six feet in length provided there are no modifications to the characteristics of the branch circuit. For the purpose of this specialty, "electrical equipment" does not include electrical conductors, raceway or conduit systems external to the equipment or whip.

This specialty may perform the work defined in (h) and (i) of this subsection.

This specialty cannot perform any work governed under Article(s) 500, 501, 502, 503, 504, 505, 510, 511, 513, 514, 515, or 516 NEC (i.e., classified locations). This specialty cannot perform any plumbing work regulated under chapter [18.106](#) RCW.

(k) **Appliance repair (07D):** Servicing, maintaining, repairing, or replacing household appliances, small commercial/industrial appliances, and other small electrical utilization equipment.

(i) For the purposes of this subsection:

(A) The appliance or electrical utilization equipment must be self-contained and built to standardized sizes or types. The appliance/equipment must be connected as a single

unit to a single source of electrical power limited to a maximum of 250 volts, 60 amperes, single phase.

- (B) Appliances and electrical utilization equipment include, but are not limited to: Ovens, office equipment, vehicle repair equipment, commercial kitchen equipment, self-contained hot tubs and spas, grinders, and scales.
- (C) Appliances and utilization equipment do not include systems and equipment such as: Alarm/energy management/similar systems, luminaires, furnaces/heaters/air conditioners/heat pumps, sewage disposal equipment, door/gate/similar equipment, or individual components installed so as to create a system (e.g., pumps, switches, controllers, etc.).

(ii) This specialty includes:

- (A) The in-place like-in-kind replacement of the appliance or equipment if the same unmodified electrical circuit is used to supply the equipment being replaced. This specialty also includes the like-in-kind replacement of electrical components within the appliance or equipment;
- (B) The disconnection and reconnection of low-voltage control and line voltage supply whips not over six feet in length provided there are no modifications to the characteristics of the branch circuit; and
- (C) The installation of an outlet box and outlet at an existing appliance or equipment location when converting the appliance from a permanent electrical connection to a plug and cord connection. Other than the installation of the outlet box and outlet, there can be no modification to the existing branch circuit supplying the appliance or equipment.

(iii) This specialty does not include:

- (A) The installation, repair, or modification of branch circuits conductors, services, feeders, panelboards, disconnect switches, or raceway/conductor systems interconnecting multiple appliances, equipment, or other electrical components.
- (B) Any work governed under Article(s) 500, 501, 502, 503, 504, 505, 510, 511, 513, 514, 515, or 516 NEC (i.e., classified locations).
- (C) Any plumbing work regulated under chapter [18.106](#) RCW.

(l) **Equipment repair (07E):** Servicing, maintaining, repairing, or replacing utilization equipment.

See RCW [19.28.095](#) for the equipment repair scope of work and definitions. This specialty cannot perform any plumbing work regulated under chapter [18.106](#) RCW.

(m) **Telecommunications (09):** Limited to the installation, maintenance, and testing of telecommunications systems, equipment, and associated hardware, pathway systems, and cable management systems.

(i) This specialty includes:

- (A) Installation of open wiring systems of telecommunications cables.
- (B) Surface nonmetallic raceways designated and used exclusively for telecommunications.
- (C) Optical fiber innerduct raceway.
- (D) Underground raceways designated and used exclusively for telecommunications and installed for additions or extensions to existing telecommunications systems not to exceed fifty feet inside the building.
- (E) Incidental short sections of circular or surface metal raceway, not to exceed ten feet, for access or protection of telecommunications cabling and installation of cable trays and ladder racks in telecommunications service entrance rooms, spaces, or closets.
- (F) Audio or paging systems where the amplification is integrated into the telephone system equipment.
- (G) Audio or paging systems where the amplification is provided by equipment listed as an accessory to the telephone system equipment and requires the telephone system for the audio or paging system to function.
- (H) Closed circuit video monitoring systems if there is no integration of line or low-voltage controls for cameras and equipment. Remote controlled cameras and equipment are considered (intrusion) security systems and must be installed by appropriately licensed electrical contractors and certified electricians.
- (I) Customer satellite and conventional antenna systems receiving a telecommunications service provider's signal. All receiving equipment is on the customer side of the telecommunications network demarcation point.

(ii) This specialty does not include horizontal cabling used for fire protection signaling systems, intrusion alarms, access control systems, patient monitoring systems, energy management

control systems, industrial and automation control systems, HVAC/refrigeration control systems, lighting control systems, and stand-alone amplified sound or public address systems. Telecommunications systems may interface with other building signal systems including security, alarms, and energy management at cross-connection junctions within telecommunications closets or at extended points of demarcation. Telecommunications systems do not include the installation or termination of premises line voltage service, feeder, or branch circuit conductors or equipment. Horizontal cabling for a telecommunications outlet, necessary to interface with any of these systems outside of a telecommunications closet, is the work of the telecommunications contractor.

(n) **Door, gate, and similar systems (10):** This specialty may install, service, maintain, repair, or replace door/gate/similar systems electrical operator wiring and equipment.

- (i) For the purposes of this subsection, door/gate/similar systems electrical operator systems include electric gates, doors, windows, awnings, movable partitions, curtains and similar systems. These systems include, but are not limited to: Electric gate/door/similar systems operators, control push buttons, key switches, key pads, pull cords, air and electric treadle, air and electric sensing edges, coil cords, take-up reels, clocks, photo electric cells, loop detectors, motion detectors, remote radio and receivers, antenna, timers, lock-out switches, stand-alone release device with smoke detection, strobe light, annunciator, control panels, wiring and termination of conductors.
- (ii) This specialty includes:
 - (A) Low-voltage, NEC Class 2, door/gate/similar systems electrical operator systems where the door/gate/similar systems electrical operator system is not connected to other systems.
 - (B) Branch circuits originating in a listed door/gate/similar systems electric operator control panel that supplies only door/gate/similar systems system components providing: The branch circuit does not exceed 600 volts, 20 amperes and the component is within sight of the listed door/gate/similar systems electric operator control panel.
 - (C) Reconnection of line voltage power to a listed door/gate/similar systems electric operator control panel is permitted provided:
 - There are no modifications to the characteristics of the branch circuit/feeder;
 - The circuit/feeder does not exceed 600 volts, 20 amperes; and
 - The conductor or conduit extending from the branch circuit/feeder disconnecting means or junction box does not exceed six feet in length.
- (iii) This specialty does not include any work governed under Article(s) 500, 501, 502, 503, 504, 505, 510, 511, 513, 514, 515, or 516 NEC (i.e., classified locations). This specialty may not install, repair, or replace branch circuit (line voltage) conductors, services, feeders, panelboards, or disconnect switches supplying the door/gate/similar systems electric operator control panel.

(3) A specialty electrical contractor, other than the (06) limited energy specialty electrical contractor, may only perform telecommunications work within the equipment or occupancy limitations of their specialty electrical contractor's license. Any other telecommunications work requires a telecommunications contractor's license.

WAC 296-46B-925 Electrical/telecommunications contractor's license.

General.

(1) The department will issue an electrical/telecommunications contractor's license that will expire twenty-four months following the date of issue to a person, firm, partnership, corporation or other entity that complies with requirements for such license in chapter [19.28](#) RCW. An electrical/telecommunications contractor's license will not be issued to or renewed for a person, firm, or partnership unless the Social Security number, date of birth, and legal address of each member(s) (see WAC [296-46B-100](#) definition for member), are submitted with the application. The department may issue an electrical/telecommunications contractor's license for a period greater or less than twenty-four months for the purpose of equalizing the number of electrical contractor's licenses that expire each month. The department may prorate the electrical/telecommunications contractor's license fee according to the license period.

The applicant, upon application and renewal, must provide the department with the Social Security number, date of birth, and legal address of each member(s).

(2) Combination specialty contractor's license. The department may issue a combination specialty contractor's license to a firm that qualifies for more than one specialty electrical contractor's license. The assigned administrator must be certified in all specialties applicable to the combination specialty contractor's license. The license will plainly indicate the specialty licenses' codes included in the combination license. An administrator assigned to a telecommunications contractor must be certified as a telecommunications administrator. A combination license will not be issued for telecommunications (09).

(3) See RCW [19.28.041](#)(7) for a contractor doing domestic pumping work as defined in RCW [18.106.010](#)(10)(c).

(4) The department may deny application, renewal, change of assignment of administrator/master electrician, reinstatement, or issuance of an electrical/telecommunications contractor's license if a firm, an owner, partner, member, or corporate officer owes money as a result of an outstanding final judgment(s) under chapter 19.28 RCW.

Electrical/telecommunications contractor bond, cash or securities deposit.

(5) Bond, cash, or securities deposit.

(a) The electrical/telecommunications contractor may furnish the department with a cash or security deposit to meet the bond requirements in lieu of posting a bond. A cash or security deposit assigned to the department for bond requirements will be held in place for one year after the contractor's license is expired, revoked, or the owner notifies the department in writing that the company is no longer doing business in the state of Washington as an electrical/telecommunications contractor. Upon written request, the cash or security deposit will then be released by the department providing there is no pending legal action against the contractor under chapter [19.28](#) RCW of which the department has been notified.

(b) See RCW [19.28.041](#)(7) for a contractor doing domestic pumping work as defined in RCW [18.106.010](#)(10)(c).

Telecommunications contractor insurance.

(6) To obtain a telecommunications contractor's license, the applicant must provide the department with an original certificate of insurance naming the department of labor and industries, electrical section as the certificate holder. Insurance coverage must be no less than twenty thousand dollars for injury or damages to property, fifty thousand dollars for injury or damage including death to any one person, and one hundred thousand dollars for injury or damage including death to more than one person. The insurance will be considered a continuing obligation unless canceled by the insurance company. The insurance company must notify the department in writing ten days prior to the effective date of said cancellation or failure to renew.

(7) The telecommunications contractor may furnish the department with an assigned account to meet the insurance requirements in lieu of a certificate of insurance. An account assigned to the department for insurance requirements will be held in place for three years after the contractor's license is expired, revoked, or the owner notifies the department in writing that the company is no longer doing business in the state of Washington as a telecommunications contractor. Upon written request, the account then will be released by the department providing there is no pending legal action against the contractor under chapter [19.28](#) RCW of which the department has been notified.

Electrical/telecommunications contractor exemptions.

(8) The following types of systems and circuits are considered exempt from the requirements for licensing and permitting described in chapter [19.28](#) RCW. The electrical failure of these systems does not inherently or functionally compromise safety to life or property.

Low-voltage thermocouple derived circuits and low-voltage circuits for:

- (a) Built-in residential vacuum systems;
- (b) Underground landscape sprinkler systems;
- (c) Underground landscape lighting; and
- (d) Residential garage doors.

For these types of systems and circuits to be considered exempt, the following conditions must be met:

- (e) The power supplying the installation must be derived from a listed Class 2 power supply;
- (f) The installation and termination of line voltage equipment and conductors supplying these systems is performed by appropriately licensed and certified electrical contractors and electricians;
- (g) The conductors of these systems do not pass through fire-rated walls, fire-rated ceilings or fire-rated floors in other than residential units; and
- (h) Conductors or luminaires are not installed in installations covered by the scope of Article 680 NEC (swimming pools, fountains, and similar installations).

(9) Firms who clean and/or replace lamps in luminaires are not included in the requirements for licensing in chapter [19.28](#) RCW. This exemption does not apply to electric signs as defined in the NEC.

(10) Firms who install listed plug and cord connected utilization equipment are not included in the requirements for licensing in chapter [19.28](#) RCW. The plug and cord must be a single listed unit consisting of a molded plug and cord and not exceeding 250 volt 60 ampere single phase. The plug and cord can be field installed per the manufacturer's instructions and the product listing requirements. The utilization equipment must be a single manufactured unit, including the plug and cord, that does not require any electrical field assembly except for the installation of the plug and cord and is allowed to be plug and cord connected by the NEC. Firms who perform field electrical servicing, maintaining, or repairing of plug and cord connected utilization equipment other than household appliances are not included in this exemption.

(11) Firms regulated by the Federal Communications Commission or the utilities and transportation commission, supplying telecommunications service to an end-user's property, are not required to be licensed as a telecommunications contractor under chapter [19.28](#) RCW for telecommunications installations made ahead of the telecommunications network demarcation point.

(12) Unregulated firms, supplying telecommunications service to an end-user's property, are not required to be licensed as a telecommunications contractor under chapter [19.28](#) RCW for telecommunications installations made ahead of the telecommunications network demarcation point.

(13) Leaseholders. For electrical installations, maintenance, or alterations to existing buildings only, any person, firm, partnership, corporation, or other entity holding a valid, signed lease from the property owner authorizing the leaseholder to perform electrical work, on the property the leaseholder occupies, will be allowed to purchase an electrical permit(s) and do electrical work on or within the property described in the lease. The lessee and/or his or her regularly employed employees must perform the electrical installation, maintenance and alteration.

The lessee who performs the electrical maintenance or installation work must be the sole occupant of the property or space. Property owners or leaseholders cannot perform electrical work on new buildings for rent, sale, or lease, without the proper electrical licensing and certification. Refer to RCW [19.28.261](#) for exemptions from licensing and certification.

(14) Assisting a householder. A friend, neighbor, relative, or other person (including a certified electrician) may assist a householder, at his/her residence in the performance of electrical work on the condition that the householder is present when the work is performed and the person assisting the householder does not accept money or other forms of compensation for the volunteer work. For the purposes of this subsection, a residence is a single-family residence.

(15) Volunteering to do electrical work. There are no exceptions from the electrical contractor's license or electrician certification requirements to allow persons to perform volunteer electrical work for anyone other than a householder or a nonprofit organization as allowed by RCW [19.28.091](#)(7). For the purpose of this section, volunteer means that there is no remuneration or receiving of goods or services in return for electrical installations performed.

(16) Farms or place of business. See RCW [19.28.261](#) for licensing/certification exemptions allowed for the owner(s) of a farm or other place of business and for the employees of the owner.

(17) The licensing and certification requirements of chapter 19.28 RCW do not apply to persons or firms who remove electrical wiring and/or equipment for the purpose of disposal when all conductors, raceways, and equipment to be disposed of have been physically separated from the source of power by a properly certified electrician employed by

a licensed electrical contractor, or person(s) meeting the exemptions listed in RCW 19.28.261. Removal of a component or only a portion of an equipment unit is considered electrical maintenance and does not qualify for this exemption.

Exemptions - Electrical utility and electrical utility's contractor.

(18) Electrical utility exemptions.

- (a) Utility system exemption – RCW [19.28.010](#)(1) and RCW [19.28.091](#)(1).
 - (i) Neither a serving electrical utility nor a contractor or subcontractor employed by the serving electrical utility is required to have an electrical contractor's license for work on the "utility system" or on service connections or on meters or other apparatus used to measure the consumption of electricity.
 - (ii) Exemption from inspection. The work of a serving electrical utility and its contractor(s) on the work exempted by NEC 90.2 (b)(5), 1981 edition, is not subject to inspection.
- (b) Street/area lighting exemption – RCW [19.28.091](#)(2)(a).
 - (i) On:
 - (A) Publicly owned streets, parks, athletic/play fields, beaches, and similar areas where the public has general, clear, and unrestricted access; or
 - (B) Outside area lighting installed on a utility owned pole(s) that is used to support the utility's electric distribution wiring or equipment that supplies a private property owner's property, the serving electrical utility is considered to be an owner and is not required to have an electrical contractor's license or electrical permit to install or work on wiring or equipment, owned by the utility and used in the lighting of those streets/areas.
 - (ii) On other privately or publicly owned property (e.g., private streets, parking lots, businesses, schools, etc.), the serving utility is not required to have an electrical contractor's license or electrical permit to install or work on outside street/area lighting where the light(s) is supplied directly from the utility system and installed according to the NESC or NEC.
This work is considered to be utility type work.

An electric utility is not allowed to install or work on street/area lighting:

- (A) When the area is privately or publicly owned and the public does not have general, clear, and otherwise unrestricted access such as: Industrial property, residential property, or other property where the public's access is restricted in any manner.
- (B) Where the lighting is supplied from a source of power derived from a customer-owned electrical system.
- (C) Where the lighting or wiring is attached to a building or other customer owned structure.
- (D) If the utility does not directly perform the installation or work, it may only contract the work to an appropriately licensed electrical contractor(s). See RCW [19.28.091](#)(3).

- (c) Customer-owned equipment exemption – RCW [19.28.091](#)(2)(b). A serving electrical utility is not required to have an electrical contractor's license to work on electrical equipment owned by a commercial, industrial, or public institution customer if:
 - (i) The utility has not solicited such work; and
 - (ii) Such equipment:
 - (A) Is located outside a building or structure; and
 - (B) The work performed is ahead of the secondary side of the customer's transformer(s) which supplies power at the customer's utilization voltage.

If the utility does not directly perform the installation or work, it may only contract the work to an appropriately licensed electrical contractor(s). See RCW [19.28.091](#)(3).

This work is considered to be utility type work.

The owner will provide the electrical work permit and be responsible for requesting inspections and for ensuring the work is installed per chapter [19.28](#) RCW and this chapter.

Exemptions - Electrical utility telecommunications transition equipment installations, maintenance and repair.

(19) No license, inspection or other permit will be required by the department of any electric utility or, of any person, firm, partnership or corporation or other entity employed or retained by an electric utility or its contractor, because of work in connection with the installation, maintenance, or repair of telecommunications transition equipment located ahead of the utility's telecommunications network demarcation point on the outside of a building or other structure when the work is performed by a qualified person consistent with the requirements of the National Electric Code (NEC) except as provided in (a) and (b) of this subsection:

(a) The following exceptions to the NEC will be permitted:

- (i) An additional service disconnect supplying power to the transition equipment can be connected on the supply side of the main service disconnect supplying general power to the building;
- (ii) Service entrance disconnects may be separated when clearly labeled;
- (iii) The service disconnect used for supplying power to the transition equipment must be connected to the grounding electrode system using:
 - (A) # 8 AWG copper or larger grounding electrode conductor if protected from physical damage; or
 - (B) # 6 AWG copper or larger grounding electrode conductor if not protected from physical damage;
- (iv) Use of equipment or materials that have been listed/field evaluated by a recognized independent testing laboratory or the department;
- (v) Low-voltage circuits do not require a separate disconnecting means and may be grounded to the transition equipment grounding system;
- (vi) Any other variance to the NEC must be approved by the department.

(b) A variance recommended by a joint utility standards group composed of representatives of both public and private utilities or certified by a professional engineer will be approved by the department unless the recommendation is inconsistent with meeting equivalent objectives for public safety.

(c) For the purposes of this section, a qualified worker is employed by a utility or its contractor and is familiar with the construction or operation of such lines and/or equipment that concerns his/her position and who is proficient with respect to the safety hazards connected therewith, or, one who has passed a journey status examination for the particular branch of the electrical trades with which he/she may be connected or is in a recognized training or apprenticeship course and is supervised by a journey level person.

(d) Although the utility is responsible for inspection and approval of the installation, including the selection of material and equipment, the department reserves the right to audit worker qualifications and inspect such installations semiannually for conformance with the requirements of (a), (b) and (c) of this subsection but will not collect a permit fee for such inspection or audit.

(e) If a utility fails to meet the requirements of this section, the department may require the utility to develop and submit a remedial action plan and schedule to attain compliance with this section which may be enforced by the department.

(f) This exemption will be in addition to any other exemption provided in chapter [19.28](#) RCW, this chapter or other applicable law.

Exemptions - Independent electrical power production equipment exemption.

(20) An independent electrical power production entity is not required to have an electrical contractor's license to work on electrical equipment used to produce or transmit electrical power if:

(a) The entity is:

- (i) The owner or operator of the generating facility is regulated by the Federal Energy Regulatory Commission (FERC);
- (ii) A municipal utility, or other form of governmental electric utility, or by an electrical cooperative or mutual corporation; or
- (iii) The owner or operator of the generating facility is an independent electrical power producer and the facility generates electrical power only for sale to one or more:
 - (A) Electrical utilities regulated by FERC, municipal utility, or other form of governmental utility, or to an electric cooperative or mutual corporation; and
 - (B) The electrical power generated by the facility is not used for self-generation or any other on- or off-site function other than sale to one or more utilities regulated by FERC or by one or more state public utilities commissions, or to a PUD, municipal utility, or other form of governmental electric utility, or to an electric cooperative or mutual corporation.

- (b) The entity must supply the chief electrical inspector a valid master business license issued by the department of licensing, state of Washington so that the entity's status as a revenue generating business can be confirmed.
- (c) The entity has entered into an agreement to sell electricity to a utility or to a third party; and
- (d) The electrical equipment is used to transmit electricity from the terminals of an electrical generating unit located on premises to the point of interconnection with a utility system.
- (e) The electrical power production facility's generation capacity exceeds 100 KVA.
- (f) Notwithstanding that a generating facility may be granted an exemption pursuant to this section, the facility will be subject to all the requirements of chapter [19.28](#) RCW if the facility at any time in the future ceases to comply with the requirements for exemption. All site facilities not exclusively and directly required to generate and/or distribute the electrical power generated on the site are subject to all the licensing and inspection requirements of chapter [19.28](#) RCW. All facility services, feeders, and circuits not exclusively and directly required to generate and/or distribute the electrical power (e.g., lights, outlets, etc.) must comply with all requirements of chapter [19.28](#) RCW for licensing and inspection. Facility circuits supplied to equipment required for the function of generation equipment (e.g., block heaters, power supplies, wind generator tower circuits, etc.) must comply with all requirements of chapter [19.28](#) RCW for licensing and inspection up to and including the equipment termination point.
- (g) The generation equipment must not be mounted on or in any building or structure not required for generation of power (e.g., schools, offices, residences, apartment buildings, hospitals, etc.).

Exemptions - Telegraph and telephone utility and telegraph and telephone utility's contractor.

- (21) Telegraph and telephone utility exempted equipment and installations. No person, firm, partnership, corporation, or other entity is required to have an electrical contractor's license for work on electrical equipment and installations thereof that are exempted by RCW [19.28.151](#). For the purposes of this exemption, "building or buildings used exclusively for that purpose" may mean any separate building or space of a building where the space is separated from the remainder of the building by a two-hour fire wall. The telecommunications or telegraph equipment within such a space must supply telephone or telegraph service to other customer's buildings (i.e., telecommunications or telegraph equipment cannot solely supply the building containing the telephone/telegraph space).

Exemptions - Manufacturers of electrical/telecommunications products.

- (22) Manufacturers of electrical/telecommunications systems products will be allowed to utilize a manufacturer's authorized factory-trained technician to perform initial calibration, testing, adjustment, modification incidental to the startup and checkout of the equipment, or replacement of components within the confines of the specific product, without permit or required licensing:
 - (a) Provided the product:
 - (i) Has not been previously energized;
 - (ii) Has been recalled by the Consumer Product Safety Commission;
 - (iii) Is within the manufacturer's written warranty period, a period not to exceed one year from date of original installation of the new product; or
 - (iv) The manufacturer is working under the written request and supervision of an appropriately licensed electrical contractor.
 - (b) Except for the replacement of individual components, as allowed above, this exemption does not include the initial installation, removal, or replacement of the electrical product. Modifications to the equipment, as designated above, must not include any changes to the original intended configuration nor changes or contact with external or field-connected components or wiring.
 - (c) The manufacturer will be responsible for obtaining any required reapproval/recertification from the original listing or field evaluation laboratory.
 - (d) The manufacturer must notify the department if any modifications have been made or reapproval/recertification is required.

Premanufactured electric power generation equipment assemblies and control gear.

- (23) Premanufactured electric power generation equipment assemblies and control gear.
 - (a) Manufacturers of premanufactured electric power generation equipment assemblies and control gear will be allowed to utilize a manufacturer's authorized factory-trained technician to perform initial calibration, testing, adjustment, modification incidental to the startup and checkout of the equipment, or replacement of components within the confines of the specific product, without permit or required licensing, provided:

- (i) For transfer equipment, the product has not been previously energized or is within the manufacturer's written warranty period;
- (ii) Modifications to the equipment, as designated above, must not include any changes to the original intended configuration nor changes or contact with external or field-connected components or wiring;
- (iii) The manufacturer will be responsible for obtaining any required reapproval/recertification from the original listing or field evaluation laboratory; or
- (iv) The manufacturer must notify the department if any modifications have been made or reapproval/recertification is required.

(b) Premanufactured electric power generation equipment assemblies are made up of reciprocating internal combustion engines and the associated control gear equipment. Control gear equipment includes control logic, metering, and annunciation for the operation and the quality of power being generated by the reciprocating internal combustion engine and does not have the function of distribution of power.

(c) Modifications of a transfer switch must not include changes to the original intended configuration or changes or contact with externally field-connected components.

(d) For the purposes of this subsection, the following work on premanufactured electric power generation equipment assemblies is not exempt from the requirements of chapter [19.28](#) RCW:

- (i) Installation or connection of conduit or wiring between the power generation unit, transfer switch, control gear;
- (ii) Installation of the transfer switch;
- (iii) Connections between the power generation unit, transfer switch, control gear, and utility's transmission or distribution systems;
- (iv) Connections between the power generation unit, transfer switch, control gear, and any building or structure; or
- (v) Test connections with any part of:
 - (A) The utility's transmission or distribution system; or
 - (B) The building or structure.

(24) The installation, maintenance, or repair of a medical device deemed in compliance with chapter [19.28](#) RCW is exempt from licensing requirements under RCW [19.28.091](#), certification requirements under RCW [19.28.161](#), and inspection and permitting requirements under RCW [19.28.101](#). This exemption does not include work providing electrical feeds into the power distribution unit or installation of conduits and raceways. This exemption covers only those factory engineers or third-party service companies with equivalent training who are qualified to perform such service.

(25) Coincidental electrical/plumbing work. See RCW [19.28.091](#)(8) for the plumber exemption.

(26) Nothing in this section will alter or amend any other exemptions from or requirement for licensure or inspection, chapter [19.28](#) RCW or this chapter.

Photovoltaic equipment.

(27) See WAC [296-46B-690](#) for specific exemptions related to photovoltaic installations.

WAC 296-46B-930 Assignment — Administrator or master electrician.

An administrator or master electrician designated on the electrical/telecommunications contractor's license must be a member of the firm who fulfills the duties of an assigned master electrician/administrator as required in RCW [19.28.061](#)(5), or be a full-time supervisory employee. A member of the firm is defined in [WAC 296-46B-100](#).

In determining whether an individual is a full-time supervisory employee, the department will consider whether the individual is on the electrical/telecommunications contractor's full-time payroll; receives a regular salary or wage similar to other employees; has supervisory responsibility for work performed by the electrical/telecommunications contractor, and carries out the duties shown in chapter [19.28](#) RCW.

WAC 296-46B-935 Administrator certificate.

General.

- (1) The department will deny application, renewal, change of assignment, reinstatement, or issuance of an administrator or master electrician certificate if an individual owes money as a result of an outstanding final judgment(s) under chapter 19.28 RCW.
- (2) For special accommodation see WAC [296-46B-960](#).
- (3) An applicant will not be issued a specialty administrator certificate that is a subspecialty of a certificate the applicant currently holds (i.e., the applicant is not eligible to take the domestic well administrator examination if the applicant currently possesses a pump and irrigation administrator certificate).

Qualifying for examination.

- (4) There are no qualification requirements for taking an administrator certificate examination. Applicants should contact the testing agency directly.

Original - Administrator certificates.

- (5) The scope of work for electrical administrators is described in WAC [296-46B-920](#). The department will issue an original administrator certificate to a general administrator, or specialty administrator who:
 - (a) Successfully completes the appropriate administrator examination; and
 - (b) Submits the appropriate examination passing report from the testing agency with the applicant's: Date of birth, mailing address, and Social Security number; and
 - (c) Pays all appropriate fees as listed in WAC [296-46B-909](#).For an examination report to be considered, all the above must be submitted within ninety days after the completion of the examination. After ninety days, the applicant will be required to successfully retake the complete examination. An individual's original administrator certificate will expire on their birth date at least one year, and not more than three years, from the date of original issue.

Combination - Specialty administrator certificate.

- (6) The department may issue a combination specialty administrator certificate to an individual who qualifies for more than one specialty administrators' certificate. The combination specialty administrators' certificate will plainly indicate the specialty administrator's certificate(s) the holder has qualified for. Telecommunications cannot be issued a combination because the renewal requirements are different from those required for electrical administrators.

Renewal - Administrator certificate.

- (7) An individual must apply for renewal of their administrator certificate on or before the expiration date of the certificate. The individual may not apply for renewal more than ninety days prior to the expiration date. Renewed certificates are valid for three years, with the exception of telecommunications administrators, who will be renewed for two years.
- (8) An individual may renew their administrator certificate within ninety days after the expiration date without reexamination if the individual pays the late renewal fee listed in WAC [296-46B-909](#).
- (9) All renewals received more than ninety days after the expiration date of the certificate will be denied. The administrator will be required to pass the appropriate administrator examination before being recertified.
- (10) All applicants for certificate renewal must:
 - (a) Submit a complete renewal application;
 - (b) Pay all appropriate fees as listed in WAC [296-46B-909](#); and
 - (c) Complete the continuing education requirements described in WAC [296-46B-970](#). Continuing education classes are only valid when all the requirements of WAC 296-46B-970 are completed.

Telecommunications administrators are not required to provide continuing education information.

Continuing education for pump and irrigation (03) and domestic pump (03A) administrators may be comprised of fifty percent electrical and fifty percent plumbing instruction.

(11) An individual who has not completed the required hours of continuing education can renew an administrator's certificate if the individual applies for renewal on or before the certificate expires and pays the appropriate renewal fee. However, the certificate will be placed in an inactive status. When the certificate is placed in inactive status, an assigned administrator will be automatically unassigned from the electrical contractor. The electrical contractor will be notified of the unassignment and has ninety days to replace the administrator. An assignment fee will then be required per WAC [296-46B-909](#).

The inactive certificate will be returned to current status upon validation, by the department, of the required continuing education requirements. If the certificate renewal date occurs during the inactive period, the certificate must be renewed on or before the renewal date to allow the return to current status.

(12) An individual may renew a suspended administrator's certificate by submitting a complete renewal application including obtaining and submitting the continuing education required for renewal. However, the certificate will remain in a suspended status for the duration of the suspension period. Before the suspended administrator's certificate can be activated, the holder must pass the appropriate administrator examination in accordance with RCW 19.28.211(2).

(13) An individual may not renew a revoked administrator's certificate.

WAC 296-46B-940 Electrician/certificate of competency required.

General.

(1) The department will deny application, renewal, reinstatement, or issuance of a certificate or permit if an individual owes money as a result of an outstanding final judgment(s) under chapter 19.28.RCW.

(2) The scope of work for electricians is described in WAC [296-46B-920](#).

Electrician - Certificate of competency required.

(3) To work in the electrical construction trade, an individual must possess, wear, and visibly display on the front of the upper body, a current valid:

- (a) Master journey level electrician certificate of competency issued by the department;
- (b) Journey level electrician certificate of competency issued by the department;
- (c) Master specialty electrician certificate of competency issued by the department;
- (d) Specialty electrician certificate of competency issued by the department; or
- (e) Electrical training certificate, learning the trade in the proper ratio, per RCW [19.28.161](#), under the supervision of a certified master journey level electrician, journey level electrician, master specialty electrician working in their specialty, or specialty electrician working in their specialty.

The certificate may be worn inside the outer layer of clothing when outer protective clothing (e.g., rain gear when outside in the rain, arc flash, welding gear, etc.) is required. The certificate must be worn inside the protective clothing so that when the protective clothing is removed, the certificate is visible. A cold weather jacket or similar apparel is not protective clothing.

The certificate may be worn inside the outer layer of clothing when working in an attic or crawl space or when operating equipment (e.g., drill motor, conduit threading machine, etc.) where wearing the certificate may pose an unsafe condition for the individual.

The certificate must be immediately available for examination at all times.

When working as a certified electrician, the electrician must not display a training certificate.

When supervising a trainee(s), the supervising electrician's certificate must be appropriate for the work being performed by the trainee(s).

Any person working as an electrician or trainee must also possess a government issued photo identification and immediately present that identification when requested by the inspector.

(4) The department issues master electrician and electrician certificates of competency in the following areas of electrical work:

- (a) General journey level (01);

- (b) Specialties:
 - (i) Residential (02);
 - (ii) Pump and irrigation (03);
 - (iii) Domestic pump (03A);
 - (iv) Signs (04);
 - (v) Limited energy system (06);
 - (vi) HVAC/refrigeration (06A);
 - (vii) HVAC/refrigeration - Restricted (06B);
 - (viii) Nonresidential maintenance (07);
 - (ix) Nonresidential lighting maintenance and lighting retrofit (07A);
 - (x) Residential maintenance (07B);
 - (xi) Restricted nonresidential maintenance (07C);
 - (xii) Appliance repair (07D);
 - (xiii) Equipment repair (07E); and
 - (xiv) Door, gate, and similar systems (10).

Original certificates of competency.

- (5) The department will issue an original certificate of competency to master, journey level, or specialty electricians who meet the eligibility requirements listed in:
 - (a) RCW [19.28.191](#) (1)(a) or (b) and chapter [19.28](#) RCW ; and
 - (i) Submit an application for an original master electrician certificate including: Date of birth, mailing address and Social Security number; and
 - (ii) Pay all appropriate fees, as listed in WAC [296-46B-909](#);
 - (b) RCW [19.28.191](#) (1)(d) and (e);
 - (i) Submit an original master electrician certification examination application including: Date of birth, mailing address and Social Security number; and
 - (ii) Pay all appropriate fees, as listed in WAC [296-46B-909](#); or
 - (c) RCW [19.28.191](#) (1)(f) through (g);
 - (i) Submit an original electrician certification examination application including: Date of birth, mailing address and Social Security number; and
 - (ii) Pay all appropriate fees, as listed in WAC [296-46B-909](#).
- (6) An individual's original electrician certificate of competency will expire on their birth date at least two years, and not more than three years, from the date of original issue.

Renewal - Master electrician, journey level, and specialty electrician certificates of competency.

- (7) An individual must apply for renewal of their electrician certificate of competency on or before the expiration date of the certificate. The individual may not apply for renewal more than ninety days prior to the expiration date. Renewed certificates are valid for three years.
- (8) An individual may renew their certificate of competency within ninety days after the expiration date without reexamination if the individual pays the late renewal fee listed in WAC [296-46B-909](#).
- (9) All applications for renewal received more than ninety days after the expiration date of the certificate of competency require that the electrician pass the appropriate competency examination before being recertified.
- (10) All applicants for certificate of competency renewal must:
 - (a) Submit a complete renewal application;
 - (b) Pay all appropriate fees; and
 - (c) Complete the continuing education requirements described in WAC [296-46B-970](#). Continuing education classes are only valid when all the requirements of WAC [296-46B-970](#) are completed.
 Continuing education for pump and irrigation (03) and domestic pump (03A) electricians may be comprised of fifty percent electrical and fifty percent plumbing instruction.
- (11) An individual who has not completed the required hours of continuing education can renew a certificate of competency if the individual applies for renewal before the certificate of competency expires and pays the appropriate renewal fee. However, the certificate of competency will be placed in an inactive status. The inactive certificate of competency will be returned to current status upon validation, by the department, of the required continuing education. If the certificate renewal date occurs during the inactive period, the certificate must be renewed on or before the renewal date to allow the return to current status.
- (12) An individual may renew a suspended certificate of competency by submitting a complete renewal application including obtaining and submitting the continuing education required for renewal. However, the certificate will remain in a suspended status for the duration of the suspension period. Before the suspended certificate of competency can be activated, the holder must pass the appropriate electrician or master electrician competency examination in accordance with RCW 19.28.211(2)

(13) An individual may not renew a revoked certificate of competency.

Exemptions - Lineworker.

- (14) When performing the work described and allowed in WAC [296-46B-925](#)(18)(a) or (b)(i), when employed by the serving utility or its contractor or subcontractor(s), a lineworker is exempt from the requirements of chapter [19.28](#) RCW.
- (15) When performing the work described and allowed in WAC 296-46B-925(18)(b)(ii) or (c), when employed by the serving utility or its licensed electrical contractor or sub contractor(s), a lineworker must meet the requirements of RCW [19.28.261](#)(5)(b) or be an appropriately certified electrician. See the definition of a lineworker in WAC [296-46B-100](#).

Exemptions - Plumbers.

- (16) Coincidental electrical/plumbing work. See RCW [19.28.091](#)(8) for the plumber exemption.

Original - master electrician, journey level, and specialty electrician certificates of competency.

WAC 296-46B-942 Training certificate required.

General.

- (1) To work in the electrical construction trade as an electrical trainee, an individual must possess, wear, and visibly display a current valid electrical training certificate, learning the trade in the proper ratio, per RCW [19.28.161](#), under the supervision of a certified master journey level electrician, journey level electrician, master specialty electrician working in their specialty, or specialty electrician working in their specialty.
The trainee must meet all the requirements of WAC [296-46B-940](#) related to visibly displaying a current certificate and having a valid photo identification on his/her person.
- (2) An active training certificate is required for all individuals throughout the individual's enrollment and matriculation in an approved construction electrician training school program described in RCW [19.28.191](#). A training certificate is required to work in the electrical construction trade if an individual does not:
 - (a) Possess a current journey level certificate of competency issued by the department;
 - (b) Possess a current specialty electrician certificate of competency issued by the department while working in that specialty's scope of work; or
 - (c) Is not working in exempt status as allowed by chapter [19.28](#) RCW.
- (3) Trainees who have had their training certificates revoked or suspended (during the duration of the revocation or suspension) will not be issued a training certificate.

Original training certificates.

- (4) The department will issue an original training certificate when the trainee applicant submits a complete training certificate application including:
 - (a) Date of birth, mailing address, Social Security number; and
 - (b) All appropriate fees as listed in WAC [296-46B-909](#).All applicants for an electrical training certificate must be at least sixteen years of age. The original training certificate will be valid for two years.
If an individual has previously held an electrical training certificate, then that individual is not eligible for a subsequent original training certificate.

Specialty specific – Zero percent and seventy-five percent supervision modified training certificates.

- (5) For specialties as allowed in Table 945-1 (i.e., specialties with seven hundred twenty minimum hours of work experience required to be eligible for examination):
 - (a) The department will approve the trainee to take the appropriate specialty competency examination necessary to qualify for a zero percent supervision modified training certificate. To qualify, the trainee

applicant must submit a complete zero percent supervision modified training certificate application including:

- (i) Date of birth, mailing address, Social Security number;
- (ii) Affidavit of experience fulfilling the minimum work experience hours required to qualify for the specialty examination described in Table 945-1; and
- (iii) All appropriate fees as listed in WAC [296-46B-909](#).

Upon successful completion of the appropriate examination, the trainee will be issued a nonrenewable zero percent supervision modified training certificate for the appropriate specialty. The zero percent supervision modified training certificate will be restricted in duration to the time allowed in Table 945-1, note 2.

- (b) Prior to the expiration of the zero percent supervision modified training certificate, the individual must submit a complete application for a seventy-five percent supervision modified training certificate for the appropriate specialty including:
 - (i) Seventy-five percent supervision training certificate application including: Date of birth, mailing address, Social Security number; and
 - (ii) All appropriate fees as listed in WAC [296-46B-909](#).
- (c) A trainee may possess multiple (i.e., in different specialties) modified supervision training certificates for specialties where reduced supervision is allowed in Table 945-1. Combination training certificates will not be issued.

Renewal of training certificates.

- (6) An individual must apply for renewal of their training certificate on or before the expiration date of the certificate. The individual may not apply for renewal more than ninety days prior to the expiration date. Renewed certificates are valid for two years.
- (7) An individual may renew their training certificate after the expiration date if the individual pays the late renewal fee listed in WAC [296-46B-909](#).

- (8) All applicants for training certificate renewal must:
 - (a) Submit a complete renewal application;
 - (b) Pay all appropriate fees; and
 - (c) Complete the approved basic trainee classes required by WAC [296-46B-970](#). Basic trainee classes are only valid when all the requirements of WAC 296-46B-970 are completed.
 - (d) Within thirty days after renewing an electrical training certificate, the individual, if not enrolled in a department approved apprenticeship program, must submit a completed, signed, and notarized affidavit(s) of experience for all hours of experience gained since the individual's last training certificate was effective.

Employers are required to provide the necessary documentation and signed affidavit of experience to the trainee within twenty days after the trainee requests the affidavit. See WAC 296-46B-942(12). See WAC 296-46B-985(4) for the penalty for providing a false or inaccurate affidavit of experience. If the individual is enrolled in a department approved apprenticeship program, the program may submit the required affidavit(s) of experience upon the individual's completion of the required experience hours without cost to the individual. The affidavit of experience must accurately attest to:

- (i) The electrical installation work performed for each employer the individual worked for in the electrical trade during the previous period;
- (ii) The correct electrical category the individual worked in; and
- (iii) The actual number of hours worked in each category under the proper supervision of a Washington certified, master journey level electrician, journey level electrician or appropriate master specialty electrician or specialty electrician under that specific training certificate. If a trainee possesses multiple training certificates, an affidavit must be submitted for each training certificate for the hours worked under that specific training certificate.

If the individual is enrolled in a department approved apprenticeship program, the program may submit the required affidavit(s) of experience upon the individual's completion of the required experience hours without cost to the individual.

- (9) An individual who has not completed the required hours of basic trainee class education can renew a training certificate if the individual applies for renewal before the training certificate expires and pays the appropriate renewal fee. However, the training certificate will be placed in an inactive status. The inactive training certificate will be returned to current status upon validation, by the department, of the required basic trainee class education.
- (10) An individual may renew a suspended training certificate by submitting a complete renewal application including obtaining and submitting the basic trainee class education required for renewal. However, the certificate will remain in a suspended status for the duration of the suspension period.

- (11) An individual will not be issued a renewed or reinstated training certificate if the individual owes the department money as a result of an outstanding final judgment under chapter 19.28 RCW.
- (12) The individual should ask each employer and/or apprenticeship training director for an accurately completed, signed, and notarized affidavit of experience for the previous certification period. The employer(s) or apprenticeship training director(s) must provide the previous period's affidavit of experience to the individual within twenty days of the request. If an individual is enrolled in an approved electrical construction trade apprenticeship program under chapter [49.04 RCW](#) when the individual renews an electrical training certificate, the individual and their apprenticeship training director and/or each employer must give the department an accurately completed, signed, and notarized affidavit of experience accurately attesting to:
 - (a) The electrical installation work the individual performed in the electrical trade during the previous certification period;
 - (b) The correct electrical category the individual worked in; and
 - (c) The actual number of hours worked in each category under the proper supervision of a Washington certified master journey level electrician, journey level electrician or appropriate master specialty or specialty electrician for each employer. For apprentices enrolled in a registered apprenticeship program, the applicant and the training director are the only authorized signatures the department will accept on affidavits of experience.
- (13) The individual and their employer(s) and/or apprenticeship training director(s) must sign and have notarized the affidavit of experience attesting to the accuracy of all information contained in the affidavit.
- (14) The trainee, supervising electrician, contractor, and assigned administrator or master electrician are responsible for ensuring compliance with subsection (13) of this section. See WAC [296-46B-985](#) and [296-46B-990](#) (3)(c) and (f) for information about failing to submit or submitting false/fraudulent documents. Falsifying documents may be considered perjury and might result in criminal prosecution, civil penalty, or certificate revocation or suspension.

Trainees without supervision present on the job site.

- (15) When the supervising electrician is found to not be present on the job site, the trainee may be given a form by the inspector that must be fully completed and returned or postmarked within twenty-four hours to the inspector. The supervising electrician must sign the statement for the trainee if appropriate supervision was provided. If the supervising electrician fails or refuses to assist the trainee in completing the form, the trainee must return the form with a signed and dated statement stating the supervising electrician's name and saying that the supervising electrician refused to assist.

Trainees seeking a journey level electrician certificate – Working with no supervision.

- (16) Trainee seeking a general (01) journey level electrician certificate of competency. After review by the department, a trainee may be issued a six-month, nonrenewable unsupervised electrical training certificate that will allow the individual to work without supervision if the trainee:
 - (a) Has submitted a complete application for an unsupervised electrical training certificate;
 - (b) Has worked over seven thousand hours properly supervised not to include more than four thousand of specialty experience;
 - (c) Has successfully completed or is currently enrolled in an approved apprenticeship program or an electrical construction trade program in a school approved by the board of community and technical colleges;
 - (d) Has paid all appropriate training certificate fees listed in WAC [296-46B-909](#);
 - (e) Is currently working for and continues to work for a licensed electrical contractor that employs at least one certified journey level or specialty electrician in the appropriate specialty; and
 - (f) Has not previously failed a journey level electrician certificate of competency examination (see WAC 296-46B-960(11)).

Trainees seeking certain specialty electrician certificates – Working with reduced or no supervision.

- (17) After review by the department, a trainee may be issued a nonrenewable zero percent supervision training certificate that will allow the individual to work without supervision if the trainee meets the requirements in subsection (4) of this section.
- (18) Electrical trainees may work unsupervised when installing HVAC/R thermostat cable when the HVAC/R system consists of a single thermostat in one- and two-family dwelling units where line voltage power has not been connected to the dwelling's electrical system.

WAC 296-46B-945 Qualifying for master, journey level, specialty electrician examinations.

General.

(1) General

- (a) All applicants must be at least sixteen years of age.
- (b) All applicants, from in or out of state, must demonstrate the completion of basic trainee classes described in WAC [296-46B-970](#)(4)(c)(ii)(D).
 - (i) Twenty-four hours where 2,000 or more; but less than 4,000 hours of work experience is required.
 - (ii) Forty-eight hours where 4,000 or more; but less than 6,000 hours of work experience is required.
 - (iii) Seventy-two hours where 6,000 or more; but less than 8,000 hours of work experience is required.
 - (iv) Ninety-six hours where 8,000 hours or more of work experience is required.

Qualifying for the master electrician examination.

- (2) An individual may take the master electrician's certificate of competency examination if the individual meets the requirements described in RCW [19.28.191](#) (1)(d) or (e).

Qualifying for the master electrician examination from out-of-state.

- (3) No credit may be applied from out-of-state toward qualifying for a master electrician certificate of competency examination.

Qualifying for the journey level electrician competency examination.

- (4) An individual may take the journey level electrician's certificate of competency examination if the individual held a current electrical training certificate and has worked for an employer who employs at least one certified master electrician, journey level, or specialty electrician on staff and the individual:

- (a) Has been employed, in the electrical construction trade, under the direct supervision of a master electrician, journey level electrician or specialty electrician working in the appropriate specialty in the proper ratio, per RCW [19.28.161](#), for four years (eight thousand hours). Of the eight thousand hours:
 - (i) At least two years (four thousand hours) must be in new industrial and/or new commercial electrical installation (excluding all work described for specialty electricians or technicians) under the direct supervision of a master journey level electrician or journey level electrician while working for a general electrical contractor; and
 - (ii) Not more than a total of two years (four thousand hours) may be for work described as an electrical specialty in WAC [296-46B-920](#)(2).
- (b) Has completed a four-year apprenticeship program in the electrical construction trade that is registered with the state apprenticeship council while working under the direct supervision of a master journey level or journey level electrician in the proper ratio, per RCW [19.28.161](#); or
- (c) Has completed a two-year electrical construction training program as described in RCW [19.28.191](#) for journey level electricians, and two years (four thousand hours) of work experience in new industrial and/or new commercial electrical installations (excluding work described for specialty electricians or electrical technicians) under the direct supervision of a journey level electrician while working for a general electrical contractor in the proper ratio, per RCW 19.28.161. See WAC [296-46B-971](#) for additional training school information.

Electrical construction training hours gained in specialties requiring less than two years (i.e., four thousand hours) will not be credited towards qualification for journey level electrician.

The trainee and their employer and/or apprenticeship training director must attest to the accuracy of all information contained on affidavits of experience and apprenticeship graduation certificates used to verify eligibility for the examination.

Qualifying for a specialty electrician certificate of competency or examination.

(5) After review and approval by the department, an individual may qualify for a specialty electrician's examination and certificate of competency if the individual held a current electrical training certificate, and has worked for an employer who employs at least one certified master journey level electrician, journey level electrician, appropriate master specialty electrician, or appropriate specialty electrician on staff and the individual:

(a) Has been employed, in the electrical construction trade, under the direct supervision of an appropriate electrician in the appropriate specialty as follows:

Specialty	Minimum Hours of Work Experience Required to be Eligible for Examination ⁽⁴⁾⁽⁵⁾	Minimum Hours of Work Experience Required for Certification
Residential certificate (02)	4,000 ⁽³⁾	4,000
Pump and irrigation certificate (03)	4,000 ⁽³⁾	4,000
Domestic well certificate (03A)	720 ⁽¹⁾⁽²⁾	2,000 ⁽⁶⁾
Signs certificate (04)	4,000 ⁽³⁾	4,000
Limited energy system certificate (06)	4,000 ⁽³⁾	4,000
HVAC/refrigeration system certificate (06A)	4,000 ⁽³⁾	4,000 ⁽⁷⁾
HVAC/refrigeration restricted (06B)	1,000 ⁽¹⁾⁽²⁾	2,000 ⁽⁶⁾
Nonresidential maintenance certificate (07)	4,000 ⁽³⁾	4,000
Nonresidential lighting maintenance and lighting retrofit certificate (07A)	720 ⁽¹⁾⁽²⁾	2,000 ⁽⁶⁾
Residential maintenance certificate (07B)	720 ⁽¹⁾⁽²⁾	2,000 ⁽⁶⁾
Restricted nonresidential maintenance certificate (07C)	1,000 ⁽¹⁾⁽²⁾	2,000 ⁽⁶⁾
Appliance repair certificate (07D)	720 ⁽¹⁾⁽²⁾	2,000 ⁽⁶⁾
Equipment repair certificate (07E)	1,000 ⁽¹⁾⁽²⁾	2,000 ⁽⁶⁾
Door, gate, and similar systems certificate (10)	720 ⁽¹⁾⁽²⁾	2,000 ⁽⁶⁾

Notes:

⁽¹⁾ Until the examination is successfully completed, the trainee must work under one hundred percent supervision. Once the appropriate examination is successfully completed, the modified supervision trainee may work under zero percent supervision.

⁽²⁾ The trainee may have only one zero percent supervision certificate in a specialty (valid for no more than two years). If the trainee has not gained the required work experience by the time the zero percent supervision certificate has expired, the trainee must get a seventy-five percent supervision certificate and work under supervision until all required work experience hours are gained and credited towards the minimum work experience requirement.

⁽³⁾ This specialty is not eligible for unsupervised trainee status as allowed in chapter 19.28 RCW.

⁽⁴⁾ The trainee and their employer and/or apprenticeship training director must attest to the accuracy of all information contained on affidavits of experience used to verify eligibility for the examination.

⁽⁵⁾ Neither previous work experience credit nor training school credit is allowed as a substitute for the initial hours of minimum work experience required to be eligible for examination unless the trainee's work experience hours under direct supervision are provided as required in RCW 19.28.191 (1) (g)(ii).

(6) Electrical construction training hours gained in specialties requiring two thousand hours or less for certification will not be credited towards qualification for journey level electrician or any of the four thousand hour specialties, except as allowed by (7), below.

(7) The 2,000 minimum hours of work experience required for certification as a HVAC/refrigeration-restricted (06B) specialty electrician may be credited as 2,000 hours towards the 4,000 minimum hours of work experience required for certification as a HVAC/refrigeration (06A) specialty electrician. Hours of work experience credited from the HVAC/refrigeration-restricted (06B) specialty cannot be credited towards qualification for taking the general electrician (01) examination or minimum work experience requirements.

(8) Experience hours may be coincidentally credited towards qualifying for electrician and plumber certifications. See RCW 19.28.191(1)(g)(iv).

(b) Or has completed an appropriate two-year apprenticeship program in the electrical construction trade that is registered with the state apprenticeship council while working under the direct supervision of an electrician in the appropriate specialty in the proper ratio, per RCW 19.28.161.

Qualifying for a certificate of competency when the Washington electrical work experience is exempt from certification requirements in RCW [19.28.261](#).

(6) After review and approval by the department, an individual may be granted work experience credit to take the journey level/specialty electrician's competency examination when an original notarized letter of work experience accompanied by verifiable documentation is provided— see subsection (7) of this section.

For the purposes of this section, exempt work does not include work performed on property owned, in whole or part, by the individual seeking credit.

All exempt individuals must have a valid electrical training certificate when working to gain electrical work experience. Work experience requested by an individual for telecommunications work must be gained while working for (01) general electrical, (02) residential, or (06) limited energy system electrical contractors as allowed by those scopes of work. When the work was performed, the individual must have a valid training certificate, be under the supervision of an appropriately certified journey level, residential or limited energy electrician, and be in compliance with RCW 19.28.191.

General – Qualifying hours gained by applicants seeking work experience credit without a Washington electrician training certificate.

(7) The type of on-the job work experience must be similar to the credit being applied for and lawfully gained in the state or other entity where the work was performed. The individual must submit verifiable documentation (e.g. payroll, time sheets, permits, supervision, etc.) that the department may use to ascertain the type of work performed and the number of hours worked for each type (i.e. specialty) of work.

Training hours credited for specialties requiring less than two years (i.e. four thousand hours) may not be credited towards qualification for general journey level electrician.

The documentation must include a complete description of the individual's usual duties with percentages attributed to each type (e.g. wiring, material handling, shop, low voltage, etc.).

The department may reduce the number of hours allowed if the:

- (a) Individual did not have supervision during the training period;
- (b) Training hours are not related to electrical construction;
- (c) Training hours are not related to the specialty being applied for;
- (d) Documentation submitted by the individual does not fully verify the requested work experience; or
- (e) Work credit was not lawfully gained.

Training school credit.

(8) No more than fifty percent of the minimum work experience needed to qualify for specialty electrician certification is allowed for any training school program (e.g., a specialty requiring two thousand hours of minimum required work experience may receive no more than one thousand hours credit from an electrical construction training program).

See RCW [19.28.191](#) (1)(h) for training school credit allowed for journey level applicants.

See WAC [296-46B-971](#) for additional information on training schools.

Qualifying for the journey level/specialty electrician competency examination when work was performed in a state requiring electrician certification.

(9) After review and approval by the department, an individual may be granted on-the-job work experience towards qualifying to take the journey level/specialty electrician's competency examination for hours worked in the other state when the state certifies to the department:

- (a) The type and number of hours of work performed within that state. Credit will not be allowed for work not done within the certifying state.
- (b) That the work was legally performed under the other state's licensing and certification requirements; and
- (c) The other state's certificate of competency was obtained by examination.

If the experience is for other than a new commercial or industrial installation, the individual must identify the specialty credit desired and provide verifiable documentation identifying the other state's allowed scope of work for the specialty, see (6) above.

Qualifying for the journey level/specialty electrician competency examination when work was performed in a state that does not require electrician certification.

(10) After review and approval by the department, an individual may be granted work experience credit to take the journey level/specialty electrician's competency examination when an original notarized letter of work experience accompanied by documentation, see (7) above, that can be used to verify the individual has worked the hours being requested is provided by:

- (a) An appropriately licensed electrical contractor,
- (b) Registered apprenticeship training director,
- (c) Nationally recognized contractor/labor organization, or
- (d) The individual's lawful employer.

Military/shipyard experience.

(11) After review and approval by the department, an individual who has worked in the electrical construction trade performing work described in WAC [296-46B-920](#) while serving in the armed forces of the United States may be eligible to take the examination for the certificate of competency as a journey level or specialty electrician. Credit may be allowed for hours worked or training received.

If an individual has military experience in a specialized electrical field (e.g., rating) that is similar to a specialty electrician category listed in WAC 296-46B-920, credit may be allowed toward the appropriate specialty certificate. Nuclear, marine, shipyard, shipboard, radar, weapons, aeronautical experience, or similar experience may be acceptable for no more than fifty percent of the minimum required work experience for qualifying for electrician examination.

The department will evaluate and determine whether the submitted experience is related specifically to the electrical construction/maintenance trade regulated by chapter [19.28](#) RCW.

Experience in another country.

(12) After review and approval by the department, and if an individual has a journey level electrician certificate from a country outside the United States that requires that at least four years of electrical construction training and certification is obtained by examination, the individual may be eligible for four thousand hours of the specialty credit allowed towards the qualification to take the Washington journey level electrician examination.

No more than two years of the required training to become a Washington journey level electrician may be for work described for specialty electricians or technicians in WAC [296-46B-920](#). In addition to the maximum of four thousand hours credit that may be allowed by this subsection, an additional four thousand hours of new commercial/industrial experience must be obtained using a training certificate in the state while under the supervision of a master journey level electrician or journey level electrician.

Documentation substantiating the individual's out-of-country experience must be submitted in English.

(13) Out-of-country experience credit is not allowed toward a specialty electrician certificate.

WAC 296-46B-960 Administrator and electrician certificate of competency examinations.

General.

- (1) The minimum passing score on any examination or examination section is seventy percent. If examination is requested to be administered by the department, an application is required and the examination must be successfully completed within one year of application or the individual must submit a new application for exam including all appropriate fees.
- (2) All examinations are open book.
 - (a) Candidates may use:
 - (i) Any original copyrighted material;
 - (ii) A silent, nonprinting, nonprogrammable calculator that is not designed for preprogrammed electrical calculations;
 - (iii) Copies of chapter [19.28](#) RCW and this chapter; or
 - (iv) A foreign language dictionary that does not contain definitions.
 - (b) Candidates may not use:
 - (i) Copies of copyrighted material;
 - (ii) Copies of internet publications, except for RCWs or WACs;
 - (iii) Personal notes; or
 - (iv) A personal computing device of any type other than the calculator in (a)(ii) of this subsection.
- (3) Administrator, master electrician, and electrician examinations may consist of multiple sections. For all administrator examinations, all sections must be successfully completed within a one-year examination period after beginning the examination. For all master electrician and electrician examinations, all sections must be successfully completed within a one-year examination period beginning with the date of the examination approval. Within the one-year examination period, the candidate does not have to retake any sections successfully completed within the examination period. If all sections are not successfully completed within the one-year period, the candidate must begin a new examination period and retake all sections.

Special accommodations for examination.

- (4) An applicant for an examination who, due to a specific physical, mental, or sensory impairment, requires special accommodation in examination procedures, may submit a written request to the chief electrical inspector for the specific accommodation needed.
 - (a) The applicant must also submit to the department a signed and notarized release, authorizing the specifically identified physician or other specialist to discuss the matter with the department representative. The applicant must also submit an individualized written opinion from a physician or other appropriate specialist:
 - (i) Verifying the existence of a specific physical, mental, or sensory impairment;
 - (ii) Stating whether special accommodation is needed for a specific examination;
 - (iii) Stating what special accommodation is necessary; and
 - (iv) Stating if extra time for an examination is necessary and if so, how much time is required. The maximum allowance for extra time is double the normal time allowed.
 - (b) The written request for special accommodation and individualized written opinion must be submitted to the department at least six weeks in advance of the examination date and must be accompanied by a completed application and fees as described in WAC [296-46B-909](#).
 - (c) Only readers and interpreters provided from the administrative office of the courts and/or approved by the department may be used for reading or interpreting the examination. The applicant will be required to bear all costs associated with providing any reading or interpretive services used for an examination.
 - (d) Applicants who pass the examination with the assistance of a reader or interpreter will be issued a certificate with the following printed restriction: "Requires reading supervision for product usage." A competent reader or interpreter must be present on any job site where a person with this restriction is performing electrical work as described in chapter [19.28](#) RCW.

Applicants who pass the examination with the assistance of a mechanical device (e.g., magnifier, etc.) will be issued a certificate with the following printed restriction: "Requires mechanical reading assistance for product usage." Appropriate mechanical reading assistance must be present on any job site where a person with this restriction is performing electrical work as described in chapter 19.28 RCW.

If a candidate successfully retakes the examination without the assistance of a reader or translator, a new certificate will be issued without the restriction.

(5) Applicants who wish to use a foreign language dictionary during an examination must obtain approval at the examination site prior to the examination. Only dictionaries without definitions will be approved for use.

Failed examination appeal procedures.

(6) Any candidate who takes an examination and does not pass the examination may request a review of the examination.

- (a) The department will not modify examination results unless the candidate presents clear and convincing evidence of error in the grading of the examination.
- (b) The department will not consider any challenge to examination grading unless the total of the potentially revised score would result in a passing score.

(7) The procedure for requesting an informal review of examination results is as follows:

- (a) The request must be made in writing to the chief electrical inspector and must be received within twenty days of the date of the examination and must request a rescore of the examination. The written request must include the appropriate fees for examination review described in WAC [296-46B-909](#).
- (b) The following procedures apply to a review of the results of the examination:
 - (i) The candidate will be allowed one hour to review their examination.
 - (ii) The candidate must identify the challenged questions of the examination and must state the specific reason(s) why the results should be modified with multiple published reference material supporting the candidate's position.
 - (iii) Within fifteen days of the candidate's review, the department will review the examination and candidate's justification and notify the candidate in writing of the department's decision.

Failing an administrator certificate exam or electrician certificate of competency examination.

(8) Anyone failing an administrator or electrician competency examination may retake the examination by making arrangements with the testing agency and paying the retesting fee.

(9) If the individual makes a failing score, the individual must wait two weeks before being eligible to retest.

(10) If the individual fails an electrician examination or a part of an administrator or master electrician examination three times within a one-year period, the individual must wait three months to retake the failed portion of the examination.

(11) Anyone failing an electrician competency examination may continue to work in the electrical trade if they have a valid electrical training certificate and work under the direct supervision of a certified journey level or specialty electrician in the proper ratio, per RCW [19.28.161](#).

Cheating on an examination.

(12) Anyone found cheating on an examination, attempting to bribe a proctor or other agent involved in administering an examination, or using inappropriate materials/equipment during an examination will be required to wait at least eleven months before being allowed to reexamine. All such reexaminations will be administered by the department in Tumwater, Washington and the candidate will be required to apply and schedule for the examination with the chief electrical inspector. The department may also file a civil penalty action under chapter [19.28](#) RCW.

Examination confidentiality.

(13) All examination questions are confidential. Examination candidates and persons who have taken an examination are not allowed to copy or otherwise make note of or share examination content, in any manner, outside the individual's examination environment. Examination candidates must agree, prior to beginning an examination, to keep all examination content confidential. The department may also file a civil penalty action under chapter [19.28](#) RCW.

WAC 296-46B-970 Continuing education and classroom education requirements.

(1) Definitions - for purposes of this section.

- "Applicant" means the entity submitting an application for review.
- "Application" means a submittal made by an applicant seeking instructor or class approval.
- "Calendar day" means each day of the week, including weekends and holidays.
- "Class" means continuing education or basic trainee class.
- "Currently adopted code," for this section, means the code adopted in WAC 296-46B-010(1) or any more recently published National Electric Code.
- "Date of notification" means the date of a request for additional information from the department or the approval/denial letter sent to the applicant by the department.
- "Examination" is any examination required by this section. Each examination must be unique and must provide randomized questions, except for classroom training. Each examination question bank must be at least two times larger than the number of questions in any individual examination. Examinations must not direct or point the individual to a correct answer or reference. Individuals must be responsible to determine the correct answer without the assistance of the sponsor. No more than 20% of an examination's questions may have a true/false answer. Competency is demonstrated by scoring at least 75% on the examination.
- "Individual" means a master electrician, administrator or electrician seeking credit for continuing education or a trainee seeking credit for basic trainee class for renewal or certification.
- "Instructor" means an individual who is authorized to instruct an approved continuing education or basic trainee class.
- "Working day" means Monday through Friday, excluding state of Washington holidays.

(2) General.

- (a) The department and the electrical board have the right to monitor all approved classes without notice and at no charge.
 - If the department or electrical board determines that the class or instructor does not meet or exceed the minimum requirements for approval, course length, or instructor qualifications, the department may revoke the class and/or instructor approval and/or reduce the number of credited hours for the class.
- (b) Department-offered classes and the instructors used for department classes are automatically approved.
- (c) Instructors who meet the minimum requirements using subsection (5)(d)(iv) of this section may only instruct classes sponsored by the manufacturer(s) who verified the instructors' qualifications.
- (d) An individual will not be given credit for the same approved continuing education class taken more than once. A course sponsor may not submit an individual's name on a roster(s) for multiple classes (i.e., multiple class numbers) when the classes are given simultaneously (e.g., code update, industry related, and/or basic trainee class that have similar class content given during the same class session). Credit will not be granted for a class that is not approved per this section.
- (e) Electrical administrators, master electricians, and electricians:
 - (i) To be eligible for renewal of an administrator certificate, master electrician or electrician certificate of competency, the individual must have completed at least eight hours of approved continuing education for each year of the prior certification period. The individual is not required to take the classes in separate years.
 - (A) At least eight hours of the total required continuing education must be on the changes in the currently adopted code.
 - (B) Four hours of the required continuing education must be on the currently adopted chapter [19.28](#) RCW and/or its related WAC.
 - (ii) An individual changing an electrical administrator and an electrician certificate of competency into a master electrician's certificate of competency as allowed in RCW [19.28.191](#) (1)(a) or (b) must have completed at least eight hours of approved continuing education for each year of the electrician's prior certificate period. The individual is not required to take the classes in separate years.
 - (A) At least eight hours of the total required continuing education must be on the changes in the currently adopted code.
 - (B) Four hours of the required continuing education must be on the currently adopted chapter 19.28 RCW and/or its related WAC.
 - (iii) Any portion of a year of a prior administrator or electrician certificate period is equal to one year for the purposes of the required continuing education.
 - (iv) An individual who has both an electrician certificate and an administrator certification may use the same class to fulfill the requirements for continuing education.

(f) Training certificates:

To be eligible for renewal of a training certificate, the individual must have completed:

- (i) At least forty-eight hours of approved basic trainee classes. The individual cannot use a basic trainee class as credit for the continuing education requirements for renewing an electrician or administrator certificate(s) when the class is also used to satisfy the training certificate renewal requirements; or
- (ii) Equivalent electrical training classes taken as a part of an approved:
 - Apprenticeship program under chapter 49.04 RCW; or
 - Electrical training program under RCW 19.28.191(1)(h).

Equivalent classes must be submitted to and approved by the chief electrical inspector thirty calendar days prior to offering the class.

(g) A continuing or basic trainee class attended or completed by an individual before the class's effective date cannot be used to meet the certificate renewal/certification requirements.

(3) Class and instructor – General approval process.

- (a) The department will review the application for completeness and conformance with the requirements in this section.
- (b) The department will deny approval of applications that do not meet the minimum requirements.
- (c) All applications will be considered to be new applications (i.e., Classes and instructors may not be renewed. All applications must include all information necessary to show conformance with the minimum requirements).
- (d) Application process:
 - (i) The applicant must submit a complete application to the department at least thirty calendar days prior to offering or instructing a class.
 - (ii) The department will only consider material included with the application when reviewing an application.
 - (iii) All applications must include:
 - (A) Applicant's name, address, contact name, email address, and telephone number;
 - (B) All required fees.
- (e) Review process:
 - (i) When the application is received:
 - (A) The department must review the application for completeness within seven working days after receipt.
 - (B) If the application is incomplete, the department must, within two working days, notify the applicant of the status of the review and what additional information is required.
 - The applicant must provide any additional information requested by the department within five working days after the date of notification.
 - The department will deny the application if the additional required information is not received within the five working days after the date of notification for additional information.
 - (C) The department must complete the review and approval/denial process within fifteen working days upon receipt of a complete application or additional requested information and within two working days notify the applicant of the approval/denial in writing or electronically.
 - (ii) A notification of denial must include:
 - (A) Applicant's name and telephone number;
 - (B) Date of denial;
 - (C) Sponsor's name and class title if applicable;
 - (D) Instructor's name if applicable; and
 - (E) The reason for denial.
 - (iii) A notification of approval:
 - (A) For classes must include:
 - Applicant's name and telephone number;
 - Sponsor's name and telephone number;
 - Sponsor number;
 - Class title;
 - Class number;
 - Number of hours approved for the class. The department may reduce the hours requested in the application if the review shows that the requested number of hours is excessive;

- Effective date for this class;
- Expiration date of class;
- Category for which the class is approved (i.e., code update, RCW/WAC update, industry related, basic trainee class, or pumping industry);
- Type of class (i.e., classroom, correspondence, internet); and
- Whether the class is open to the public.

(B) For instructors, must include:

- Applicant's name and telephone number;
- Instructor's name and telephone number;
- Effective date for the approval; and
- Expiration date of the approval.

(iv) The applicant may request a review by the electrical board, of the department's denial or modification of the application. The applicant must submit a written request for review to the Secretary of the Electrical Board – Chief Electrical Inspector - within twenty days of notification of the denial/modification. The request must include review fee of one hundred nine dollars and fifty cents. The review fee is nonrefundable.

(4) Class approval process.

(a) Class applications must include:

- (i) Sponsor's name, address, contact name, email address, telephone number, and sponsor's number (if a class was previously approved);
- (ii) Class title;
- (iii) Number of education hours requested for the class;
- (iv) Category of class for which approval is sought (e.g., code update, RCW/WAC update, industry related, basic trainee class, or pumping industry);
- (v) Statement that all requirements of this section will be complied with;
- (vi) Statement of whether the class is open to the public;
- (vii) Class syllabus (e.g., presentation method(s), description of the training, specific NEC/RCW/WAC articles taught, theory subjects, time allowed for various subject matter components, examination question samples, etc.) describing how the class meets the minimum requirements, described below, for the type of class being offered;
- (viii) The applicant must show that the sponsor regularly employs at least one staff member who meets the requirements for instructors in this section;
- (ix) List of resources (e.g., texts, references, etc.).

(b) Class approval will be valid for three years except:

- (i) If the class is "code update" and a new NEC is adopted by the department within the class approval period, the class approval will be considered automatically revoked; or
- (ii) If the class is modified after the application is approved, the class approval will be considered automatically revoked (i.e., change in syllabus, hours, examination, etc.).

(c) Minimum requirements:

- (i) Class length:
 - (A) The minimum allowed length of a class is two hours; however, the minimum length for a basic trainee class is four hours that may be delivered in multiple classroom components of not less than two hours each.
 - (B) Class length must be based on two-hour increments (e.g., 2, 4, 6, 8, etc.).
 - (C) Class length must be based on the following:
 - Classroom instruction will be based on the total hours the individual is in the classroom. A continuing education class may be divided into multiple components so long as each component is not less than two hours in length and all components are completed within a one-month period. A basic trainee class may be divided into multiple components so long as each component is not less than two hours in length and all components are completed within a two-month period.
 - Distance learning continuing education classes (i.e., correspondence and internet continuing education classes) will be based on clock hours necessary to complete the class if it was presented in a classroom setting.
- (ii) Class content:
 - (A) Industry-related classes must be based on:
 - Codes or rules included in the currently adopted National Electrical Code (see definition of currently adopted), the electrical law/rule;

- Electrical theory based on currently published documents that are readily available for retail purchase; and/or

- Materials and methods that pertain to electrical construction, building management systems, electrical maintenance, or workplace electrical safety such as NFPA 70E – Handbook for Electrical Safety in the Workplace. First aid type classes must be approved and will be limited to four hours of credit towards the individual's total continuing education requirement.

(B) Code update classes must be based on the currently adopted (see definition) National Electrical Code and must specify the code articles to be addressed in the class presentation.

(C) RCW/WAC update classes must be based on the latest adopted versions of chapter [19.28](#) RCW and/or chapter [296-46B](#) WAC.

(D) All basic trainee classes must be classroom instruction only and based upon basic electrical theory, currently adopted (see definition for currently adopted) National Electrical Code, and/or use of the electrical laws or rules.

Correspondence and internet classes are not allowed.

All basic trainee classes must include an appropriate written competency examination(s) to ensure the participant has mastered the basic concepts of the class. The examination must consist of at least five questions per two hours of class credit.

(E) For all pumping industry classes, curriculum must include fifty percent electrical and fifty percent plumbing instruction.

(F) The sponsor of any distance learning class (e.g., correspondence/internet continuing education) must provide the following additional information with the application:

- How the sponsor will provide an orientation session with the instructor or an affiliated representative of the sponsor.
- The application must include a complete description of any hardware, software, or other technology to be used by the provider and needed by the student to effectively engage in the delivery and completion of the class material.
- In the case of internet based continuing education classes, describe how the class software addresses automatic shutdown after a period of inactivity.
- How will the sponsor provide security to ensure that the student who receives credit for the class is the student who enrolled in and completed the class. The approved sponsor and the student must certify that the student has completed the class and the required number of clock hours.
- The application must describe the process and the acceptable methods of how students can contact approved instructors to answer questions regarding the class.
- The application must describe the consistent and regular interactive events appropriate to the delivery method. The interactive elements must be designed to promote student involvement in the learning process and must directly support the student's achievement of the class learning objectives.
- The application must demonstrate that the class includes the same or reasonably similar information content as a course that would otherwise qualify for the requisite number of clock hours of classroom-based instruction.
- The application must demonstrate how the sponsor determined the number of clock hours requested.
- The application must demonstrate how mastery of the material is evaluated (e.g., describing how the material is divided into major learning units and describing how these learning units are divided into modules of instruction, describing how the student's progress toward completion of the mastery requirement will be measured, and describing how the class will provide a mechanism of individual remediation to correct any deficiencies in each module of instruction).

(5) Instructor approval process.

(a) Except first-aid training, all instructors must be approved per this section.

(b) The instructor application will include:

(i) Instructor's name, address, telephone number, email address;

(ii) Copies of credentials or other information showing conformance with the instruction minimum qualifications.

(c) Instructor approval will be valid for three years except:

- (i) If the instructor's credentials are invalidated (e.g., suspension or revocation by the issuing entity) for any reason, approval will be automatically revoked.
- (ii) When the instructor approval expires or is revoked, a new application must be submitted to regain approved instructor status.

(d) Minimum requirements:

The application must show that the instructor meets one of the following:

- (i) Has a valid Washington administrator, master electrician, or electrician's certificate and has appropriate knowledge of and experience working as an electrical/electronic trainer; or
- (ii) Is currently an instructor in a two-year program in the electrical construction trade licensed by the Washington work force training and education coordinating board. The instructor's normal duties must include providing electrical/electronic education; or
- (iii) Is a high school vocational teacher, community college, college, qualified instructor with a state of Washington approved electrical apprenticeship program, or university instructor. The instructor's normal duties must include providing electrical/electronic education; or
- (iv) Works for and is approved by a manufacturer of electrical products to teach electrical continuing education; or
- (v) Is an electrical engineer registered under chapter 18.43 RCW; or
- (vi) Subject matter experts approved by the chief electrical inspector who can demonstrate appropriate knowledge of, and experience in the electrical construction trade and working as an electrical/electronic trainer.

(6) Forms.

- (a) The department will develop an appropriate form(s) for the applicant's use when submitting for instructor or class approval;
- (b) Applicants must use the department's form when submitting an application for review.

(7) Class attendance.

- (a) The department is not responsible for providing verification of an individual's continuing education or basic trainee classroom training history with the class sponsor;
- (b) Electrical approved classes offered in Washington:
 - (i) The sponsor must provide the department with an accurate online course attendance/completion roster for each class given. Class attendance will only be verified based on the online attendance/completion roster provided by the sponsor.
 - (A) Within seven days of a student completing the class, the course sponsor must provide the attendance/completion roster in an internet format provided by the department.
 - (B) The attendance/completion roster must show each individual's name, Washington certificate number, class number, and date of completion.
 - (ii) Individuals will not be granted credit for a class unless the sponsor's online attendance/completion roster shows the individual successfully completed the class.
- (c) For classes approved under chapter [18.106](#) RCW for the pumping industry, a class number will be created for electrical continuing education. Sponsors for these classes must verify attendance for the electrical credit using the format described in subsection (b) of this section.

(8) Noncompliance with this section by a course sponsor or instructor.

- (a) Before a course sponsor or instructor is revoked or suspended for noncompliance with this section, the course sponsor or instructor will be given written notice of the department's intention to suspend or revoke. The notification will describe the allegations and provide the necessary procedures to request a hearing before the electrical board as described in RCW [19.28.341](#).
- (b) The department may also file a civil penalty action under chapter [19.28](#) RCW for fraudulent, inaccurate, or material misrepresentation activity.

WAC 296-46B-971 Training schools.

- (1) The department must evaluate and approve training school programs in the electrical trade as regulated by chapter [19.28](#) RCW for equivalency to hours of supervised work experience. Approved training programs must be from a Washington state public community or technical college, or a not-for-profit nationally accredited technical or trade school licensed by the work force training and education coordinating board under chapter [28C.10](#) RCW.
- (2) The minimum total hours for an electrical technical training program must be determined per RCW [19.28.191](#).
- (3) Training school programs must be approved before their graduates may request credit for equivalent work experience hours toward journey level or specialty electrician certification. Until December 31, 2003, existing electrical training programs, in effect after January 1, 2000, may apply for retroactive approval of their program to

determine the number of hours that will be credited for the program graduates. After December 31, 2003, all training programs must be approved by the department prior to beginning instruction.

- (4) Training schools must submit the curriculum of each journey level or specific specialty electrical training program to the department for approval. The curriculum must include a detailed description of each course that is included in the total training hours required by RCW 19.28.191. The curriculum must be reviewed by the department whenever significant changes in program content or course length are implemented or at an interval not to exceed three years. After department review, the program may be renewed. In evaluating the relevance of the curriculum, the department will consider the following criteria:
 - (a) Scope of work for the appropriate electrician certification.
 - (b) Understanding whole systems related to and integrated with electrical equipment installation, maintenance, troubleshooting, and appliance repair (e.g., refrigeration, pumps, hydraulics, thermodynamics, compressed air, and similar systems).
 - (c) Courses not directly related to electrical technical instruction or specific scope of work, but required to complete the specific training program (i.e., mathematics, technical writing, business, safety, first aid, ergonomics, etc.), must not exceed ten percent of the total student/instructor contact time of the program.
- (5) Within thirty days after beginning a program, the program sponsor must supply the department with a roster of individuals enrolled in the program. The roster must show each student's name, date of enrollment, Washington training or electrician certificate number, and the training program number. Within thirty days after each graduation cycle, approved training school programs must provide the department with a roster of individuals that have successfully completed the program. The roster must show each student's name, date of completion, Washington training or electrician certificate number, and the training program title.
- (6) All school training activities involving electrical work or appliance repair done outside of in-school lab facilities must be done under a valid Washington electrical contractor's license. All students performing such work must have a valid training certificate and work under a supervising journey level or specialty electrician in a ratio, per RCW [19.28.161](#), in compliance with RCW 19.28.161.
- (7) Individuals in a two-year electrical construction trade training program for journey level electrician must obtain the additional two years of work experience required in new industrial or commercial installation prior to the beginning, or after the completion, of the technical school program.

All student electrical training hours obtained when working for contractors or other employers in intern programs arranged by the school must be evaluated as part of the training program hours. Additional work experience credit gained in an intern program is not allowed.

This does not prohibit trainees in a training program for specialty electricians from having concurrent employment and obtaining additional specialty work experience while attending school. All such concurrent work must be documented in an affidavit of experience per WAC 296-46B-942(8).

The following supervision requirements must be met when working as an intern or student:

- (a) Intern when working for contractors or other employers as a:
 - (i) General electrician, there must be not more than one noncertified individual for every certified master journey level electrician or journey level electrician.
 - (ii) Specialty electrician, there must be not more than two noncertified individuals for every certified master specialty electrician working in that electrician's specialty, specialty electrician working in that electrician's specialty, master journey level electrician, or journey level electrician.
- (b) Student when working for a public community or technical college, or not-for-profit nationally accredited trade or technical school licensed by the work force training and education coordinating board under chapter 28C.10 RCW as a journey level or specialty electrician in the training program, the ratio requirements are one certified master specialty electrician working in that electrician's specialty, specialty electrician working in that electrician's specialty, master journey level electrician, or journey level electrician working as a specialty electrician to no more than four students enrolled in and working as part of an electrical construction program. All such work will be considered to be an integral part of the training program and work experience credit will not be allowed except as a part of the program.

When the ratio of certified electricians to noncertified individuals on a job site is one certified electrician to three or four noncertified individuals, the certified electrician must:

- (i) Directly supervise and instruct the noncertified individuals and the certified electrician may not directly make or engage in an electrical installation; and
- (ii) Be on the same job site as the noncertified individual for a minimum of one hundred percent of each working day.

The public community or technical colleges, or not-for-profit nationally accredited trade or technical schools must be an appropriately licensed electrical contractor when performing work outside the classroom.

(8) The department will use the criteria in this section to evaluate the hours of credit that may be allowed for United States armed forces experience and training in the electrical construction, electrical maintenance, and appliance repair trades. See WAC [296-46B-945](#).

WAC 296-46B-975 Electrical audit. — General.

- (1) The department may audit the employment records of the electrical contractor or employer to verify the employment status of trainees, assigned administrators, or assigned master electricians.
- (2) Every employer or contractor must keep a record of trainee, assigned administrator/master electrician employment so the department may obtain the information it needs to verify electrical trainee, assigned administrator, or assigned master electrician status and trainee work experience. Upon the request of the department's auditors or agents, these records must be made available to the department for inspection within seven business days.
- (3) Any information obtained from the contractor or employer during the audit is confidential and is not open to public inspection under chapter [42.17](#) RCW.

Trainee hours.

- (4) The time period covered by a trainee audit will not exceed five years prior to the period included in the last affidavit verifying trainee hours is submitted.
- (5) An employer or contractor must maintain payroll records, time cards, or similar records to verify:
 - (a) The number of hours the trainee worked as a supervised trainee;
 - (b) The type of electrical work the trainee performed; and
 - (c) Who provided the trainee's supervision.
- (6) The department's audit may include, but will not be limited to, the following:
 - (a) An audit to determine whether the trainee was employed by the contractor or employer during the period for which the hours were submitted, the actual number of hours the trainee worked, the category of electrical work performed, and who provided the trainee's supervision; and
 - (b) An audit covering a specific time period and examining a contractor's or employer's books and records which may include their reporting of the trainee's payroll hours required for industrial insurance, employment security or prevailing wage purposes.

Administrator/master electrician - status.

- (7) The time period covered by an administrator/master electrician audit will not exceed five years prior to the beginning of the audit.
- (8) Every employer or contractor must maintain pay records, time cards, or similar records to verify the work relationship and status of the assigned administrator or master electrician so the department may obtain the information it needs to verify the contractor-administrator/master electrician relationship. Upon the request of the department's auditors or agents, these records must be made available to the department for inspection within seven business days.
- (9) The department's audit may include, but will not be limited to, the following:
 - (a) An audit to determine whether the assigned administrator or assigned master electrician was employed by the contractor or employer during the period assigned which may include their reporting of the assigned administrator's/master electrician's payroll hours required for employment security, prevailing wage, worker's compensation, etc.; and
 - (b) An audit to determine the full-time supervisory status of the assigned administrator/master electrician.

WAC 296-46B-980 Enforcement — Installations, licensing, and certification requirements.

- (1) The department inspects the electrical worksites of individuals, employers, and employees with respect to the methods and installation requirements of chapter [19.28](#) RCW and this chapter. The department's electrical inspectors and electrical auditors make electrical work inspections. The department's electrical

inspectors/auditors verify that all required electrical work permits or labels are obtained prior to beginning any electrical work which requires an inspection. The department's electrical inspectors, electrical auditors, and compliance officers make electrical licensing/certification inspections.

(2) The department ensures that individuals, employers, and employees comply with the electrical licensing and certification requirements of chapter 19.28 RCW and this chapter. To do this, inspections are made by the department's electrical inspectors/auditors and compliance officers.

Compliance officers or electrical inspectors/auditors determine whether:

- (a) Each person or entity advertising to do electrical work or doing electrical work on an electrical worksite has a proper license or certificate;
- (b) The ratio, per RCW [19.28.161](#), of certified journey level/specialty electricians to the certified trainees on the job site is correct; and
- (c) Each certified trainee is directly supervised by an individual who possesses an appropriate certificate of competency for the type of electrical work being performed.

WAC 296-46B-985 Penalties for false statements or material misrepresentations.

- (1) A person who makes a false statement or material misrepresentation on an application, statement of hours, or signed statement to the department may be referred to the county prosecutor for criminal prosecution under RCW [9A.72.020](#), [9A.72.030](#), and [9A.72.040](#). The department may also file a civil action under RCW [19.28.131](#) or [19.28.271](#) and may revoke or suspend a certificate under RCW [19.28.241](#) or [19.28.341](#).
- (2) The department may file a civil action under RCW 19.28.131 or 19.28.271 and may revoke or suspend a certificate of competency under RCW 19.28.341 or 19.28.241 for inaccurate or false reporting of continuing or basic trainee classroom education units on the administrator, master electrician, electrician, or training certificate renewal form.
- (3) If the department determines that a course sponsor has issued an inaccurate or incomplete course application or attendance/completion roster, the department may suspend or revoke the course approval and deny future approval of a continuing or basic trainee classroom education course(s) by the course sponsor.
- (4) The department may file a civil action under RCW 19.28.271 against both the trainee and the contractor, apprentice training director, or other entity verifying the training hours and may subtract up to two thousand hours of employment from a trainee's total hours if the department determines a false statement or material misrepresentation has been made in an affidavit of experience.

WAC 296-46B-990 Failure to comply with the electrical contractor licensing, administrator certification, or electrician certification laws

General.

- (1) If the compliance officer or electrical inspector/auditor determines that an individual, employer, or employee has violated chapter [19.28](#) RCW or this chapter, the department will issue a citation that describes the violation.

Suspension or revocation - Of an electrical contractor's license, administrator's certificate, master electrician's certificate of competency, electrician's certificate of competency, or training certificate.

- (2) The department may revoke or suspend, for such time as it determines appropriate, an electrical contractor's license, administrator's certificate, master electrician's certificate of competency, electrician's certificate of competency, or training certificate if:
 - (a) The license, certificate, or permit was obtained through error or fraud;
 - (b) The license, certificate, or permit holder is judged to be incompetent to work in the electrical construction trade as a master electrician, journey level electrician, specialty electrician, electrical technician, or electrical trainee;
 - (c) For serious noncompliance as described below. See RCW [19.28.241](#) and [19.28.341](#) for other grounds and procedures.
 - (d) The license or certificate holder incompletely or inaccurately reported continuing or basic trainee class education units on an application for renewal; or
 - (e) The certificate holder falsely, incompletely, or inaccurately reported previous work experience.

The department will deny an application for any license/certificate during the period of revocation or suspension of the same or another license/certificate under chapter 19.28 RCW.

(3) For the purposes of this section, serious noncompliance includes, but is not limited to, any of the following:

- (a) Causing or failing to correct a serious violation. A serious violation is a violation of chapter 19.28 RCW or chapter [296-46B](#) WAC that creates a hazard of fire or a danger to life safety. A serious violation is also a violation that presents imminent danger to the public. Imminent danger to the public is present when installations of wire and equipment that convey or utilize electric current have been installed in such a condition that a fire-hazard or a life-safety hazard is present. Imminent danger to the public is also present when unqualified, uncertified, or fraudulently certified electricians or administrators; or unlicensed or fraudulently licensed contractors are continuously or repeatedly performing or supervising the performance of electrical work covered under chapter [19.28](#) RCW. For the purposes of this section, a certified electrician is considered qualified, provided the electrician is working within his or her certification;
- (b) The license or certificate was obtained through error or fraud;
- (c) Submitting a fraudulent document to the department;
- (d) Continuous noncompliance with the provisions of chapter 19.28 RCW or this chapter. For the purposes of this section, continuous noncompliance will be defined as three or more citations demonstrating a disregard of the electrical law, rules, or regulations within a period of three years, or where it can be otherwise demonstrated that the contractor, master electrician, electrician, or administrator has continuously failed to comply with the applicable electrical standards;
- (e) Failure to make any books or records, or certified copies thereof, available to the department for an audit to verify the hours of experience submitted by an electrical trainee;
- (f) Making a false statement or material misrepresentation on an application, statement of hours, or signed statement required by the department;
- (g) The certificate holder falsely or inaccurately reported continuing or basic trainee class education units on an application for renewal;
- (h) Installing a shortened rod/pipe grounding electrode, improper splicing of conductors in conduits/raceways or concealed within walls, or installing a fake equipment grounding conductor.

For any act of serious noncompliance, the person, firm, partnership, corporation, or other entity may be referred to the county prosecutor for criminal prosecution under chapter [9A.72](#) RCW. The department may also file a civil action under chapter 19.28 RCW.

(4) Before a license or certificate is revoked or suspended, the certificate holder will be given written notice of the department's intention to suspend or revoke. Notification will be sent by registered mail to the certificate holder's last known address. The notification will list the allegations against the certificate holder, and provide the certificate holder with the procedures necessary to request a hearing before the electrical board as described in WAC [296-46B-995](#).

Confiscation - Of an electrical contractor's license, administrator certificate, electrician certificate of competency, or training certificate.

(5) The department may confiscate a license or certificate that is counterfeit, revoked, expired, suspended, or altered. The individual may be referred to the county prosecutor for criminal prosecution under chapter 9A.72 RCW. The department may also file a civil action under chapter 19.28 RCW.

WAC 296-46B-995 Electrical board -Appeal rights and hearings

General.

- (1) Chapter [19.28](#) RCW provides the authority for the duties and responsibilities of the electrical board. Except as provided in chapter 19.28 RCW and this chapter, all proceedings will be conducted according to chapter [34.05](#) RCW, Administrative Procedure Act and chapter [10-08](#) WAC, Model rules of procedure. See chapter 34.05 RCW, Administrative Procedure Act for specific definitions not described in this chapter.
- (2) See RCW [19.28.311](#) for the composition of the electrical board.
- (3) The board adopts the current edition of the "Roberts' Rules of Order, Newly Revised."
- (4) The board will hold regular meetings on the last Thursday of January, April, July, and October of each year per RCW 19.28.311.
- (5) The director or the chairperson of the board may call a special meeting at any time.

- (6) Each board member must be notified in writing of the agenda, date, time, and place of each regular and special meeting. "Writing" includes by electronic mail, also known as "email," if the member has provided an email address for such notice.
- (7) The board or department may elect to have an appeal heard by the office of administrative hearings either tape recorded or transcribed by a court reporter; and the board may so elect regarding hearings or board reviews heard by the board as a whole.
- (8) A majority of the board constitutes a quorum for purposes of rendering any decision.
 - (a) If a majority does not attend a hearing or board review on an appeal, the board may either continue the hearing or board review to a date certain or may hear the testimony and arguments.
 - (b) If the board hears the testimony and arguments, the members of the board who are absent may make their decisions after hearing the tape recording or reading the transcript, of the hearing or board review.
 - (c) If the board selects the method in subsection (8)(b) of this section, at the time of the hearing, the board will set a date certain for the absent members to complete review of the record and for the board as a whole to vote on the decision. The vote in subsection (8)(b) and (c) of this section may occur by U.S. mail, facsimile or by electronic mail and will be determined by the board at the hearing; the members' votes will be public record.
- (9) All filings and documents for any matter before the board must be submitted to the chief electrical inspector, as secretary to the board, 7273 Linderson Way, P.O. Box 44460, Olympia, WA 98504-4460. Twenty copies of filings and documents must be submitted by ordinary mail, certified or registered mail, or by personal delivery. Filings and documents must be received no later than forty-five days prior to the scheduled meeting. When filings or documents are received after the deadlines, the filings and documents will be presented to the board at the second regularly scheduled board meeting.
- (10) All hearings before the board as a whole will be held on regularly scheduled meeting dates, as listed in subsection (4) of this section, unless the board determines that an alternate date is necessary.
- (11) All notices of appeal, with a certified check payable to the department in the amount specified in subsection (12), (14), (15), or (17) of this section if required, must be received in the office of the chief electrical inspector, as secretary to the board, at least forty-five days before the regularly scheduled board meeting at which the hearing would occur. A separate appeal fee is required for each entity's appeal of a specific violation type (e.g., for a single entity, the designated administrator, multiple alleged violations of RCW [19.28.061](#)(5)(a) – Designated administrator not available, RCW 19.28.061(5)(d) – Designated administrator fails to ensure proper permit is purchased, and RCW 19.28.061(5)(e) – Designated administrator fails to ensure corrections are made would require three of the applicable appeal amounts; one for each specific violation type). The total appeal fee for each entity seeking an appeal hearing is one thousand dollars maximum for all violation types. For original appeals to the board, the appellant must submit twenty copies of any written argument, briefs, testimony, or documents for the board's consideration at least forty-five days prior to the scheduled hearing. When appeals, written argument, briefs, testimony, or documents are received after the deadlines, the appeals, written argument, briefs, testimony, or documents will be presented to the board at the second regularly scheduled board meeting.

Appeals

- (12) Appeals of penalties issued by the department.
 - (a) A party may appeal a penalty issued by the department, pursuant to chapter [19.28](#) RCW and this chapter, to the board. The appeal will be assigned to the office of administrative hearings.
 - (b) The appeal must be filed within twenty days after the notice of the decision or penalty is given to the assessed party either by personal service or using a method by which the mailing can be tracked or the delivery can be confirmed, sent to the last known address of the assessed party and must be made by filing a written notice of appeal with the chief electrical inspector, as secretary to the board. The request for an appeal must be accompanied with a certified check payable to the department in the sum of two hundred dollars or ten percent of the penalty amount, whichever is less, but in no event less than one hundred dollars.
- (13) Appeals of proposed decisions issued by the office of administrative hearings.
 - (a) A party may appeal a proposed decision issued by the office of administrative hearings pursuant to chapter 19.28 RCW to the board. The appeal must be filed within twenty days after service of the decision and must be made by filing a written notice of appeal with the chief electrical inspector, as secretary to the board.
 - (b) The notice of appeal of a proposed decision must be received in the office of the chief electrical inspector, as secretary to the board, at least forty-five days before a regularly scheduled board meeting. If you want the board to consider a written argument, briefs, testimony, or other documents, it must be submitted at least forty-five days prior to the scheduled hearing.
- (14) Appeals of suspension, revocation, or nonrenewal.

- (a) An appeal of the suspension or revocation of a license or certificate of competency under RCW [19.28.241](#) and [19.28.341](#) or of nonrenewal of a license or certificate of competency under this chapter will be heard by the board in accordance with chapter [34.05](#) RCW and not assigned to the office of administrative hearings. The board will conduct the hearing and may elect to have the assistance of an administrative law judge in the proceeding.
- (b) The appeal must be filed within twenty days after the notice of suspension or revocation is served on the subject of said action, either by personal service or using a method by which the mailing can be tracked or the delivery can be confirmed, sent to the last known address of the subject and must be filed by written notice of appeal with the chief electrical inspector, as secretary to the board. The request for an appeal must be accompanied with a certified check payable to the department in the sum of two hundred dollars or, for appeals of nonrenewal due to outstanding final judgements owed to the department, the amount shall be two hundred dollars or ten percent of the outstanding penalty amount, whichever is less, but in no event less than one hundred dollars.

(15) Appeals of decisions on installation.

- (a) A party may seek board review for disputes relating to the interpretation and application of electrical/telecommunications installation or maintenance standards under RCW [19.28.111](#), [19.28.480](#), and [19.28.531](#). The board will conduct the hearing and may elect to have the assistance of an administrative law judge in the proceeding.
- (b) The notice of appeal, with the certified check payable to the department in the sum of two hundred dollars, must be received in the office of the chief electrical inspector, as secretary to the board, at least thirty days before a regularly scheduled board meeting. All parties must submit any written argument, briefs, testimony, or documents for the board's consideration at least twenty days prior to the scheduled hearing.

(16) Appeals of a continuing or basic trainee class or instructor for denials or revocations.

A party may appeal a decision issued by the department, pursuant to WAC [296-46B-970](#) (3)(e)(iv) to the superior court per RCW [34.05.542\(3\)](#).

(17) Appeals pertaining to engineer approval or electrical testing laboratory recognition and accreditation.

- (a) A party may appeal a decision issued by the department pursuant to WAC [296-46B-997](#) or WAC [296-46B-999](#). The appeal will be heard by the board in accordance with chapter 34.05 RCW and not assigned to the office of administrative hearings. The board will conduct the hearing and may elect to have the assistance of an administrative law judge in the proceeding.
- (b) The notice of appeal, with the certified check payable to the department in the sum of two hundred dollars for appeals pertaining to engineer approval or recognition and accreditation of an electrical testing laboratory, must be filed within twenty days after the notice of the department's decision is served on the subject of said action, either by personal service or using a method by which the mailing can be tracked or the delivery can be confirmed, sent the last known address of the subject and must be filed by written notice of appeal with the chief electrical inspector, as secretary to the board.

(18) Judicial review of final decisions of the board.

A party may seek judicial review of a final order of the board within thirty days after service of the decision.

Appeals of final decisions and orders must be done in accordance with chapter [34.05](#) RCW.

(19) If appeal(s) according to subsections (12), (13), (15), and (16) of this section are not filed or the appeal is not filed timely, the proposed decision or action becomes final with no further action on the part of the department or the board.

(20) Appeals - General requirements.

- (a) Appeals according to subsection (12), (15), or (16) of this section must specify the contentions of the appellant, and must for subsection (13) of this section specify to which conclusions of law and findings of fact the party takes exception. The appeal will be based on the record of the hearing. The board will not grant a hearing de novo.
- (b) In appeals under subsections (13), (14), (15), and (16) of this section, the issues to be adjudicated must be made as precise as possible, in order that the board may proceed promptly to conduct the hearing on relevant and material matter only.
- (c) In all appeals of chapter [19.28](#) RCW and this chapter heard before the office of administrative hearings or directly by the board, the department has the burden of proof by a preponderance of the evidence.
- (d) In all appeals of a decision by the office of administrative hearings to the board, the party aggrieved by the decision of the office of administrative hearings has the burden of proof by a preponderance of the evidence.

Appearance and practice before board.

(21) No party may appear as a representative in proceedings other than the following:

- (a) Attorneys at law qualified to practice before the supreme court of the state of Washington;
- (b) Attorneys at law qualified to practice before the highest court of record of another state, if the attorneys at law of the state of Washington are permitted to appear as representatives before administrative agencies of the other state, and if not otherwise prohibited by Washington law; or
- (c) An owner, officer, partner, or full-time employee of a firm, association, organization, partnership, corporation, or other entity who appears for the firm, association, organization, partnership, corporation or other entity.

(22) All persons appearing in proceedings as a representative must conform to the standards of ethical conduct required of attorneys before the courts of Washington. If a person does not conform to these standards, the board may decline to permit the person to appear as a representative in any proceeding before the board.

WAC 296-46B-997 Engineer approval.

- (1) This section describes the methods required to obtain recognition and accreditation of professional engineers registered under chapter [18.43](#) RCW to approve industrial utilization equipment. This section provides assurance to the general consuming public that electrical products have been tested for safety and identified for their intended use.
- (2) Industrial utilization equipment is considered to be safe when it is certified by an engineer accredited by the department.
 - (a) The department may declare industrial utilization equipment unsafe if:
 - (i) The equipment is not being manufactured or produced in accordance with all standards of design and construction and all terms and conditions set out in the certification report for the equipment referred to in this chapter;
 - (ii) The equipment has been shown by field experience to be unduly hazardous to persons or property;
 - (iii) An examination of the equipment or of the certification report for the equipment shows that the equipment does not comply with all applicable standards; or
 - (iv) An examination of the certification report or the equipment shows that the equipment cannot be installed in accordance with this chapter.
 - (b) When the department declares industrial utilization equipment unsafe, the department will notify the product owner and the certifying engineer in writing.

Accreditation - General.

- (3) The department's chief electrical inspector's office reviews requests for accreditation. Applicants must submit supporting data to document and verify the requirements of this section have been met.
- (4) The accreditation of an engineer will be valid for the period of three years.
- (5) On-site inspection of an engineer's facilities.
 - (a) On-site inspection of the facility(ies) may be required during the initial application process or the renewal process. Representative(s) of the department will evaluate for compliance with accreditation criteria.
 - (b) The applicant must pay all costs associated with the on-site inspection.
- (6) For purposes of chapter [19.28](#) RCW, all engineers who certify industrial utilization equipment offered for sale in the state of Washington must be accredited by the department.
- (7) Fees are payable as required in [WAC 296-46B-911](#).
- (8) The engineer must apply for renewal of accreditation at least thirty days prior to the accreditation expiration date. The department will renew accreditation for the period of three years or notify the renewing engineer of the department's reason(s) of refusal following receipt of the completed form and renewal fee.
- (9) The department accepts or denies engineer accreditation for engineers seeking to evaluate industrial utilization equipment within the state. Accreditation is determined when an engineer provides evidence to the department that all the requirements of this chapter are met. Accreditation is determined by the department and prior to making a determination, the department may require information and documentation to be provided by the engineer.
 - (a) Accreditation is subject to review when deemed necessary by the department. The engineer must pay all costs associated with on-site review.
 - (b) Every accredited engineer must continue to satisfy all the conditions specified in this chapter during the period of the accreditation. An engineer must furnish the department an annual report detailing the extent of its activities for the year. The report must include, but not be limited to:
 - (i) The number of industrial utilization equipment items approved;
 - (ii) Organizational structure of the engineer's company;

- (iii) Statement of ownership of the engineer's company; and
- (iv) Reports of litigation, which in any way were the result of or may affect any accreditation or testing of products covered by this chapter.

(c) The department will notify the applicant of the accreditation results. A letter of accreditation from the department is proof of the accreditation of the engineer.

(10) The engineer will be approved to certify industrial utilization equipment.

Suspension or revocation.

- (11) The department may suspend, revoke, or refuse to renew the department's accreditation of any engineer found to be in noncompliance with requirements of this chapter, the laws of the state of Washington, or submitting false information.
- (12) The department will serve written notice of intent prior to suspension, revocation, or refusal to renew the accreditation of an engineer.
- (13) An engineer, whose accreditation has been suspended, may not reapply for accreditation during the period of such suspension. An engineer, whose accreditation has been revoked, may reapply for accreditation no sooner than two years after the date of revocation of accreditation.

Business structure, practices, and personnel.

- (14) The engineer must be an independent, third-party organization with no organizational, managerial, financial, design, or promotional affiliation with owners, manufacturers, suppliers, installers, or vendors of products covered under the engineer's certification or evaluation programs.

The engineer must have an adequate diversity of clients or activity so that the loss or award of a specific contract regarding certification or evaluation would not be a deciding factor in the financial well-being of the engineer.

- (15) The engineer must adequately meet the following business practices:
 - (a) Perform the examinations, tests, evaluations, and inspections required under the certifications programs in accordance with the designated standards and procedures;
 - (b) Assure that reported values accurately reflect measured and observed data;
 - (c) Limit work to that for which competence and capacity is available;
 - (d) Treat test data, records, and reports as proprietary information;
 - (e) Respond to and attempt to resolve complaints contesting certifications and evaluation results;
 - (f) Maintain an independent relationship between its clients, affiliates, and other organizations so the engineer's capacity to give certifications and evaluations objectively and without bias is not adversely affected; and
 - (g) Notify the department within thirty calendar days should it become unable to conform to any of the requirements of this chapter.

- (16) Engineers accredited under this chapter must notify the department within thirty calendar days of any of the following:

- (a) Change in company name and/or address;
 - (b) Changes in major test equipment which affect the ability to perform work for which accredited; or
 - (c) Change in independent status.

- (17) The engineer must develop and maintain a certification or evaluation program plan that includes, but is not limited to:

- (a) The procedures and authority to ensure the product complies with the standard(s) established by the program;
 - (b) A quality control system;
 - (c) Verification and maintenance of facilities and/or equipment; or
 - (d) Sample selection as applicable for product certifications, and for component testing as necessary for evaluations.

The plan must demonstrate that the engineer has adequate facilities, and equipment to perform all certifications and testing for which it is accredited by the state of Washington. These elements must be contained in the engineer's operations control manual.

- (18) The engineer must develop and maintain a quality control system adequate to assure the accuracy and technical integrity of its work as follows:

- (a) The engineer's quality control system must include a quality control or engineer's operations control manual;

- (b) The quality control or engineer's operations control manual must be adequate to guide a testing technician or inspector in conducting the inspection, evaluation, and/or test in accordance with the test methods and procedures required for the engineer's certification and/or evaluation program(s); and
- (c) The engineer must have a current copy of the quality control or laboratory engineer operations control manual available for the engineer's use.

(19) The engineer must have training, technical knowledge, and experience adequate to perform the tests, examinations, and evaluations for the certification and/or evaluation activities for which recognition is sought.

(20) The engineer must:

- (a) Provide adequate safeguards protecting the engineer's status from the influence or control of manufacturers, vendors, owners, or installers of electrical products certified or tested by the engineer; and
- (b) Develop and maintain an adequate training program assuring that the engineer will be able to perform tasks properly and uniformly.

Recordkeeping and reporting - General.

- (21) The engineer must develop and maintain records and reports of those testing, inspection, certification, and evaluation activities associated with each piece of industrial utilization equipment. The engineer must retain these records for a minimum of three years.
- (22) The engineer must make available to the department, upon request, all records required by the department to verify compliance with this chapter.
- (23) See WAC [296-46B-906](#) for fee information. The engineer's evaluation report must include:
 - (a) Name and address of the engineer;
 - (b) Name of client;
 - (c) Address where the evaluated product is or will be installed;
 - (d) Designation of standards used to certify or test the product including edition and latest revision (e.g., UL 508, 17th Edition, Jan. 1999, Revision March 15, 2013);
 - (e) Description of the overall product evaluated to include full nameplate data and equipment type;
 - (f) A statement as to whether or not the results comply with the requirements of the standard;
 - (g) Pertinent test evaluation data and identification of tests or inspections including anomalies;
 - (h) The engineer's stamp; and
 - (i) Any condition of acceptability or restrictions on use/relocation.
- (24) Within ten calendar days after affixing the evaluation mark, the engineer must submit a copy of the evaluation report to their client submitted in any format acceptable to the client and engineer.

WAC 296-46B-999 Electrical testing laboratory requirements — General.

- (1) This section describes the methods required to obtain recognition and accreditation of electrical product(s) certification and/or field evaluation laboratories by the state of Washington. This section provides assurance to the general consuming public that electrical products have been tested for safety and identified for their intended use.
- (2) An electrical product is considered to be safe when it is either certified by a laboratory accredited by the department or labeled with a field evaluation mark by a laboratory accredited by the department.
 - (a) The department may declare electrical equipment unsafe if:
 - (i) The equipment is not being manufactured or produced in accordance with all standards of design and construction and all terms and conditions set out in the certification report for the equipment referred to in this chapter;
 - (ii) The equipment has been shown by field experience to be unduly hazardous to persons or property;
 - (iii) An examination of the equipment or of the certification report for the equipment shows that the equipment does not comply with all applicable standards; or
 - (iv) An examination of the certification report or the equipment shows that the equipment cannot be installed in accordance with this chapter.
 - (b) When the department declares an electrical product unsafe, the department will:
 - (i) Notify the product manufacturer and the appropriate testing laboratory in writing;
 - (ii) Notify the general public by:
 - (A) Report to the Consumer Product Safety Commission;
 - (B) A published article in the Electrical Currents;
 - (C) Internet web site posting; and/or

(D) News release.

Accreditation - General.

- (3) The department's chief electrical inspector's office reviews requests for accreditation or evaluation. Applicants must submit supporting data to document and verify the requirements of this section have been met.
- (4) The accreditation of a NRTL will be valid for the period of the laboratory's current OSHA NRTL accreditation. The accreditation of a non-NRTL will be valid for the period of five years from the date of the department's accreditation.
- (5) On-site inspection of a laboratory.
 - (a) On-site inspection of the laboratory may be required during the initial application process or the renewal process. Technically qualified representative(s) of the department will evaluate for compliance with accreditation criteria.
 - (b) On-site inspection is not required for NRTL-recognized laboratories requesting approval as certification laboratories using standards for which NRTL recognition has been approved.
 - (c) The department may waive on-site inspection for:
 - (i) Laboratories recognized or accredited by another state determined to provide an accreditation program acceptable to the department; or
 - (ii) NRTL-recognized laboratories requesting approval as certification laboratories for using other standards for which NRTL recognition has not been approved.
 - (d) The applicant must pay all costs associated with the on-site inspection.
- (6) For purposes of chapter [19.28](#) RCW, all laboratories which certify and/or field evaluate electrical products offered for sale in the state of Washington must be accredited by the department. A NRTL requesting approval as a certification laboratory will be approved for accreditation by the department upon completion of the application process.
- (7) Fees are payable as required in WAC [296-46B-911](#).
- (8) The laboratory must apply for renewal of accreditation at least thirty days prior to the accreditation expiration date. The department will renew accreditation for the period specified in subsection (4) of this section or notify the renewing laboratory of the department's reason(s) of refusal following receipt of the completed form and renewal fee. Accreditation may be renewed or refused for one or more electrical product category(ies).
- (9) The department accepts or denies laboratory accreditation for all laboratories within the state. Accreditation is determined when a laboratory provides evidence to the department that all the requirements of this chapter are met. Accreditation is determined by the department and prior to making a determination, the department may require information and documentation to be provided by the laboratory.
 - (a) Accreditation is subject to review when deemed necessary by the department. The laboratory must pay all costs associated with on-site review.
 - (b) Every accredited laboratory must continue to satisfy all the conditions specified in this chapter during the period of the accreditation. A non-NRTL accredited laboratory must furnish the department an annual report detailing the extent of its activities for the year. The report must include, but not be limited to:
 - (i) The number of factory inspections;
 - (ii) Organizational structure of the laboratory;
 - (iii) Statement of ownership of the laboratory;
 - (iv) Laboratory equipment verification;
 - (v) Client accreditation programs;
 - (vi) Reports of litigation, which in any way were the result of or may affect any accreditation or testing of products covered by this chapter; or
 - (vii) Assessment of recordkeeping (i.e., certification/evaluation plans, certification/evaluation reports).
 - (c) The department will notify the applicant of the accreditation results. A letter of accreditation from the department is proof of the accreditation of a laboratory.
- (10) The laboratory will be approved to certify only those categories identified and authorized by the department. The department will approve and list electrical product category(ies) the laboratory is qualified to certify or evaluate. The accreditation letter will indicate the electrical product category(ies) for which accreditation is issued.
- (11) The department may exclude specific electrical products from acceptance. When required, the laboratory must provide evidence, acceptable to the department, that the laboratory is qualified to certify or field evaluate the specific electrical product. Laboratory recognition as an NRTL for the standard(s) used to certify or field evaluate an electrical product will be acceptable evidence. The standards used for certification or field evaluation must be determined by the department to be acceptable and applicable to the electrical product being certified or field evaluated.

If a laboratory chooses to add additional standards prior to its expiration date, it must submit a request approval for Additional Standards form to the chief electrical inspector.

Suspension or revocation.

- (12) Any laboratory failing to comply with the requirements of this chapter or submitting false information may have accreditation revoked or suspended for one or more electrical product category(ies).
- (13) The department may suspend, revoke, or refuse to renew the accreditation of any laboratory found to be in noncompliance with this chapter or the laws of the state of Washington.
- (14) The department will serve written notice of intent prior to suspension, revocation, or refusal to renew the accreditation of a laboratory.
- (15) The laboratory must immediately notify all manufacturers whose products are covered by the accreditation that such products manufactured subsequent to the departmental revocation and offered for sale in the state of Washington can no longer bear the laboratory's label that identified it as a certified product in the state of Washington. A laboratory, whose accreditation has been suspended, may not reapply for accreditation during the period of such suspension. A laboratory, whose accreditation has been revoked, may reapply for accreditation no sooner than one year after the date of revocation of accreditation.

Business structure, practices, and personnel.

- (16) The laboratory must be an independent, third-party organization with no organizational, managerial, financial, design, or promotional affiliation with manufacturers, suppliers, installers, or vendors of products covered under its certification or evaluation programs.

The laboratory must have an adequate diversity of clients or activity so that the loss or award of a specific contract regarding certification or evaluation would not be a deciding factor in the financial well-being of the laboratory.

- (17) The laboratory must adequately meet the following business practices:
 - (a) Perform the examinations, tests, evaluations, and inspections required under the certifications programs in accordance with the designated standards and procedures;
 - (b) Assure that reported values accurately reflect measured and observed data;
 - (c) Limit work to that for which competence and capacity is available;
 - (d) Treat test data, records, and reports as proprietary information;
 - (e) Respond and attempt to resolve complaints contesting certifications and evaluation results;
 - (f) Maintain an independent relationship between its clients, affiliates, and other organizations so the laboratory's capacity to give certifications and evaluations objectively and without bias is not adversely affected; and
 - (g) Notify the department within thirty calendar days should it become unable to conform to any of the requirements of this chapter.
- (18) Laboratories accredited under this chapter must notify the department within thirty calendar days of any of the following:
 - (a) Change in company name and/or address;
 - (b) Changes in major test equipment which affect the ability to perform work for which accredited;
 - (c) Changes in principal officers, key supervisory and responsible personnel in the company including the director of testing and engineering services, director of follow-up services, and the laboratory supervisor; or
 - (d) Change in independent status.
- (19) The laboratory must develop and maintain a certification or evaluation program plan that includes, but is not limited to:
 - (a) The procedures and authority to ensure the product complies with the standard(s) established by the program;
 - (b) A quality control system;
 - (c) Adequate personnel to perform the certification or evaluation;
 - (d) Verification and maintenance of facilities and/or equipment; or
 - (e) Sample selection as applicable for product certifications, and for component testing as necessary for field evaluations.

The plan must demonstrate that the laboratory has adequate personnel, facilities, and equipment to perform all certifications and testing for which it is accredited by the state of Washington. These elements must be contained in the laboratory operations control manual.

- (20) The laboratory must develop and maintain a quality control system adequate to assure the accuracy and technical integrity of its work as follows:
 - (a) The laboratory's quality control system must include a quality control or laboratory operations control manual;

- (b) The quality control or laboratory operations control manual must be adequate to guide a testing technician or inspector in conducting the inspection, evaluation, and/or test in accordance with the test methods and procedures required for the laboratory's certification and/or evaluation program(s); and
- (c) The laboratory must have a current copy of its quality control or laboratory operations control manual available in the laboratory for use by laboratory personnel.

(21) Competent personnel who must have training, technical knowledge, and experience adequate to perform the tests, examinations, and evaluations for the certification and/or evaluation activities for which recognition is sought must staff the laboratory.

(22) The laboratory must:

- (a) Provide adequate safeguards protecting the employment status of personnel from the influence or control of manufacturers, vendors, or installers of electrical products certified or tested by the laboratory;
- (b) Develop and maintain a job description for each technical position category;
- (c) Ensure the competency of its staff to perform assigned tasks through individual yearly observation and/or examination by a person(s) qualified by the person who has technical responsibility for the laboratory;
- (d) Develop and maintain records of the results and dates of the observation or examination of personnel performance;
- (e) Maintain information on the training, technical knowledge, and experience of personnel; and
- (f) Develop and maintain an adequate training program assuring that new or untrained personnel will be able to perform assigned tasks properly and uniformly.

Recordkeeping and reporting - General.

(23) The laboratory must develop and maintain records and reports of those testing, inspection, certification, and evaluation activities associated with each program for which accreditation is sought. The laboratory must retain these records for a minimum of three years.

(24) The laboratory must make available to the department, upon request, all records required by the department to verify compliance with this chapter.

Recordkeeping and reporting - Certification.

(25) Certification reports must contain, as applicable:

- (a) Name and address of the laboratory;
- (b) Pertinent data and identification of tests or inspections;
- (c) Name of client;
- (d) Appropriate product title;
- (e) Designation of standards used to certify or test the product including edition and latest revision (e.g., UL 508, 17th Edition, Jan. 1999, Revision March 15, 2013);
- (f) Description and identification of the sample including, as necessary, where and how the sample was selected;
- (g) Identification of the test, inspection, or procedure as specified for certification or evaluation by the standard;
- (h) Known deviations, additions to, or exclusions from evaluation and certification activities in order to be appropriate for new or innovative products not contemplated by the standard;
- (i) Measurements, examinations, derived results, and identification of test anomalies;
- (j) A statement as to whether or not the results comply with the requirements of the standard;
- (k) Name, contact information, and signature of person(s) having responsibility for the report;
- (l) Raw data, calculations, tables, graphs, sketches, and/or photographs generated during certification or evaluation must be maintained if not included in the report;
- (m) Control forms documenting the receipt, handling, storage, shipping, and testing of samples;
- (n) Laboratory records of its quality control checks and audits for monitoring its test work associated with its certification programs, including:
 - (i) Records of products assurance (follow-up) test results; and
 - (ii) Records of detected errors and discrepancies and actions taken subsequent to such detection.
- (o) Record of written complaints and disposition thereof; and
- (p) A statement that records required by these criteria will be maintained for a minimum of three years after cessation of the certification or evaluation.

Recordkeeping and reporting - Field evaluation.

(26) The evaluation report must include:

- (a) Name and address of the laboratory;

- (b) Name of client;
- (c) Address where the evaluated product is or will be installed;
- (d) Designation of standards used to certify or test the product including edition and latest revision (e.g., UL 508, 17th Edition, Jan. 1999, Revision March 15, 2013);
- (e) Description and identification of the nonlisted and nonlabeled component(s) requiring evaluation by applicable standard(s);
- (f) Description of the overall product evaluated to include full nameplate data and equipment type;
- (g) A statement as to whether or not the results comply with the requirements of the standard;
- (h) Pertinent test evaluation data and identification of tests or inspections including anomalies;
- (i) Signature of person(s) having responsibility for the report;
- (j) Any condition of acceptability or restrictions on use/relocation;
- (k) Serial number(s) of the field evaluation label(s) applied must be included with the equipment identification;
and
- (l) Date the equipment label was affixed.

(27) Within thirty calendar days after affixing the evaluation mark, the laboratory must submit a copy of the evaluation report to their client submitted in any format acceptable to the client and testing laboratory.

Facilities and equipment.

- (28) The laboratory must provide adequate evidence of the calibration, verification, and maintenance of the facilities and equipment specified for each certification or evaluation.
- (29) Verification and maintenance of facilities and equipment must include as applicable, but not be limited to:
 - (a) Equipment description;
 - (b) Name of manufacturer;
 - (c) Model, style, serial number, or other identification;
 - (d) Equipment variables subject to calibration and verification;
 - (e) Statement of the equipment's allowable error and tolerances of readings;
 - (f) Calibration or verification procedure and schedule;
 - (g) Dates and results of last calibrations or verifications;
 - (h) Specified maintenance practices;
 - (i) Calibration and/or verification of equipment used;
 - (j) Name and contact information of personnel or outside contractor providing the calibration or verification service; and
 - (k) Traceability to National Institute of Standards and Technology or other equivalent standard reference authority.

Standards.

- (30) The laboratory must have copies available, for laboratory personnel use, of applicable standards and other documents referred to or used in performing each certification or test for which approval is sought.
- (31) If a laboratory desires to use a standard other than an ANSI standard, the department will evaluate the proposed standard to determine that it provides an adequate level of safety. The National Electrical Code, NFPA 70, will not be allowed to be the primary standard used to evaluate a product.

Product certification.

- (32) The electrical product certification program must contain test procedure(s), standard(s) used, certification agreement(s), method(s) of identification of products, follow-up inspection, and other laboratory procedures and authority necessary to ensure that the product complies with the standards (requirements) established by the program.
- (33) All components of certified or tested products must be labeled or evaluated for compliance with all standards and conditions of use applicable to such components.
- (34) The laboratory must publish an Annual Product Directory identifying products that are authorized to bear the laboratory's certification mark. The products directory must briefly describe the program, the products covered, the name of the manufacturer or vendor of the certified products, and the identification of the published standards or the compiled requirements on which the program is based. The product directory must be available to the public. Supplemental up-to-date information must be available to the public at the office of the laboratory during normal business hours.

Certification laboratory/manufacturer - Agreement.

(35) Measures to provide for manufacturer compliance with the provisions of the product standard and laboratory control of the use of the certification mark must be embodied in an agreement between the manufacturer and the certification laboratory. The certification agreement must:

- (a) Require the manufacturer to provide information and assistance as needed by the laboratory to conduct the necessary product conformity and production assurance evaluation;
- (b) Allow the laboratory's representative(s) access to the manufacturer's facilities during working hours for inspection and may allow audit activities without prior notice;
- (c) Restrict the manufacturer's application of certification marks to products that comply with requirements of the product standard;
- (d) Secure the manufacturer's agreement to the publication of notice by the certification laboratory for any product already available in the marketplace that does not meet the safety standard;
- (e) Require reevaluation of products whenever the standard covering the product is revised;
- (f) Require the laboratory to notify the manufacturer's personnel responsible for and authorized to institute product recall in the case of a hazard;
- (g) Provide for control of certification marks by the laboratory;
- (h) Require that the laboratory provide the manufacturer with a report of original product evaluation. The report must document conformity with applicable product standards by test results and other data; and
- (i) Require the identification of the manufacturer(s) of the product and the location(s) where the product is produced.

Certification mark.

(36) The laboratory owns the certification mark.

(37) The certification mark must be registered as a certification mark with the United States Patent and Trademark Office.

(38) The certification mark must:

- (a) Not be readily transferable from one product to another;
- (b) Be directly applied to each unit of production in the form of labels or markings suitable for the environment and use of the product. When the physical size of the unit does not permit individual marking, markings may be attached to the smallest package in which the unit is marketed;
- (c) Include the name or other appropriate identification of the certification laboratory;
- (d) Include the product category; and
- (e) The laboratory must have a system of controls and records for all marks. The records must include marks removed or otherwise voided. See WAC 296-46B-999(25).

(39) The certification mark may be applied to the product prior to authorizing the use of a certification mark on a product. The laboratory must:

- (a) Determine by examination and/or tests that representative samples of the product comply with the requirements (standards). Components of certified products must comply with the applicable safety requirements (standards) or be listed. Evaluation of the product design must be made on representative production samples or on prototype product samples with subsequent verification that factory productions are the same as the prototype;
- (b) Determine that the manufacturer has the necessary facilities, test equipment, and control procedures to ensure that continuing production of the product complies with the requirements; and
- (c) If the certification mark is not applied at the manufacturing facility, the laboratory must provide prior notification to the department of its intent to affix the certification mark in the field.

Certification laboratory product - Assurance/follow up.

(40) To verify continued product acceptability, the laboratory must develop and maintain a factory follow-up inspection program and manual to determine continued compliance of certified products with the applicable standard.

(41) The follow-up inspection file must include the:

- (a) Conditions governing the use of the certification mark on products;
- (b) Identification of the products authorized for certification;
- (c) Identification of manufacturer and plant location at which manufacture and certification are authorized;
- (d) Description, specifications, and requirements applicable to the product;
- (e) Description of processes needed for control purposes;
- (f) Description of the manufacturer's quality assurance program when used as part of the follow-up program;
- (g) Description of inspections and tests to be conducted by the manufacturer and the laboratory; and
- (h) Description of follow-up tests to be conducted in the laboratory.

(42) Follow-up procedures and activities must include:

- (a) Periodic inspections at the factory with testing at the factory or certification laboratory of representative samples selected from production and, if appropriate, from the market;
- (b) Periodic auditing or surveillance of the manufacturer's quality assurance program through the witnessing of manufacturer's tests, review of the manufacturer's records, and verification of the manufacturer's produced data;
- (c) Investigation of alleged field failures upon department request; and
- (d) Procedures for control of the use of the certification mark by:
 - (i) Keeping records of the release and use of certification marks;
 - (ii) Removal of marks from noncomplying products;
 - (iii) Return or destruction of unused marks when the authority to use the marks is terminated; and
 - (iv) Legal action.

(43) The frequency of laboratory follow-up inspections must not be less than four times per year during production, unless adequate data is provided to the department to justify less frequent inspections. If there is no production during the year, at least one follow-up inspection is to be completed. The frequency of follow-up inspections must be sufficient to provide a reasonable check on the method(s) the manufacturer exercises to assure that the product bearing the certification mark complies with the applicable standards.

Field evaluation - Requirements.

- (44) The field evaluation laboratory may perform evaluations on any products or product categories previously approved by the department. NRTL recognition may be accepted by the department as a basis for approval to perform field evaluations. Since OSHA does not review or recognize laboratories for field evaluation purposes, laboratories seeking accreditation from the department for field evaluation may be required to provide additional justification of capability such as, but not limited to: Recordkeeping, employee standards and proficiency, equipment requirements, and other requirements described in this chapter.
- (45) The scope of a field evaluation will depend on the status of the item to be evaluated as follows:
 - (a) A new piece of equipment must have a complete evaluation of all components and the assembly as provided by the manufacturer. For example: An industrial machine with a control panel, remote motors, sensors, controls, and other utilization equipment; and
 - (b) A product that has been modified internally or by an addition need have only those portions evaluated that were affected by the modification. For example: A switchboard with multiple sections that has a section added would only need the new section, the one section immediately adjacent, and any control modifications evaluated.
- (46) Each unit that receives a field evaluation mark applied by the field evaluation laboratory must have sufficient inspections and/or testing completed to ensure it is in essential conformance with the applicable product standard(s).
- (47) The laboratory may perform the preliminary evaluation in the manufacturer's facility. Final evaluation and acceptance of the product must be made on-site at the location of final installation, unless waived by the department.

Field evaluation mark.

- (48) Only laboratory personnel may apply the field evaluation mark after final acceptance of the product. The field evaluation label must be applied on-site at the location of the final installation, unless waived by the department.
- (49) The field evaluation laboratory must have a system of controls and records for all field evaluation marks it applies. The records must include labels removed or otherwise voided.
- (50) A field evaluated product may be relocated or fed from a different power source if not prohibited by the field evaluation mark or the field evaluation report.
- (51) The field evaluation mark must:
 - (a) Not be readily transferable from one product to another;
 - (b) Be directly applied by the laboratory personnel to each unit of production in the form of labels or markings suitable for the environment and use of the product;
 - (c) Include the name or other appropriate identification of the certification laboratory;
 - (d) Include a unique evaluation laboratory reference number; and
 - (e) Include a reference to the evaluation report or other notation if there are any limitations of use noted within the report.
- (52) The field evaluation laboratory must have a system of controls and records for all field evaluation marks it applies. The records must include labels removed or otherwise voided. See subsection (26) of this section.

Department of Labor and Industries
Field Services and Public Safety
Electrical Section
PO Box 44460
Olympia WA 98504-4460